REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8106180256 DOC.DATE: 81/06/10 NOTARIZED: NO DOCKET #
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH.NAME AUTHOR AFFILIATION
UHRIG,R.E. Florida Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION
VARGA,S.A. Operating Reactors Branch 1

SUBJECT: Clarifies compliance w/Item 2.1.4 of TMI Lessons Learned, containment isolation,per NRC 810508 request,Emergency procedures have been revised.Procedures require dedicated person to close & lock isolation valves during emergency.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 3 ENCL 0 SIZE: 1
TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME		COPIES LTTR	COPIES ENCL
ACTION:	VARGA,S.	04	13	1				
INTERNAL:	D/DIR,HUM FAC	08	1	1	DIR,DIV OF LIC		1	1
	I&E	06	2	2	NRC PDR	02	1	1
	OELD	11	1	0	OR ASSESS BR	10	1	0
	RAD ASMT BR		1	1	REG FILE	01	1	1
EXTERNAL:	ACRS	09	16	1	LPDR	03	1	1
	NSIC	05	1					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 40 ENCL 38 0

P.O. BOX 529100 MIAMI, FL 33152

FPL
FLORIDA POWER & LIGHT COMPANY

June 10, 1981
L-81-242

Office of Nuclear Reactor Regulation
Attention: Mr. Steven A. Varga, Chief
Operating Reactor Branch #1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Varga:

Re: Turkey Point Units 3 & 4
Docket Nos. 50-250 & 50-251
TMI Lessons Learned-Containment Isolation

The purpose of this letter is to respond to your request for clarification regarding our compliance with item 2.1.4, Containment Isolation, of the TMI Lessons Learned. Your May 8, 1981 letter from Mr. Varga to Dr. Uhrig noted that our earlier response overlooked the portion of the item which required a dedicated person to close the isolation valves "when the operation is complete." In addition, the response failed to mention that the normally closed manual isolation valves would be locked closed.

We would like to advise you that in November 1980, we not only revised our Emergency Procedures, but also our Administrative and Operating Procedures to require that a "dedicated person" or persons would close and lock any normally closed manual isolation valve which might be open during plant operation in the event of an emergency, or when the operation is complete. We would also clarify our position regarding the dedicated person by stating that this person is not restricted to the Nuclear Control Center Operator, but could also be his designee or other assigned plant personnel.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/JEM/ras

cc: Mr. J. P. O'Reilly, Region II
Harold F. Reis, Esquire

RECEIVED
JUN 17 1981
U.S. NUCLEAR REGULATORY COMMISSION

A001
S
3/0

8106180256
P