

dm²
dv

JUL 01 1981


Docket Nos. 50-280
and 50-251

Dr. Robert E. Uhrig, Vice President
Advanced Systems and Technology
Florida Power and Light Company
Post Office Box 529100
Miami, Florida 33152

DISTRIBUTION

Dockets
NRC PDR
L PDR
TERA
NSIC
ORB#1 Rdg
DEisenhut
OELD
IE-3
ACRS-10
SVarga
MGrotenhuis
CParrish
Gray File

GLainas
PCheck



SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER
FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSs DESIGNED
BY W AND CE

We have completed a generic review on this subject and conclude that
no further action is necessary since the concerns expressed in Item
II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not
considered applicable to NSSSs with inverted U-tube steam generators
such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required
to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original signed by:
S. A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

cc: See next page

8107100013 810701
PDR ADDCK 05000250
P PDR

OFFICE	ORB#1:DL	ORB#1:DL					
SURNAME	MGrotenhuis	SVarga					
DATE	7/1/81:ds	7/1/81					



Robert E. Uhrig
Florida Power and Light Company

cc: Mr. Robert Lowenstein, Esquire
Lowenstein, Newman, Reis and Axelrad
1025 Connecticut Avenue, N.W.
Suite 1214
Washington, D. C. 20036

Environmental and Urban Affairs Library
Florida International University
Miami, Florida 33199


Mr. Norman A. Coll, Esquire
Steel, Hector and Davis
1400 Southeast First National
Bank Building
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager
Turkey Point Plant
Florida Power and Light Company
P. O. Box 013100
Miami, Florida 33101

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Resident Inspector
Turkey Point Nuclear Generating Station
U. S. Nuclear Regulatory Commission
Post Office Box 1207
Homestead, Florida 33030



JUL 01 1981

Docket Nos. 50-250
and 50-251

Dr. Robert E. Uhrig, Vice President
Advanced Systems and Technology
Florida Power and Light Company
Post Office Box 529100
Miami, Florida 33152

DISTRIBUTION

Dockets GLainas
NRC PDR PCheck
L PDR
TERA
NSIC
ORB#1 Rdg
DEisenhut
OELD
IE-3
ACRS-10
SVarga
MGrotenhuis
CParrish
Gray File

SUBJECT: ELIMINATION OF ITEM II.K.2.19 (SEQUENTIAL AUXILIARY FEEDWATER
FLOW ANALYSIS) REQUIREMENT FOR LICENSEES WITH NSSSS DESIGNED
BY W AND CE

We have completed a generic review on this subject and conclude that
no further action is necessary since the concerns expressed in Item
II.K.2.19 of the TMI Action Plan, as clarified in NUREG-0737, are not
considered applicable to NSSSSs with inverted U-tube steam generators
such as those designed by Westinghouse and Combustion Engineering.

We consider this item to be complete and therefore you are not required
to respond to Item II.K.2.19 of the TMI Action Plan.

Sincerely,

Original signed by:
S. A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

cc: See next page

OFFICE	ORB#1:DL	ORB#1:DL					
SURNAME	MGrotenhuis	SVarga					
DATE	7/1/81:ds	7/1/81					



Robert E. Uhrig
Florida Power and Light Company

cc: Mr. Robert Lowenstein, Esquire
Lowenstein, Newman, Reis and Axelrad
1025 Connecticut Avenue, N.W.
Suite 1214
Washington, D. C. 20036

Environmental and Urban Affairs Library
Florida International University
Miami, Florida 33199

Mr. Norman A. Coll, Esquire
Steel, Hector and Davis
1400 Southeast First National
Bank Building
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager
Turkey Point Plant
Florida Power and Light Company
P. O. Box 013100
Miami, Florida 33101

Mr. Jack Shreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Resident Inspector
Turkey Point Nuclear Generating Station
U. S. Nuclear Regulatory Commission
Post Office Box 1207
Homestead, Florida 33030

