



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-250

TURKEY POINT PLANT UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 74
License No. DPR-31

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated January 25, 1977, as supplemented on March 20 and May 1, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8201140072 811207
PDR ADOCK 05000250
PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-31 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 74, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Marga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: DEC 7 1981



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-251

TURKEY POINT PLANT UNIT NO. 4

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 68
License No. DPR-41

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated January 25, 1977, as supplemented on March 20 and May 1, 1980, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.




2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-41 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 68, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1-2
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: DEC 7 1981

ATTACHMENT TO LICENSE AMENDMENTS

AMENDMENT NO. 74 TO FACILITY OPERATING LICENSE NO. DPR-31

AMENDMENT NO. 68 TO FACILITY OPERATING LICENSE NO. DPR-41

DOCKET NOS. 50-250 AND 50-251

Revise Appendix A as follows:

Remove Page

Table 4.1-1

Insert Page

Table 4.1-1

TABLE 4.1-1

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND
TEST OF INSTRUMENT CHANNELS

<u>CHANNEL DESCRIPTION</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>TEST</u>	<u>REMARKS</u>
1.a. Nuclear Power Range (Check, Calibrate and Test only applicable above 10% of rated power.)	S(1) M*(4)	D(2) Q*(4)	M(3)	1) Load vs. flux curve or ΔT vs reactor power curve 2) Thermal power calculation 3) Signal to ΔT ; bistable action (permissive, rod stop, trips) 4) Upper & lower detectors for symmetric offset (+5 to -5%).
b. Power Distribution Map			M(1)	1) Following initial loading and prior to operation above 75% power. 2) Once per effective full power month. 3) Confirm hot channel factor limits.
2. Nuclear Intermediate Range	S(1) [†]	N.A.	P(2)	1) Once/shift up to 50% R.P. 2) Log level; bistable action (permissive, rod stop, trip)
3. Nuclear Source Range	S(1)	N.A.	P(2)	1) Once/shift when in service. 2) Bistable action (alarm, trip)
4. Reactor Coolant Temperature	S [†]	R	B/W(1) [†] (2) [†]	1) Overtemperature- ΔT 2) Overpower- ΔT
5. Reactor Coolant Flow	S [†]	R	M [†]	
6. Pressurizer Water Level	M [†]	R	M [†]	
7. Pressurizer Pressure	S [†]	R	M [†]	
8. 4 kv Voltage & Frequency	N.A.	R**	R	Reactor protection circuits only
9. Analog Rod Position	S [†]	R	M [†]	With step counters.