

Yellow

JAN 21 1982

Florida Power and Light Company
ATTN: Dr. R. E. Uhrig, Vice President
Advanced Systems and Technology
P. O. Box 529100
Miami, FL 33152

Gentlemen:

Subject: Report Nos. 50-250/81-33 and 50-251/81-33

This refers to the routine safety inspection conducted by Mr. R. J. Vogt-Lowell of this office on October 26 - November 25 and December 7-18, 1981, of activities authorized by NRC Operating License Nos. DPR-31 and DPR-42 for the Turkey Point facility. Our preliminary findings were discussed with Mr. J. K. Hays, Plant Manager, at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

During the inspection, it was found that certain activities under your license appear to violate NRC requirements. These items and references to pertinent requirements are listed in the Notice of Violation enclosed herewith as Appendix A. Elements to be included in your response are delineated in Appendix A.

This also confirms the telephone conversation on November 6, 1981, between Mr. H. C. Dance, Chief, Reactor Projects Section 2C, of our office and Mr. K. N. Harris, Assistant Manager, Nuclear Energy, of your staff. This conversation expressed our concern over the plugging of the boron injection tank inlet piping. This concern relates to the conditions or circumstances that caused this event and the adequacy and scope of your corrective actions taken to prevent recurrence. Consequently, your reply should describe in particular those actions taken or planned to improve the effectiveness of your management controls in these areas.

We have examined actions you have taken with regard to previously reported unresolved items. The status of these items is discussed in the enclosed report.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC's Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).

8204010438 820323
PDR ADOCK 05000250
PDR

[Faint, illegible text covering the majority of the page, possibly bleed-through from the reverse side.]

[A faint rectangular stamp or box at the bottom right corner of the page.]

JAN 21 1982

Florida Power & Light Company

2

The responses directed by this letter and the enclosures are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,



R. C. Lewis, Director
Division of Resident and
Reactor Project Inspection

Enclosures:

1. Appendix A, Notice of Violation
2. Inspection Report Nos. 50-250/81-33
and 50-251/81-33

cc w/encl:
H. E. Yaeger, Site Manager

bcc w/encl:
NRC Resident Inspector
Document Management Branch
State of Florida

~~RII~~

~~RVogt-Lowell:dt
1/ /82~~

~~RII~~

~~KLandis
1/ /82~~

RII

HCD
HCDance
1/20/82

RII

PJ
PJKellogg
1/2 /82

~~RII~~

~~RCLewis
1/21 /82~~

2015