

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8209080348 DOC. DATE: 82/09/01 NOTARIZED: NO DOCKET #
 FACIL: 50-000 Generic Docket 05000000
 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co. 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light Co. 05000251
 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME: AUTHOR AFFILIATION
 SCHMIDT, A.D. Steam Generator Owners Group
 SCHMIDT, A.D. Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 EISENHUT, D. Division of Licensing

SUBJECT: Forwards summary of comments sent to all PWR owners re proposed steam generator generic requirements presented at 820729 meeting. Comments intended to facilitate review by all PWR owners.

DISTRIBUTION CODE: YG01S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Generic Material with no Specific Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	EISENHUT, D. 01.	1 1		
INTERNAL:	NRR LICCIARDO	1 1	REG. FILE	03. 1 1
	RGN1 07	1 1	RGN2 08	1 1
	RGN3 09	1 1	RGN4 10	1 1
	RGN5 11	1 1		
EXTERNAL:	ACRS 12	10 10	NRCI PDR 02	1 1
	NSIC 04	1 1	NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 21

1. The first part of the report is a general description of the project and its objectives. It includes a brief history of the project and a statement of the problem being investigated. The second part of the report is a description of the methods used in the study. This includes a description of the experimental design, the subjects, and the procedures used to collect and analyze the data.

3. The third part of the report is a description of the results of the study. This includes a description of the data collected and a discussion of the findings. The fourth part of the report is a conclusion and a discussion of the implications of the findings. This includes a summary of the main findings and a discussion of the limitations of the study and the need for further research.

5. The fifth part of the report is a list of references. This includes a list of all the sources used in the study, including books, articles, and other documents. The sixth part of the report is an appendix. This includes any additional information that is relevant to the study, such as raw data, questionnaires, and other documents.

7. The seventh part of the report is a list of figures and tables. This includes a list of all the figures and tables included in the report, along with a brief description of each. The eighth part of the report is a list of footnotes. This includes any additional information that is relevant to the study, such as corrections or clarifications.

9. The ninth part of the report is a list of acknowledgments. This includes a list of all the people and organizations that have helped with the study, including the sponsor, the principal investigator, and the research assistants.

11. The tenth part of the report is a list of appendices. This includes any additional information that is relevant to the study, such as raw data, questionnaires, and other documents.

13. The eleventh part of the report is a list of references. This includes a list of all the sources used in the study, including books, articles, and other documents.

15. The twelfth part of the report is a list of footnotes. This includes any additional information that is relevant to the study, such as corrections or clarifications.

17. The thirteenth part of the report is a list of acknowledgments. This includes a list of all the people and organizations that have helped with the study, including the sponsor, the principal investigator, and the research assistants.

19. The fourteenth part of the report is a list of appendices. This includes any additional information that is relevant to the study, such as raw data, questionnaires, and other documents.

21. The fifteenth part of the report is a list of references. This includes a list of all the sources used in the study, including books, articles, and other documents.

23. The sixteenth part of the report is a list of footnotes. This includes any additional information that is relevant to the study, such as corrections or clarifications.

25. The seventeenth part of the report is a list of acknowledgments. This includes a list of all the people and organizations that have helped with the study, including the sponsor, the principal investigator, and the research assistants.

27. The eighteenth part of the report is a list of appendices. This includes any additional information that is relevant to the study, such as raw data, questionnaires, and other documents.


29. The nineteenth part of the report is a list of references. This includes a list of all the sources used in the study, including books, articles, and other documents.

31. The twentieth part of the report is a list of footnotes. This includes any additional information that is relevant to the study, such as corrections or clarifications.

33. The twenty-first part of the report is a list of acknowledgments. This includes a list of all the people and organizations that have helped with the study, including the sponsor, the principal investigator, and the research assistants.

35. The twenty-second part of the report is a list of appendices. This includes any additional information that is relevant to the study, such as raw data, questionnaires, and other documents.

37. The twenty-third part of the report is a list of references. This includes a list of all the sources used in the study, including books, articles, and other documents.



September 1, 1982

Mr. Darrell Eisenhut
 Director of Licensing
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Dear Mr. Eisenhut:

My letter of August 18, 1982 transmitted to you a copy of our initial correspondence with U.S. Pressurized Water Reactor owners relative to proposed steam generator generic requirements that you presented in our meeting of July 29, 1982.

We have received comments on those proposed requirements from participants in the July 29, 1982 meeting and sent them to all PWR owners for their review and further comment.

I have enclosed a summary of the comments sent to all PWR owners to keep you informed of our progress. However, I want to emphasize that these comments are just a first step, intended to facilitate the review and comments by all PWR owners. As additional comments are obtained, discussed, and resolved, there are likely to be changes in the enclosed summary.

Very truly yours,

A. D. Schmidt
 Chairman
 SGOG Executive Committee

ADS/nfb
 Attachment

cc: D. Adams, Louisiana Power & Light
 R. Acosta, Florida Power & Light
 J. Berga, EPRI - Washington Office
 S. Brown, EPRI - NDE Center
 A. Curtis, Rochester Gas & Electric
 R. Garnsey, C.E.G.B.
 S. Green, EPRI - SGPO
 G. Lainas, NRC
 J. Lang, EPRI - SGPO
 W. Layman, EPRI - NSAC
 D. Love, Arkansas Power & Light
 R. Mecredy, Rochester Gas & Electric
 L. Parscale, Arkansas Power & Light
 R. Shell, TVA
 B. Snow, Rochester Gas & Electric
 A. Sudduth, Duke Power Company
 T. Tramm, Commonwealth Edison
 L. White, Rochester Gas & Electric
 T. Ziegler, TVA

Y601

8209080348 820901
 PDR ADDCK 05000250
 PDR

DRAFT COMMENTS ON DRAFT NRC REQUIREMENTS

II.1 Prevention and Detection of Loose Parts and Foreign Objects

General Comment: The frequency of occurrence and the potential tube degradation associated with the secondary side debris in S/G's makes it prudent to perform secondary side inspections at the next scheduled refueling outage for operating plants and prior to start-up for plants under construction.

Suggested wording for the "REQUIREMENT" section:

- o During the next scheduled refueling outage, perform secondary side visual examination of the entire periphery (and tube lane), at and above the tubesheet, using an appropriate visual technique such as fiber optics or TV camera.
- o Additional inspections/corrective actions (if required) should be site specific and should be appropriate and consistent with the findings of the secondary side visual examinations. However, should these examinations reveal secondary side tube wear, a secondary side LPMS shall be installed and operated on each S/G.
- o Review current QA/QC procedures and improve as appropriate to preclude introduction of foreign objects in S/G primary/secondary sides.

II.4 Improved Eddy Current Techniques

Requirement:

1. ". . . and discriminating among multiple defects" should be deleted from text. (Error on NRC's part)
4. The emphasis on wear type defects is overplayed. The significant issue is the presence of long/gradual discontinuities which can be missed with the differential coil. It will be difficult in practice to generate a conservative standard; the defect mechanism must exhibit a known regularity in its growth before a standard can be identified.

II.5 Primary to Secondary Leakage Limit

No Comment.

II.7 Secondary Water Chemistry Program

It should be made clear that plants shut down for steam generator repairs would be required to commit to a water chemistry program, but not to actually implement the program, prior to restart. Further, unless the repairs are due to corrosion phenomenon, no commitment should be required.

II.8 Condenser Inservice Inspection Program

As with II.7, plants shut down for steam generator repairs would be required to commit to, but not to implement, a condenser inspection program prior to restart. Further, unless the corrosion was related to a condenser problem, no commitment should be required.

More definition of the condenser inspection program is needed in order to assess its impact.

II.9 Upper Inspection Ports

General Comment: The requirement to add upper inspection ports on S/G's should be evaluated on a case-by-case basis for all plants.

Discussion:

Upper inspection ports are a minimal value on a generic basis such that a backfit requirement, independent of a plant specific problem, is not technically justified, nor is it cost effective.

- From an inspection standpoint, the only meaningful use for upper inspection ports is to monitor flow slot hourglassing (as a warning to U-bend cracking at the apex of row 1 tubes due to displacement of the U-bend "legs"). This problem is unique to the Westinghouse design, so a requirement to include all recirculating S/G's is not appropriate. Additionally, this problem can/has been dealt with effectively in alternate ways, i.e., eddy current testing of tight radius U-bends and preventive plugging of row 1 tubes. Thus, the upper ports are of very minimal benefit even with S/G's having the flow slot configuration. Other U-bend problems (i.e., tube cracking at the transition between the bend and the straight portion of the tube) would have to be detected using eddy current methods. Obviously, a visual inspection would not detect this condition. The only real benefit of additional ports would be to assist in removing tubes (should a condition develop which would necessitate a tube pull). However, this should be a plant specific consideration because:
 1. low probability of this occurrence,
 2. a pre-established upper port may not be located in the appropriate location to address a future problem,
 3. initial cost is significantly high (Note: 1976 dollars; approximate cost in excess of \$200,000 to add 1 upper inspection port at Turkey Point Unit 4) such that with the high time value of money, "front end" implementation of upper ports becomes wastefully expensive. This is probably also true for a pre-operational plant, but must also be looked at on a case-by-case basis because the costs will be related to where the plant is in their construction/start-up sequence. This will obviously affect the cost of the modification, and more significantly, could affect schedule.

III.1.1 RCS Pressure Control During SGTR

This requirement is vague and should be revised prior to issuance as written. This requirement could result in a very extensive analytical and procedure revision effort, which is not warranted.

At the July 29 meeting, the NRC stated that the objective of this requirement was to ensure that the 1/2 hour assumed for equalization of primary and secondary pressure was met.

Rather than set an arbitrary goal for the elapsed time to primary system depressurization, it is suggested that the goal be stated in terms of radioactivity releases to the environment. The ability of a given plant to achieve the initial primary cooling, depressurization of the primary below the secondary safety valve lift pressure, and the isolation of the affected steam generator prior to overfilling the unit could then be evaluated. The objective would be to show that the release limit for that particular unit and site should not be exceeded.

III.1.3.1 Safety Injection Signal Reset

No Comment.

III.1.3.2 Containment Isolation and Reset

No Comment.

V.1.4 Standard Technical Specification Limit for Coolant Iodine Activity

No comment on the first requirement. The additional requirement for low pressure plants is without basis. First, the basis for the current Ginna specification is extremely conservative and assumes that all RCS iodine was released to the environment. Secondly, analyses are currently being performed by RG&E relating to this issue. Thus, any requirement would be premature at this time. Thirdly, a requirement such as imposed here could have a substantial impact. A number of plants have, in the past, exceeded the proposed NRC special limit. The existence of such a reduced limit in those cases would have had severe financial impact, including a requirement for additional fuel purchases to replace leaking fuel and reduce a plant output or additional outage time while waiting for fuel delivery.

NRC Proposed Actions

These proposed activities could have significant impact on utilities. For example, several steam generator sleeve designs are complete at this time. NRC guidance on sleeve design at this time could have severe financial impact on the utilities wishing to use sleeves. Additional information and technical interchanges between the NRC and industry would be helpful in assessing the potential impact of the proposed actions.

