

TABLE 4.1-2 (SHEET 2 OF 3)

MINIMUM FREQUENCIES FOR EQUIPMENT AND SAMPLING TESTS

11.	Reactor Coolant System Leakage	Evaluate	Daily	NA
12.	Diesel Fuel Supply	Fuel inventory	Weekly	10
13.	Spent Fuel Pit	Boron Concentration	Prior to refueling	NA
14.	Secondary Coolant	I-131 Concentration	Weekly**	10
15.	Vent Gas & Particulates	I-131 & Particulate Activity	Weekly*	10
16.	Fire Protection Pump & Power Supply	Operable	Monthly	45
17.	Turbine Stop and Control Valves, Reheater Stop and Intercept Valves	Closure	Monthly***	45
18.	LP Turbine Rotor Inspector (w/o rotor disassembly)	V, MT, PT	Every 5 Years	6 Years
19.	Spent Fuel Cask Crane Interlocks	Functioning	Within 7 days	7 days when crane is being used to maneuver spent fuel cask



1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960

5. TWO residual heat removal pumps shall be operable.
  6. TWO residual heat exchangers shall be operable.
  7. All valves, interlocks and piping associated with the above components and required for post accident operation, shall be operable, except valves that are positioned and locked. Valves 864-A, B, 862-A, B, 865-A, B, C; 866-A, B shall have power removed from their motor operators by locking open the circuit breakers at the Motor Control Centers. The air supply to valve 758 shall be shut off to the valve operator.
- b. During power operation, the requirements of 3.4.1a may be modified to allow one of the following components to be inoperable (including associated valves and piping) at any one time except for the cases stated in 3.4.1.b.2. If the system is not restored to meet the requirements of 3.4.1a within the time period specified, the reactor shall be placed in the hot shutdown condition. If the requirements of 3.4.1a are not satisfied within an additional 48 hours the reactor shall be placed in the cold shutdown condition. Specification 3.0.1 applies to 3.4.1.b.
1. ONE accumulator may be out of service for a period of up to 4 hours.
  2. ONE of FOUR safety injection pumps may be out of service for 30 days. A second safety injection pump may be out of service, provided the pump is restored to operable status within 24 hours. TWO of the FOUR safety injection pumps shall be tested to demonstrate operability before initiating maintenance of the inoperable pumps.
  3. ONE channel of heat tracing on the flow path may be out of service for 24 hours.\*
  4. ONE residual heat removal pump may be out of service, provided the pump is restored to operable status within 24 hours. In addition the other residual heat removal pump shall be tested to demonstrate operability prior to initiating maintenance of the inoperable pump.

\*See reference (11) on page B.3.4-2

