

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707070383      DOC. DATE: 87/06/30      NOTARIZED: NO      DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C      05000250  
          50-251 Turkey Point Plant, Unit 4, Florida Power and Light C      05000251  
 AUTH. NAME                      AUTHOR AFFILIATION  
 REYES, L. A.                      Region 2, Office of Director  
 RECIP. NAME                      RECIPIENT AFFILIATION  
 WOODY, C. O.                      Florida Power & Light Co.

SUBJECT: Ack receipt of 870615 L-87-219 ltr. Informs that continued use of operator to manually isolate Valve CV 2201, intake cooling water temp control valve, until results of tube cleaning sys evaluated acceptable.

DISTRIBUTION CODE: IE01D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 PD	1	McDONALD, D	2
INTERNAL:	AEOD	1	DEDRO	1
	ENF LIEBERMAN	1	NRR ROE, M. L	1
	NRR/DOEA DIR	1	NRR/DREP/EPB	1
	NRR/DREP/RPB	2	NRR/DRIS DIR	1
	NRR/EMAS/ILRB	1	OGC/HDS2	1
	<u>REG FILE</u>	1	RES DEPY GI	1
	RGN2 FILE 01	1		
EXTERNAL:	LPDR	1	NRC PDR	1
	NSIC	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 20

JUN 30 1987

*Official*

Florida Power and Light Company  
ATTN: Mr. C. O. Woody  
Group Vice President  
Nuclear Energy Department  
P. O. Box 14000  
Juno Beach, FL 33408

Gentlemen:

SUBJECT: UNRESOLVED ITEM 86-10-03

Thank you for your letter L-87-219, dated June 15, 1987. The continued use of an operator to manually isolate valve CV 2201, Intake Cooling Water Temperature Control Valve, until the results of a tube cleaning system are evaluated is acceptable.

Should you have any questions, please contact us.

(Original signee by V. Brownlee for)

Luis A. Reyes, Director  
Division of Reactor Projects

cc: C. M. Wethy, Vice President  
Turkey Point Nuclear Plant  
C. J. Baker, Plant Manager  
Turkey Point Nuclear Plant  
L. W. Bladow, Plant QA Superintendent  
J. Arias, Jr., Regulatory and  
Compliance Supervisor

bccs: NRC Resident Inspector  
Document Control Desk  
State of Florida

RII  
*[Signature]*  
HChristensen:vyg  
6/24/87

RII  
*[Signature]*  
BWilson  
6/24/87

RII  
*[Signature]*  
DVerrelli  
6/30/87

RII  
*[Signature]*  
VBrownlee  
6/30/87

8707070383 870630  
PDR ADDCK 05000250  
G PDR

10  
ZE01 -