

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707200109 . . . DOC. DATE: 87/06/23 NOTARIZED: NO DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251  
 AUTH. NAME AUTHOR AFFILIATION  
 ROBERTS, E. W. EG&G Idaho, Inc. (subs. of EG&G, Inc.)  
 ROBERTS, E. W. Idaho National Engineering Laboratory  
 RECIP. NAME RECIPIENT AFFILIATION  
 CARRINGTON, M. Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Forwards EGG-NTA-7738, "TMI Action-NUREG-0737 (II.D.1)  
 Relief & Safety Valve Testing, Turkey Point Units 3 & 4,"  
 informal technical evaluation rept. Addl info required to  
 reconfirm that GDC 14, 15 & 30 met.

DISTRIBUTION CODE: H001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+31  
 TITLE: File Location Distribution: NRR Docket 50

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
INTERNAL:	REG FILE 01	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1

*add: D. McDonald*

TOTAL NUMBER OF COPIES REQUIRED: LTR 4 ENCL 4

1871

1

1

W. G. B. 1871

1871

1871



Idaho National Engineering Laboratory

June 23, 1987

50-250  
251

Mr. M. Carrington, Program Manager  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

TRANSMITTAL OF TECHNICAL EVALUATION REPORT, "TMI ACTION--NUREG-0737  
(II.D.1) RELIEF AND SAFETY VALVE TESTING, TURKEY POINT UNITS 3  
AND 4," DOCKET NOS. 50-250 AND 50-251, EGG-NTA-7738, June 1987 -  
EWR-154-87

Ref: INEL Technical Assistance To The Office of Nuclear Reactor  
Regulation, "Evaluation of OR Licensing Actions - NUREG 0737,  
II.D.1" (FIN A6492)

Dear Mr. Carrington:

In accordance with the above reference, INEL has been providing  
technical assistance to the Nuclear Regulatory Commission, Office of  
Nuclear Reactor Regulation for the evaluation of plant-specific  
licensing submittals regarding qualification of safety and relief  
valves.

The enclosed report is an evaluation of the Turkey Point Units 3  
and 4 (Docket Nos. 50-250 and 50-251) submittal. This evaluation  
found that the licensee, Florida Power & Light Co., has not provided  
acceptable submittals and responses to requests for additional  
information to reconfirm that the General Design Criteria 14, 15, and  
30 of Appendix A to 10 CFR 50 have been met.

Very truly yours,

E. Wayne Roberts, Manager  
NRC Headquarters Support

CLN,c1n

Enclosure:  
As Stated

cc: C. G. Hammer, NRR-EMEB  
G. L. Jones, DOE-ID  
P. T. Kuo, NRR-EMEB  
A. S. Masciantonio, NRR-EMEB  
E. J. Sullivan, Jr., NRR-EMEB  
J. O. Zane, EG&G Idaho (w/o Encl.)

Add: D. McDonald

H001

11



Idaho, Inc.

11428 Rockville Pike

Suite 410

Rockville, MD 20852

8707200109 870623  
PDR ADOCK 05000250  
P PDR