ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

R

I

D

S 1

Å

D

D

S

R

D

S

Å

D

D

S

ACCESSION NBR:8810050299DOC.DATE: 88/09/15NOTARIZED: NODOCKET #FACIL:50-250Turkey Point Plant, Unit 3, Florida Power and Light C0500025050-251Turkey Point Plant, Unit 4, Florida Power and Light C05000251AUTH.NAMEAUTHOR AFFILIATION05000251WILSON, B.A.Region 2, Ofc of the DirectorRECIP.NAMERECIPIENT AFFILIATIONCONWAY, W.F.Florida Power & Light Co.

SUBJECT: Ack receipt of 880829 ltr informing NRC of steps taken to correct violations noted in Insp Rept 50-250/88-14.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR / ENCL / SIZE: TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT ID CODE/NAME PD2-2 PD	COPII LTTR 1	ES ENCL 1	RECIPIENT ID CODE/NAME EDISON,G	COP LTTR 2	IES ENCL 2	
INTERNAL:	AEOD	1	1	DEDRO	1	1	
	NRR MORISSEAU, D	1	1	NRR/DLPQ/PEB 11	1	1	
	NRR/DLPQ/QAB 10	1	1	NRR/DOEA DIR 11	1	1	
	NRR/DREP/EPB 10	1	1	NRR/DREP/RPB 10	2	2	a
	NRR/DRIS DIR 9A	1	1	NRR/PMAS/ILRB12	1	1	
•	NUDOCS-ABSTRACT	1	1	OE-IHEBERMAN, J	1	1	
,	OGC/HDS2	1	1	REG FILE 02	1	1	
	RES/DSIR DEPY	l	1	REG FILE 02 RGN2 FILE 01	1	1	
RNAL:	LPDR	1	l	NRC PDR	1	1	
	NSIC	1	1		•		•

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 23

SEP 1 5 1988

Florida Power and Light Company ATTN: Mr. W. F. Conway Senior Vice President - Nuclear P. O. Box 14000 Juno Beach, FL 33408-0420

Gentlemen:

SUBJECT: REPORT NOS. 50-250/88-14 AND 50-251/88-14

Thank you for your response of August 29, 1988, to our Notice of Violation issued on July 29, 1988, concerning activities conducted at your Turkey Point facility. We have evaluated your response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

We appreciate your cooperation in this matter.

Sincerely,

Original signed by R. V. Crlenjak

Bruce A. Wilson, Chief Reactor Projects Branch 2 Division of Reactor Projects

cc: J. S. Odom, Vice President Turkey Point Nuclear Plant J. E. Cross, Plant Manager Turkey Point Nuclear Plant L. W. Bladow, Plant QA Superintendent J. Arias, Jr., Regulatory and Compliance Supervisor State of Florida

 bcc: G. E. Edison, Project Manager, Project Directorate II-2, Division of Reactor Projects, NRR
NRC Resident Inspector DRS Technical Assistant Document Control Desk

RII CChristensen:er 09/15/88

10050299

RCrlenjak 10/88 09/