

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8811230275 DOC. DATE: 88/11/18 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME: CONWAY, W.F.
 AUTHORITY AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: [REDACTED]
 RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Special rept: on 81102-04, breached fire barriers & other fire protection sys impairments.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	EDISON, G	1 1		
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	ACRS WYLIE	1 1	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	ARM/DCTS/DAB	1 1
	DEDRO	1 1	NRR/DEST/ADS 7E	1 0
	NRR/DEST/CEB 8H	1 1	NRR/DEST/ESB 8D	1 1
	NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
	NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
	NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
	NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/QAB 10	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RAB 10	1 1
	NRR/DREP/RPB 10	2 2	NRR/DRIS/SIB 9A	1 1
	NUDOCS-ABSTRACT	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RES/DSR/PRAB	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	EG&G WILLIAMS, S	4 4	FORD BLDG HOY, A	1 1
	H ST LOBBY WARD	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC HARRIS, J	1 1
	NSIC MAYS, G	1 1		

*Wrong docket on
 label
 hd*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 41

*1/A-2
 [Signature]*

R
I
D
S
/
A
D
S
/
A
D
S
/
A
D
S



NOVEMBER 18 1988

L-88-501

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Special Report - Breached Fire Barriers and
Other Fire Protection System Impairments

In accordance with Technical Specification 6.9.3.c., the attached
Special Report is provided for your information.

Should there be any questions on this information, please contact
us.

Very truly yours,

W. F. Conway
Senior Vice President - Nuclear

WFC/RHF/gp

Attachment

cc: Malcolm L. Ernst, Acting Regional Administrator, Region II,
USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8811230275 881118
PDR ADOCK 05000251
S PDC

IF22
||

SPECIAL REPORT

NOVEMBER 18, 1988

FIRE PROTECTION SYSTEM IMPAIRMENTS REQUIRING NRC NOTIFICATION

PURPOSE:

Technical Specification (TS) 3.14.5.b requires the submission of a report to the NRC if a non-functional fire barrier penetration is not returned to functional status within 7 days. TS 3.14 also states that certain other conditions require NRC notification. In accordance with the above requirements, this special report is being generated in order to notify the NRC.

EVENT:

The five impairments listed below have been open in excess of TS permitted time limits.

Fire Protection Impairment (FPI) Number 2019 was issued for a detector which was required to be placed out of service in order to permit cutting and welding. This was required to support the Reactor Coolant Pump Penetration Canister work. This breach was closed Nov. 2, 1988, following completion of the work on the penetration canister.

FPI 2020 was opened in order to perform work on raceway penetrations in the control room floor for the Emergency Response Data Acquisition and Display System (ERDADS). This breach was closed on Oct. 24, 1988, following completion of the work on the on the raceway penetrations.

FPI 2022 was opened to remove the fire insulation from the 4B Charging Pump in order to permit removal of the Charging Pump motor. This breach will be closed following completion of the work on the Charging Pump motor.

FPI 2059 was opened due to an inoperable lock on fire door 058-1. This breach will be closed following repair of the door lock.

FPI 2066 was opened for raceway penetrations in the control room wall for the Safety injection mini recirculation system. This breach was closed on Nov. 4, 1988, following completion of the work in the raceway penetration.

See attachment 1 for details.

CAUSE AND CORRECTIVE ACTIONS:

The above impairments were caused by either plant modifications or equipment maintenance. The plant continues to implement the compensatory measures as applicable.

Attachment 2 identifies impairments which are now closed but were previously reported as open.

ATTACHMENT 1

FPI #	FEATURE TYPE	OPENED	CLOSED
2019	DETECTOR ALARM POINT 9	10/12/88	11/02/88
2020	BARRIER 106F CRN-C-1985	10/12/88	10/24/88
2022	BARRIER, THERMOLAG 4F141	10/13/88	/ /
2059	DOOR 58-1	10/25/88	/ /
2066	BARRIER 106S, CRN-C-2079	10/28/88	11/04/88

ATTACHMENT 2
 FIRE PROTECTION SYSTEM IMPAIRMENTS PREVIOUSLY
 NOT REPORTED CLOSED

FPI #	FEATURE TYPE	OPENED	CLOSED
1333	BARRIER 028N	02/29/88	10/17/88
1359	PENETRATION 067F-E002	01/18/88	10/22/88
1383	PENETRATION 061E-E001-4	01/20/88	10/15/88
1384	PENETRATION 016N-E005	01/20/88	10/21/88
1385	PENETRATION 013E-E001 & E002	01/20/88	10/21/88
1387	PENETRATION 063E-E001 THRU E004	01/20/88	10/20/88
1390	PENETRATION 046W-E004	01/20/88	10/20/88
1456	BARRIER, MANWAY	06/08/88	11/01/88
1475	BARRIER, THERMOLAG 071	06/17/88	10/10/88
1482	BARRIER 002C	06/23/88	11/04/88
1486	BARRIER 106F	06/23/88	10/21/88
1491	BARRIER 028N	06/23/88	10/17/88
1517	BARRIER 030F	03/29/88	11/07/88
1518	BARRIER, THERMO-LAG	03/25/88	11/01/88
1519	BARRIER, THERMO-LAG	03/25/88	11/01/88
1538	PENETRATION 097W-E007	04/12/88	10/17/88
1539	PENETRATION 023S-E002-5	04/12/88	10/15/88
1540	PENETRATION 108AF-E002	04/12/88	10/25/88
1547	PENETRATION 071W-E002	04/12/88	10/20/88
1553	PENETRATION 070W-M003-6	04/18/88	10/15/88
1884	BARRIER 047F	09/17/88	10/18/88
1885	DOOR 15-1	09/17/88	10/18/88
1886	DETECTOR ALARM POINT 22	09/18/88	10/18/88
1901	DETECTOR ALARM POINT 45	09/23/88	10/12/88
2019	DETECTOR ALARM POINT 9	10/12/88	11/02/88
2020	BARRIER 106F CRN-C-1985	10/12/88	10/24/88
2066	BARRIER 106S, CRN-C-2079	10/28/88	11/04/88



2
2