Section

<u>Title</u>

ىر

<u>Page</u>

1

ł

ł

	TECHNICAL SPECIFICATIONS	
1.0	DEFINITIONS	1-1
1.1	Safety Limits	1-1
1.2	Limiting Safety System Settings	1-1
1.3	Limiting Conditions for Operation	1-1
1.4	Operable - Operability	1-1
1.5	Containment Integrity	1-2
1.6	Protective Instrumentation Logic	1-2
1.7	Instrumentation Surveillance	1-3
1.8	Reportable Event	1-3
1.9	Action	1-4
1.10	Core Alteration	1-4
1.11	Rated Power (R.P.)	1-4
1 19	Thermal Dower	1-4
1 1 2	Design Dowen	1-4
1 14	Dose Rauivelent I-131	1-4
1 15	Dose Equivalent 1-101 Dowor Tilt	1-5
1.10	Panatan Caalant Dumpa	1-5
1.17	Lew Dewer Drugies Meste	1-0
1.10	Low Power Physics Tests	1-0
1.18	Engineered Safety Features	1-5
1.19	Reactor Protection System	1-5
1.20	Safety Related Systems and Components	1-6
1.21	Per Annum	1-6
1.22	• Reactor Coolant System Pressure Boundary Integrity	1-6
1.23	Coolant Loop	1-6
1.24	E-Average Disintegration Energy	1-7
1.25	Gas Decay Tank System	1-8
1.26	Ventilation Exhaust Treatment System'	1-8
1.27	Process Control Program (PCP)	1-8
1.28	Offsite Dose Calculation Manual (ODCM)	1-8
1.29	Dose Equivalent I-131	1-8
1.30	Purge-Purging	1-9
1.31	Venting	1-9
1.32	Site Boundary	1-9
1.33	Unrestricted Area	1-9
1.34	Member(s) of the Public	1-9
1.35	Heavy Loads	1-9
1.36	Operational Mode-Modes	1-9
1.37	Staggered Test Basis	1-9
0.0	CARDONY I IMING AND I IMINING CARDONY OVODEN CROODINGG	0 1 1
2.0	SAFETI LIMITS AND LIMITING SAFETI SISTEM SETTINGS	2.1-1
2.1	Safety Limit, Reactor Core	2.1-1
2.2	Safety Limit, Reactor Coolant System Pressure	2.2-1
2.3	Limiting Safety System Setting, Protective	
	Instrumentation	2.3-1
3.0	LIMITING CONDITIONS FOR OPERATION	3.0-1
3.1	Reactor Coolant System	3.1-1
	Operational Components	3.1-1
	Pressure-Temperature Limits	$3.1-2^{3}$
	Leakage	3.1-3
	Maximum Reactor Coolant Activity	3.1-4
	Reactor Coolant Chemistry	3.1-6
	DNR Parameters	3.1-7
		VIA 1

-i-

SS12230029 SS1220 PDR ADOCK 05000250 PDC

Amendment Nos. _____ and

TABLE OF CONTENTS (Continued)

¢

يدُ

2

, <u>Section</u>	Title	Page
3.2	Control Rod and Power Distribution Limits	3.2-1
	Control Rod Insertion Limits	3.2-1
	Misaligned Control Rod	3.2-2
	Rod Drop Time	3.2-2
	Inoperable Control Rods	3.2-2
	Control Rod Position Indication	3.2-3
`	Power Distribution Limits	3.2-3
	In-Core Instrumentation	3.2-7
	Axial Offset Alarms	3.2-8
3.3	Containment	3.3-1
3.4	Engineering Safety Features	3.4-1
	Safety Injection and RHR Systems	3.4-1
	Emergency Containment Cooling Systems	3.4-3
10	Emergency Containment Filtering System	3.4-4
	Component Cooling System	3.4-4
	Intake Cooling Water System	3.4-5
•	Post Accident Containment Vent System	3.4-6
• -	Control Room Ventilation	3.4-6
3.5	Instrumentation	3.5-1
3.6	Chemical and Volume Control System	3.6-1
3.7	Electrical Power Sources	3.7-1
3.8	Steam Power Conversion Systems	3.8-1
3.9	, Radioactive. Materials Release	3.9-1
	Liquid Effluents	3.9-1
	Gaseous Effluents	3.9-9
9 1 0 '	Containerized Effluents	3.9-19
3.1U 9 11	Keruenny Misselleneeus Bediesetius Meteriole Seureer	3.10-1
3.11 9.10	Miscellaneous Radioactive Materials Sources	3.11-1
3.12 9.19	Cask Handling	3.12-1
3.13 9.14	Snudders Bing Ducto sting Costone	3.13-1
3.14 9.15	Fire Protection Systems	3.14-1
3.13	Overpressure Mitigating System	3.15-1
3.10	Reactor Coolant System Pressure Isolation valves	3.16-1
3.17	Spent Fuel Storage	3.17-1
3.18	Auxiliary Feedwater System	3.18-1
3.18	Condensate Storage Tanks	3.19-1
3.20	Standby Feedwater System	3.20-1
4.0 SURVEILL	ANCE REQUIREMENTS	4.0-1
4.1	Operational Safety Review	4.1-1
4.2	Reactor Coolant System In Service Inspection	4.2-1
4.3	Reactor Coolant System Integrity	4.3-1
4.4	Containment Tests	4.4-1
	Integrated Leakage.Rate Test - Post Operational	4.4-1
	Local Penetration Tests	4.4-2
	Isolation Valves	4.4-3
	Residual Heat Removal System	4.4-3
	Tendon Surveillance	4.4-4
	End Anchorage Concrete Surveillance	4.4-6
	Liner Surveillance	4.4-7
4.5	Safety Injection	4.5-1
4.6	Emergency Containment Cooling Systems	4.6-1
4.7 ,	Emergency Containment Filter System, Post Accident	
	Containment Vent Systems and Control Room	
	Ventilation System	4.7-1

Amendment Nos. _____ and

1

• * * *

.

. . .

a ,



<u>TableTitle</u>

a

1.1	Operational Modes
3.5-1	Instrument Operating Conditions for Reactor Trip
3.5-2	Engineering Safety Features Actuation
3.5-3	Instrument Operating Conditions for Isolation Functions
3.5-4	Engineered Safety Feature Set Points
3.5-5	Accident Monitoring Instrumentation
3.7-1	Battery Charger Allowable Out-of-Service Times
3.9-1	Radioactive Liquid Waste Sampling and Analysis Program
3.9-2	Radioactive Liquid Effluent Monitoring Instrumentation
3.9-3	Radioactive Gaseous Waste Sampling and Analysis Program
3.9-4	Radioactive Gaseous Effluent Monitoring Instrumentation
3.13-1	Deleted
3.14-1	Fire Detection System
3.14-2	Fire Hose Stations
3.16-1	Primary Coolant System Pressure Isolation Valves
3.17-1	Spent Fuel Burnup Requirements for Storage in Region II of the Spent Fuel Pit
3.18-1	Auxiliary Feedwater System Operability
4.1-1	Minimum Frequencies for Checks, Calibrations and Test of Instrument Channels
4.1-2	Minimum Frequencies for Equipment and Sampling Tests
4.1-3	Minimum Frequency for Surveillance of Radioactive Liquid Effluent Monitoring Instrumentation
4.1-4	Minimum Frequency for Surveillance of Rádioactive Gaseous Effluent Monitoring Instrumentation
4.2-1	Deleted
4.2-2	Minimum Number of Steam Generators to be Inspected During Inservice Inspection
4.2-3	Steam Generator Tube Inspection
4.8-1	Diesel Generator Test Schedule
4.8-2	Battery Surveillance Requirements
4.12-1	Radiological Environmental Monitoring Program
4.12-2	Reporting Levels for Radioactivity Concentrations in Environmental Samples
4.12-3	Detection Capabilities for Environmental Sample Analysis
4.18-1	Minimum Frequencies for Safety Related Systems Flow Path Verification
6.2-1	Minimum Shift Crew Composition

I

3.7 **Blectrical Power Sources**

3.7.1 AC Sources

Operating

Limiting Condition For Operation

- 3.7.1.1 As a minimum, the following AC electrical power sources shall be **OPERABLE:**
 - TWO 239 KV-4160 volt start-up transformers with associated 8. circuits, and
 - TWO diesel generators with on site supply of 40,000 gallons of b. fuel available.

APPLICABILITY: MODES 1, 2, 3, 4

ACTION:

- With either start-up transformer inoperable, а.
 - Demonstrate the OPERABILITY of both diesel generators by 1) performing surveillance requirement 4.8.1.a.4 separately, for each diesel generator, if the diesel generator has not been successfully tested within the past 24 hours, and at least once per 24 hours while the startup transformer is inoperable,
 - Notify the NRC within 4 hours of declaring a startup 2) transformer inoperable.
 - 3) a) For the unit with its startup transformer inoperable in MODE 1, restore the inoperable start-up transformer to **OPERABLE** status within 24 hours or reduce THERMAL POWER to \leq 30% RATED POWER within the next 6 hours. Restore the inoperable startup transformer to **OPERABLE** status prior to increasing THERMAL POWER TO > 30% RATED POWER.
 - b) With the unit in MODES 2, 3 or 4, restore the inoperable startup transformer to OPERABLE status within 24 hours or place the unit in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
 - 4) Restore the inoperable startup transformer to OPERABLE status within 30 days or place the remaining unit in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

3.7-1

- b. With either diesel generator inoperable, for reasons other than the performance of surveillance requirements 4.8.1.c and 4.8.1.d,
 - 1) Demonstrate the OPERABILITY of the remaining diesel generator by performance of surveillance requirement 4.8.1.a.4 within 8 hours and once per 24 hours thereafter while the diesel generator is inoperable,
 - 2) Verify that the engineered safety features of the remaining diesel generator are OPERABLE within 2 hours,
 - 3) Verify the OPERABILITY of the required startup transformers and their associated circuits within 1 hour, and
 - 4) Restore the inoperable diesel generator to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 12 hours and in COLD SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously.
- c. With either diesel generator inoperable, for the performance of surveillance requirements 4.8.1.c and 4.8.1.d,
 - 1) Demonstrate the OPERABILITY of the remaining diesel generator by performance of surveillance requirement 4.8.1.a.4 within 24 hours and once per 24 hours thereafter while the diesel generator is inoperable,
 - 2) Verify that the engineered safety features of the remaining diesel generator are OPERABLE; within 2 hours
 - 3) Verify the OPERABILITY of the required startup transformers and their associated circuits within 1 hour, and
 - 4) Restore the inoperable diesel generator to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

3.7-2

- d. With one start-up transformer and one diesel generator inoperable,
 - 1) Demonstrate the OPERABILITY of the remaining diesel generator by performance of surveillance requirement 4.8.1.a.4 within 24 hours and once per 24 hours thereafter while the diesel generator is inoperable,
 - 2) Verify that the engineered safety features of the remaining diesel generator are OPERABLE, within 2 hours
 - 3). Verify the OPERABILITY of the remaining startup transformer and its associated circuits within 1 hours, and
 - 4) For the unit with the inoperable startup transformer:
 - a) Restore the inoperable startup transformer to OPERABLE status within 12 hours or reduce THERMAL POWER to \leq 30% RATED POWER within the next 6 hours. Restore the inoperable startup transformer to OPERABLE status prior to increasing THERMAL POWER TO > 30% RATED POWER.
 - b) With the unit with the inoperable startup transformer in MODES 2, 3 or 4, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
 - 5) Notify the NRC within 4 hours of declaring both a startup transformer and a diesel generator inoperable.
 - 6) For the unit with an OPERABLE startup transformer:

3.7-3

a) Restore the inoperable diesel generator to OPERABLE status within 72 hours of declaring the diesel generator inoperable or place the remaining unit in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

- e. With two diesel generators inoperable, verify the OPERABILITY of at least one startup transformer and be in at least HOT STANDBY within the next 12 hours and in COLD SHUTDOWN within the following 30 hours. Otherwise initiate corrective action to restore at least one startup transformer to OPERABLE status as soon as possible and then be in at least HOT STANDBY in the next 12 hours and in COLD SHUTDOWN in the following 30 hours. This ACTION applies to both units simultaneously.
- f. With two startup transformers inoperable,
 - 1) Demonstrate the OPERABILITY of both diesel generators by performance of surveillance requirement 4.8.1.a.4 within 8 hours and once per 24 hours thereafter while the startup transformer(s) are inoperable,
 - 2) Verify that the engineered safety features of both diesel generators are OPERABLE within 2 hours,
 - 3) a) With the affected unit(s) in MODE 1, reduce THERMAL POWER to ≤ 30% RATED POWER within the next 12 hours. Restore the inoperable startup transformer to OPERABLE status prior to increasing THERMAL POWER to > 30% RATED POWER. This ACTION applies to both units simultaneously.
 - b) With the affected unit(s) in MODES 2, 3, or 4 be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
 - 4) Notify the NRC within 4 hours of declaring both startup transformers inoperable.

and

AC Sources

Shutdown

Limiting Condition For Operation

- 3.7.1.2 As a minimum, the following AC electrical power sources shall be OPERABLE:
 - a. One start-up transformer and associated circuits or one offsite circuit supplying at least one 4160 volt bus, A or B, and
 - b. One diesel generator capable of supplying power to its associated OPERABLE 4160 volt bus, with an onsite supply of 40,000 gallons of fuel available.

APPLICABILITY*: MODES 5 and 6

ACTION:

With less than the above minimum required AC electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS, positive reactivity changes, movement of irradiated fuel, or crane operation with loads over the fuel storage pool, and within 8 hours, depressurize and vent the Reactor Coolant System through a vent greater than or equal to 2.2 square inches. In addition, when in MODE 5 with the reactor coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status and initiate corrective action to increase RCS inventory as soon as possible.

3.7-5

* (Caution - If the opposite unit is in MODES 1, 2, 3 or 4, see Specification 3.7.1.1)

___ and

3.7.2 DC Sources

Operating

Limiting Condition For Operation

- 3.7.2.1 As a minimum, the following DC electrical sources shall be **OPERABLE:**
 - 125 volt DC batteries no. 3A, 3B, 4A and 4B, and a.
 - Battery chargers 3B, 4A and 4S and any two of battery b. chargers 3A, 4B or 3S.

APPLICABILITY: MODES 1, 2, 3, 4

ACTION:

- With one of the required batteries inoperable, restore the a. inoperable battery to OPERABLE status within 24 hours or be in at least HOT STANDBY within 12 hours and COLD SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously.
- b. With one or more of the required battery chargers inoperable, restore one or more of the inoperable battery chargers to OPERABLE status within the time limits specified in Table 3.7-1; otherwise be in at least HOT STANDBY within the next 12 hours and COLD SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously.

3.7-6

.

• • • • • •

r

8

.

• 5 •

. .

	······································	BATTER	BATTERY CHARGERS (BC) 3B, 4A, AND 4S		
		No-BC's Inoperable	One-BC Inoperable	Two-BC's Inoperable	Three BC's Inoperable
Battery Chargers (BC)	No-BC's Inoperable	N/A	72 hours	24 hours	1 hour
3S	One-BC Inoperable	N/A	72 hours	1 hour	1 hour
	Two-BC's Inoperable	24 hours	1 hour	1 hour	1 hour
	Three-BC's Inoperable	1 hour	1 hour	1 hour	1 hour

BATTERY CHARGER ALLOWABLE OUT-OF-SERVICE TIMES

Amendment Nos. _____ and ____

•

۶ ۲

. t.

.

DC Sources

SHUTDOWN

Limiting Condition For Operation

3.7.2.2 As a minimum, three batteries and associated full-capacity chargers* shall be OPERABLE.

<u>APPLICABILITY**:</u> MODES 5 and 6

ACTION:

With one or more of the required 125 volt batteries inoperable and/or associated chargers inoperable, immediately suspend all operations involving CORE ALTERATIONS, positive reactivity changes, or movement of irradiated fuel; initiate corrective action to restore the required batteries and associated chargers to OPERABLE status as soon as possible, and within 8 hours, depressurize and vent the Reactor Coolant System through a vent greater than or equal to 2.2 square inches.

3.7-8

* (defined as a designated charger or a spare charger)

** (Caution - If the opposite unit is in MODES 1, 2, 3 or 4, see Specification 3.7.2.1)

3.7.3 On-S Power Distribution



<u>Operating</u>

Limiting Condition For Operation

- 3.7.3.1 The following electrical busses shall be energized in the specified manner with the 4160 volt and 480 volt Load Center tie breakers open between redundant busses within the unit and between the busses of Units 3 and 4:
 - a. One train of AC Busses consisting of:
 - 1) 4160 Volt Bus A,
 - 2) 480 Volt Load Center Busses A and C, and
 - 3) 480 Volt Motor Control Center Busses A*** and C vital sections.
 - b. One train of AC Busses consisting of:
 - 1) 4160 Volt Bus B
 - 2) 480 Volt Load Center Busses B and D, and
 - 3) 480 Volt Motor Control Center Bus B, vital section.
 - c. 480 volt Motor Control Center Bus D*, ***vital section.
 - d. Opposite unit trains of AC Busses consisting of:
 - 1) 4160 Volt Busses, A and B,** and
 - 2) Motor Control Centers A, B, and C vital sections

APPLICABILITY: MODES 1, 2, 3, 4

ACTION:

- a. With one of the required trains of AC busses not energized, reenergize the train within 8 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. This ACTION does not apply to the Limiting Condition for Operations sections 3.7.3.1.c or 3.7.3.1.d.
- b. With one of the required trains of AC busses of the opposite unit inoperable, for periodic refueling outage maintenance, re-energize the train within 7 days or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the following 30 hours.
- c. With one of the required trains of AC busses of the opposite unit inoperable, for reasons other than ACTION b above, re-energize the train within 72 hours or be in at least HOT STANDBY within 6 hours and COLD SHUTDOWN within the following 30 hours.
- d. With 480 volt Motor Control Center D vital section not energized, for periodic refueling outage maintenance, verify the OPERABILITY of both diesel generators within 1 hour and reenergize it within 24 hours or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the following 30 hours.

^{* 480} Volt Motor Control Center D is common to Unit 3 and 4.

^{**} One 4160 Volt Bus may be de-energized while the 480 Volt Load Centers are cross-tied with the associated unit in shutdown modes 5 or 6 and the opposite unit at power upon issuance of an engineering evaluation.

^{***} Loss of the normal or backup sources of power to Motor Control Centers (MCC) 3A, or D necessitates the application of ACTION f, g, or h and does not imply the inoperability of any single MCC unless both sources of power are lost concurrently.

On-Site Power Distribution

OPERATING (Continued)

- e. With 480 volt Motor Control Center D vital section not energized, for reasons other than ACTION d above, verify the OPERABILITY of both diesel generators within 1 hour and re-energize it within 8 hours or be in at least HOT STANDBY within the next 12 hours and COLD SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously.
- f. With the 480 volt Motor Control Center D vital section normal source of power or backup source of power inoperable, for periodic refueling outage maintenance, verify the OPERABILITY of both diesel generators within 1 hour and restore the inoperable power supply to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the following 30 hours.
- g. With the 480 volt Motor Control Center D vital section normal source of power or backup source of power inoperable, for reasons other than ACTION f above, verify the OPERABILITY of both diesel generators within 1 hour and restore the inoperable power supply to OPERABLE status witin 72 hours or be in at least HOT STANDBY within the next 12 hours and COLD SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously.
- h. With the 480 volt Motor Control Center 3A vital section normal source of power inoperable, for periodic refueling outage maintenance, verify the OPERABILITY of both diesel generators within 1 hour and restore the inoperable power supply to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and COLD SHUTDOWN within the following 30 hours.
- i. With the 480 volt Motor Control Center 3A vital section normal source of power inoperable, for reasons other than ACTION h, above, verify the OPERABILITY of both diesel generators within 1 hour and restore the inoperable power supply to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 12 hours and in COLD SHUTDOWN within the following 30 hours. This ACTION applies to both units simultaneously.

ONSITE POWER DISTRIBUTION

SHUTDOWN

Limiting Condition For Operation

3.7.3.2 As a minimum, the following electrical busses shall be energized:

a. One train of AC emergency busses consisting of one 4160 volt and two associated 480 volt AC busses.

APPLICABILITY*: MODES 5 and 6

ACTION:

With any of the above required electrical busses not energized, immediately suspend all operations involving CORE ALTERATIONS, positive reactivity changes, or movement of irradiated fuel, initiate corrective action to energize the required electrical busses as soon as possible, and within 8 hours, depressurize and vent the RCS through a vent greater than or equal to 2.2 square inches.

* (Caution - If the opposite unit is in MODES 1, 2, 3, or 4, see Specification 3.7.3.1)

, , . • и -• " " . , .

4.8 EMERGENCY POWER SYSTEM PERIODIC TESTS

<u>Applicability</u>: Applies to periodic testing and surveillance requirements for the emergency power system.

- <u>Objective</u>: To verify that the emergency power system will respond promptly and properly.
- Specification: The following tests and surveillance shall be performed as stated:
 - 1. <u>Diesel Generator</u>
 - a. In accordance with the frequency specified in Table 4.8-1 with diesel generator surveillances performed nonconcurrently by:
 - 1. Verifying fuel in the day tank, the engine-mounted fuel tank, and the fuel storage tank contains a total greater than 40,000 gallons.
 - 2. Verifying that a fuel transfer pump can be started and transfers fuel from the Diesel Oil Storage Tank to the Day Tank.
 - 3. Verifying that the diesel generator starts from ambient conditions and accelerated to provide $60\pm$ 1.2 Hz frequency and 4160 ± 624 volts in \leq 15 seconds*.
 - 4. Verifying that the generator is synchronized, loaded to ≥ 2500 kw within 10 minutes* and operates for ≥ 60 minutes.
 - 5. Verifying that the diesel generator cooling system functions within design limits during the 1-hour full load test required by Specification 4.8.1.a.5.
 - b. At least once per 92 days by verifying that a sample of diesel fuel from the fuel storage tank is within acceptable limits when checked for viscosity, water, and sediment.

^{*}The diesel generator start (15 sec) from normal conditions shall be performed at least once per 184 days in these surveillance tests. All other engine starts for the purpose of this surveillance testing may be preceded by an engine prelube period and/or other warmup procedures recommended by the manufacturer so that mechanical stress and wear on the diesel engine is minimized.

- c. During each Unit 4 refueling outage by:
 - 1. Subjecting the diesel to an inspection in conjunction with its manufacturer's recommendations for this class of standby service.
- d. At least once per refueling, not to exceed 24 months by:
 - 1. Verifying the diesel generator's capability to:
 - (a) Reject a load of greater than or equal to 380 kw without exceeding 4160 ± 624 volts and 60 ± 1.2 Hz.
 - (b) Reject a load of greater than or equal to 2500 kw without tripping. The generator voltage shall return to less than or equal to 4784 volts within 2 seconds following the load rejection.
 - 2. Verifying that diesel generator trips that are made operable during the test mode of diesel operation are inoperable when the diesel is not in the test mode of operation.
 - 3. Alternately initiating one of the following two diesel startup tests.
 - (a) Simulate a safety injection signal, and allow the diesel generator to achieve nominal rates voltage and speed. Then simulate a loss of offsite power, and allow the diesel generator to load and stabilize.
 - (b) Simulate a loss of offsite power, and allow the diesel generator to load and stabilize. Then simulate a safety injection signal, and allow the diesel generator to sequence safety loads and stabilize.
 - 4. Monitoring the tests specified in 4.8.1.d.3 to:
 - (a) Verify proper deenergization and load shedding from the 4160 volt busses.
 - (b) Verify that the diesel generator starts from ambient conditions and accelerates to provide 60± 1.2 hz frequency and 4160± 624 volts in ≤ 15 seconds.

- 5. Verifying that the diesel generator operates for at least 8 hours by performing the following tests:
 - (a) Load the diesel generator to ≥ 2750 kw during the first 2 hours of the 8 hour test. During this 2 hour period, increase the load to ≥ 2850 kw until the generator electrical load is stabilized and then decrease back to ≥ 2750 kw.
 - (b) Load the diesel generator to ≥ 2500 kw during the last 6 hours of the 8 hour test.
 - (c) Verify that voltage, frequency, and cooling system functions are within design limits during the 8 hour full-load test.
- 6. Demonstrating the ability to sequentially:
 - (a) Synchronize the diesel generator with offsite power while the generator is supplying emergency loads:
 - (b) Transfer the emergency load to offsite power;
 - (c) Isolate the diesel generator; and
 - (d) Return the diesel generator to standby status.
- 7. Verifying the auto-connected loads to each diesel generator do not exceed 2750 kw.
- e. At least once per 10 years or after any modification that could affect diesel generator independence, start both diesel generators simultaneously at a time when both reactors are shutdown and verify that both diesel generators provide 60 ± 1.2 Hz frequency and 4160 ± 624 volts in less than 15 seconds.
- f. <u>Reports</u> All valid diesel generator failures shall be reported to the Commission in a Special Report pursuant to Specification 6.9.3.p. within 30 days. Reports of diesel generator failures shall include the information recommended in Regulatory Position C.3.b of Regulatory Guide 1.108, Revision 1, August 1977. If the number of failures in the last 100 valid tests is greater than or equal to 7, the report shall be supplemented to include the additional information recommended in Regulatory Position C.3.b of Regulatory Guide 1.108, Revision 1, August 1977.

به من الم الم الم

`s . .

•

n . .

13

TABLE 4.8-1

DIESEL GENERATOR TEST SCHEDULE

NUMBER OF FAILURES IN LAST 20 VALID TESTS*	NUMBER OF FAILURES IN LAST 100 VALID TESTS*	TEST FREQUENCY
≤ 1	≤5	Once per 31 days
,	≥ 6	Once per 14 days
≥ 2 **	≥ 9	Once per 7 days

* Criteria for determining number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.e of Regulatory Guide 1.108, but determined on a per diesel generator basis.

For the purpose of determining the required valid test frequency, the previous valid test failure count may be reduced to zero if a complete diesel overhaul to like-new condition is completed, provided that the overhaul, including appropriate post-maintenance operation and testing, is specifically approved by the manufacturer and if acceptable reliability has been demonstrated. The reliability criterion shall be the successful completion of 14 consecutive valid tests in a single series. Ten of these valid tests shall be in accordance with the routine Surveillance Requirements 4.8.1.a.4 and 4.8.1.a.5; and four valid tests in accordance with the 184 day testing requirement of Surveillance Requirements 4.8.1.a.4 and 4.8.1.a.5. If this criterion is not satisfied during the first series of valid tests, any alternate criterion to be used to transvalue the failure count to zero requires prior NRC approval.

****** The associated valid test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 20 valid demands has been reduced to one.

Amendment Nos. and

- 1. If the power tilt in Technical Specification 3.2.6.h is not corrected to less than 2% within 24 hours and its design hot channel factors for rated power are not exceeded, a Special Report with an evaluation as to the cause of the discrepancy shall be submitted within 30 days. Reference T.S. 3.2.6.i(1).
- m. Following a normalization of the computed boron concentration as a function of burnup, if the difference between the observed and predicted boron concentration reached the equivalent of one percent in reactivity, a Special Report shall be submitted within 30 days. Reference T.S. 4.11.
- n. Reactor Vessel Level Monitoring System, Reference Table 3.5-5, Action Statements 8 and 9.
- o. Should more than 30 individual fuel rods in the core, or 10 fuel rods in any fuel assembly, be replaced per refueling, a Special Report discussing the rod replacements will be submitted to the Commission within 30 days after cycle startup. Reference T.S. 5.2.1.
- p. All valid diesel generator failures shall be reported to the Commission. Reference T.S. 4.8.1.f.

and

BASES

3.7.1, 3.7.2, and 3.7.3 A.C. SOURCES, D.C. SOURCES, AND ONSITE POWER DISTRIBUTION

The OPERABILITY of the A.C. and D.C. power sources and associated distribution systems during operation ensures that sufficient power will be available to supply the safety-related equipment required for: (1) the safe shutdown of the facility, and (2) the mitigation and control of accident conditions within the facility.

The ACTION requirements specified for the levels of degradation of the sources provide restrictions upon continued facility operation power commensurate with the level of degradation. The OPERABILITY of the power sources is consistent with the initial condition assumptions of the safety analyses and is based upon maintaining adequate onsite A.C. and D.C. power sources and associated distribution systems OPERABLE during accident conditions coincident with an assumed loss-of-offsite power and single failure of one onsite A.C. source. Two physically independent A.C. circuits exist between the offsite transmission network and the onsite Class 1E Distribution System of each unit by utilizing the following: (1) a total of eight transmission lines which lead to five separate transmission substations tie the Turkey Point Switchyard to the offsite power grid. (2) Two dual-winding startup transformers each provide 100% of the A and B train 4160 volt power from the switchyard to its associated unit. In addition, each startup transformer has the capability to supply backup power of the equivalent of one emergency diesel generator (approximately 2500 kW) to the opposite unit's A-train 4160 volt bus. Two emergency diesel generators (EDG) provide onsite emergency A.C. power for both units. EDG A provides A-train power for both Units 3 & 4 and EDG B in turn provides B-train power for both units.

Due to the shared nature of numerous electrical components between Turkey Point Units 3 and 4, the inoperability of a component on an associated unit will often affect the operation of the opposite unit. These electrical components consist primarily of both emergency diesel generators (EDG's), both startup transformers, four 4160 volt busses, most 480 volt motor control centers, four 125 volt D.C. busses, a particular five out of six battery chargers, and four battery banks. Depending on the component(s) which is (are) determined inoperable, the resulting ACTION can range from the eventual shutdown of the opposite unit long after the associated unit has been shutdown (30 days) to an immediate shutdown of both units. Therefore, ACTION times allow for an orderly sequential shutdown of both units when the inoperability of a component(s) affects both units with equal severity. When an ACTION statement requires a dual unit shutdown, the time to be in HOT STANDBY has been revised from 6 to 12 hours. This is to allow the orderly shutdown of one unit at a time and not jeopardize the reliability of the electrical grid by imposing a dual unit shutdown.

.

×

•

.

BASES

A.C. SOURCES, D.C. SOURCES, AND ONSITE POWER DISTRIBUTION (Continued)

As each startup transformer only provides the limited equivalent power of one EDG to the opposite Units A-train 4160 volt bus, the allowable out-ofservice time of 30 days has been applied before the opposite unit is required to be shutdown. With both one startup transformer and one EDG inoperable, the unit with the inoperable transformer can continue to operate at full power for only 12 hours based on the loss of its associated startup transformer and one of the EDG's. After 12 hours, if the unit with the inoperable start-up transformer is in MODE 1 it must reduce THERMAL POWER to **30% RATED POWER** within the next 6 hours. The 30% RATED POWER limit was chosen because at this power level the decay heat and fission product production has been reduced and the operators are still able to maintain automatic control of the feedwater trains and other unit equipment. At lower power levels the operators loose automatic control of the feedwater system and must use manual control with the feedwater bypass lines. By not requiring a complete unit shutdown, the plant avoids a condition requiring natural circulation and avoids intentionally relying on engineered safety features for non-accident conditions. If the unit with the inoperable start-up transformer is in MODES 2,3, or 4, then the unit will be required to be cooled down in accordance with the time frames of specification 3.0.1. The unit with the OPERABLE startup transformer is controlled by the limits for inoperability of the shared EDG. With both start-up transformers inoperable, the unit(s) in MODE 1 are required to reduce THERMAL POWER to

30% RATED POWER within 12 hours. By not requiring a complete unit shutdown, the plant avoids a condition requiring natural circulation cooldown and avoids intentionally relying on engineered safety features for non-accident conditions. If the unit(s) with the inoperable start-up transformer is in MODES 2,3, or 4, then the unit will be required to be cooled down in accordance with the time frames of specification 3.0.1. If a unit returns its associated start-up transformer to OPERABLE status, then that unit may increase THERMAL POWER to 30% RATED POWER and both units enter ACTION a based on the time that the remaining inoperable start-up transformer was taken out of service.

When one diesel generator is inoperable, there is an additional ACTION requirement to verify that all required systems, subsystems, trains, components, and devices, that depend on the remaining OPERABLE diesel generator as a source of emergency power, are also OPERABLE. This requirement is intended to provide assurance that a loss-of-offsite power event will not result in a complete loss of safety function of critical systems during the period one of the diesel generators is inoperable.

The term verify means to administratively check by examining logs or other information to determine if certain components are out-of-service for maintenance or other reasons. It does not mean to perform the surveillance requirements needed to demonstrate the OPERABILITY of the component. The notification of a loss of start-up transformer(s) to the NRC is to be performed through the resident NRC inspector.

BASES

A.C. SOURCES, D.C. SOURCES, AND ONSITE POWER DISTRIBUTION (Continued)

The requirement for both units to reach HOT STANDBY within 12 hours upon loss of both diesel generators minimizes the possibility of transients while allowing the orderly shutdown of both units.

The OPERABILITY of the minimum specified A.C. and D.C. power sources and associated distribution systems during shutdown and refueling ensures that (1) the facility can be maintained in the shutdown or refueling condition for extended time periods, and (2) sufficient instrumentation and control capability is available for monitoring and maintaining the unit status. In MODES 5 and 6. the specification for coolant loops requires at least 2 coolant loops to be OPERABLE. To ensure that at least one coolant loop has a source of onsite AC power available, the shutdown specification for AC sources requires that the OPERABLE diesel generator be capable of supplying power to its associated OPERABLE 4160 volt bus. This is so that during a loss of offsite power event at least one train of shutdown cooling will have a source of onsite AC power. In addition to the above actions, the Reactor Coolant System (RCS) must be depressurized and vented. This is required because the pressurizer Power Operated Relief Valves (PORVs) may no longer be, OPERABLE to prevent overpressure in these MODES. The minimum size of the vent ensures that overpressure can be adequately relieved without exceeding the RCS pressure/temperature limits.

During a unit shutdown the one required circuit between the offsite transmission network and the onsite Class IE Distribution System can consist of at least the associated unit startup transformer feeding one 4160 volt Bus A or B, the opposite unit's startup transformer feeding the associated unit's 4160 volt Bus A, or the associated unit's 4160 volt Bus A or B backfed through its main and auxiliary transformers with the main generator isolated. As inoperability of numerous electrical components often affect the operation of the opposite unit, the applicability for the shutdown LIMITING CONDITION FOR OPERATION (LCO) for A.C. Sources, D.C. Sources and Onsite Power Distribution all contain statements to ensure the LCO's of the opposite unit are considered.

B 3.7-3

Amendment Nos. and

BASES

A.C. SOURCES, D.C. SOURCES, AND ONSITE POWER DISTRIBUTION (Continued)

The allowable out-of-service time for each of the four batteries D.C. busses is 24 hours in order to allow for required battery maintenance without requiring both units to be shutdown.

The allowable out-of-service times for the battery chargers depicted in Table 3.7-1 are based on the following criteria:

- 1. Battery chargers 3B, 4A and 4S are all required for the operation of both units. EDG's A and B field flashing are powered by batteries 3A and 4B respectively. With one of battery chargers 3B, 4A or 4S inoperable, a single failure of Battery 3A or 4B could result in less than the minimum required number of battery chargers being OPERABLE. Therefore, an allowable out-of-service time of 72 hours is applied due to the reliance on a particular EDG.
- 2. With any two of battery chargers 3B, 4A and 4S, or with any two of battery chargers 3A, 4B and 3S, one D.C. bus is inoperable and the corresponding allowable out-of-service time of 24 hours is applied.
- 3. With a total of three or more battery chargers inoperable, shutdown of both units is required after 1 hour based on the loss of greater than or equal to one-half of the available battery chargers and one D.C. bus.

The ACTION requirements which concern the inoperability of certain Motor Control Centers (MCC's) and 4160 volt Busses are limited by the action requirements of certain equipment which receive power from them. As MCC D is common between both Units 3 and 4, it has been given an allowable out of service time of 24 hours to allow the performance of preplanned maintenance. For all reasons other than the performance of preplanned preventative maintenance, the allowable out of service time for MCC D is 8 hours. As MCC D automatically transfers from a normal power supply to a back-up power supply fed from the opposite train, allowable out-of-service times have been applied to the power supplies themselves based on their reliance on a specific EDG to provide the "only" power source for the MCC. Therefore, the normal and backup power supplies for MCC D both have allowable out-of-service times of 72 hours (7 days for preplanned preventative maintenance) based on the reliance on the remaining power source (EDG A or B) to power the required two Emergency Containment Coolers (ECC's), two Emergency Containment Filters (ECF's) of each unit and one of the required battery chargers 4S. As MCC 3A also automatically transfers from a normal power supply to a back up power supply fed from the opposite train, an allowable

Amendment Nos.____and

BASES

A.C. SOURCES, D.C. SOURCES, AND ONSITE POWER DISTRIBUTION (Continued)

out-of-service time has been applied to the normal power supply itself based on the fact that the 3A MCC powers certain auxiliary equipment necessary for OPERABILITY of the A diesel generator. Therefore, upon the loss of the normal power supply to the 3A MCC, the A EDG is not OPERABLE. The ACTION statements for the 3A MCC are similar to those applied to an inoperable diesel generator.

With one unit shutdown the 4160 volt Busses on the associated unit are only permitted to be inoperable for up to 7 days, for periodic refueling outage maintenance, upon issuance of an engineering evaluation based on the single failure vulnerability of equipment powered by sources on the shutdown unit which is required for the opposite unit at power.

B4.8 BASES FOR EMERGENCY POWER SYSTEM PERIODIC TESTS

The tests specified are designed to demonstrate that the diesel generators will provide power for operation of equipment. They also assure that the emergency generator system controls and the control systems for the safeguards equipment will function automatically in the event of a loss of normal power.

The EDG Surveillance testing requires that each EDG be started from normal conditions only once per 184 days with no additional warmup procedures. Normal conditions in this instance are defined as the pre-start temperature and lube oil conditions each EDG normally experiences with the continuous use of prelube systems and immersion heaters.

Each unit, as a backup to the normal standby AC power supply, is capable of sequentially starting and supplying the power requirement of the required safety feature equipment. Each will assume full load within 60 seconds after the initial starting signal. (1)(2)(3).

The SURVEILLANCE REQUIREMENTS to demonstrate each Emergency Diesel Generator (EDG) OPERABLE requires that the auto-connected loads to each EDG do not exceed 2750 kW. This requirement can be demonstrated by following the ESF testing method where each unit is individually tested for two loading conditions (i.e., loads due to loss of offsite power (LOOP) and loads due to LOOP coincident with a Safety Injection (SI)). The results of the test on one unit are then added arithmetically to the test on the other unit with a LOOP coincident with a Safety Injection (SI) for each EDG respectively. The sum of the difference between these loads operated in the test mode and the actual expected loads (i.e., load differences due to pumps run in recirculation mode) are added to the test values for each EDG. The sum of the two test condition loads on opposite units will be representative of the actual design basis auto-connect loads on each EDG. The EDG 8-hour Surveillance test demonstrates each EDG's capability to power the maximum of all auto-connected and required manually loaded emergency shutdown load (2850 kW) following a design basis accident, loss of offsite power (LOOP) and a single failure of one EDG.

The surveillance requirement for the full load rejection test requires the steady state voltage reading to be less than or equal to 4784 volts within 2 seconds following the load rejection. The purpose of the subject surveillance is to verify the proper operation of the voltage regulator and overspeed circuits during a full load rejection. Since the ability to measure instantaneous maximum transient voltage is dependent on the mechanical response of the measurement devices and not necessary reflective of actual regulator performance, the ability of the diesel generator to return to a steady state condition in a defined time period is a more accurate and useful measurement of the diesel generator's ability to properly regulate voltage during the performance of a full load rejection test.

Amendment Nos.____and

B 4.8-1

The specified fuel supply will ensure power requirements for at least a week.

REFERENCE:

R 0

(1) FSAR, Section 6.4.3
(2) FSAR, Section 8.2
(3) FSAR, Section 14.3.2

Amendment Nos.____and_

1

)