

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9104150042 DOC. DATE: 91/04/03 NOTARIZED: YES DOCKET #
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME AUTHORITY AFFILIATION
BOHLKE, W.H. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-31 & DPR-41, changing
Tech Spec 3/4.2.5, "Power Distribution Limits, DNB
Parameters" to provide addl operational margin to limits
associated w/RCS flow & RCS average temp.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4 + 16
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	AULUCK, R	2 2		
INTERNAL:	NRR/DET/ECMB 9H	1 1	NRR/DET/ESGB	1 1
	NRR/DOEA/OTSB11	1 1	NRR/DST 8E2	1 1
	NRR/DST/SELB 8D	1 1	NRR/DST/SICB 7E	1 1
	NRR/DST/SRXB 8E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LFMB	1 0	OGC/HDS3	1 0
	REG FILE 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

AA²/W

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

1/20/72



1/20/72

1/20/72



APR 03 1991

L-91-86

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed License Amendment
DNB Parameters, Limiting Condition for Operation

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) requests that Appendix A of Facility Operating Licenses DPR-31 and DPR-41 be amended to modify the Turkey Point Units 3 and 4 Technical Specification 3/4.2.5, Power Distribution Limits, DNB Parameters, Limiting Condition for Operation and the Bases Section 3/4.2.5, Power Distribution Limits, DNB Parameters.

The proposed amendment provides additional operational margin associated with the DNB parameters by changing the indicated values of the operating parameters as follows:

1. Reactor Coolant System (RCS) Flow from $\geq 277,900$ gpm to $\geq 275,000$ gpm,
2. RCS average temperature from ≤ 576.6 °F to ≤ 577.5 °F,
3. Pressurizer pressure from ≥ 2209 psig to ≥ 2205 psig.

The proposed amendment also revises the Bases Section 3/4.2.5, Power Distribution Limits, DNB Parameters, to reflect the changes listed above.

Additional operational margin to the limits associated with the measurement and indication of RCS flow, RCS average temperature, and pressurizer pressure may be provided by the improvement of procedures, replacement of instrumentation, and recalculation of the limits with the use of the NRC approved Westinghouse Setpoint Methodology.

FPL has determined that the proposed amendment does not involve a significant hazard pursuant to 10 CFR 50.92. The proposed revised Technical Specification change is shown in Attachment 1. A description of the amendment request and the supporting safety analysis which forms the basis for a no significant hazards determination is provided in Attachment 2. Attachment 3 provides the no significant hazards determination in support of the proposed amendment.

9104150042 910403
PDR ADOCK 05000250
P PDR

*Asol
11/11*

SECRET


SECRET

In accordance with 10 CFR 50.91(b) (1), a copy of this proposed license amendment is being forwarded to the State Designee for the State of Florida.

The proposed amendment has been reviewed by the Turkey Point Plant Nuclear Safety Committee and the FPL Company Nuclear Review Board.

Should there be any questions on this request, please contact us.

Very truly yours,



W. H. Bohlke
Vice President
Nuclear Engineering and Licensing

WHB/OIH

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant
Mr. Jacob Daniel Nash, Florida Department of Health and
Rehabilitative Services

STATE OF FLORIDA)
) ss.
COUNTY OF DADE)

W. H. Bohlke being first duly sworn, deposes and says:


That he is Vice President, Nuclear Engineering and Licensing,
of Florida Power and Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements
made in this document are true and correct to the best of his
knowledge, information and belief, and that he is authorized to
execute the document on behalf of said Licensee.



W. H. Bohlke

Subscribed and sworn to before me this
3rd day of April, 1991.



NOTARY PUBLIC, in and for the County of
Dade, State of Florida

My Commission expires _____
Notary Public, State of Florida
My Commission Expires Jan. 16, 1993
Bonded Thru Troy Fain - Insurance Inc.

RECEIVED
FEBRUARY 1964
U.S. AIR FORCE
HEADQUARTERS
WASHINGTON, D.C.

Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
DNB Parameters, Limiting Condition for Operation

ATTACHMENT 1

