- 5. TWO residual heat removal pumps shall be operable.
- 6. TWO residual heat exchangers shall be operable.
- 7. All valves, interlocks and piping assoicated with the above components and required for post accident operation, shall be operable. except valves that are positioned and locked. Valves 864-A, B, 862-A,B, 865-A, B, C; 866-A, B shall have power removed from their motor operators by locking open the circuit breakers at the Motor Control Centers. The air supply to valve 758 shall be shut off to the valve operator.
- b. During power operation, the requirements of 3.4.1a may be modified to allow one of the following components to be inoperable (including associated valves and piping) at any one time except for the cases stated in 3.4.1.b.2. If the system is not restored to meet the requirements of 3.4.1a within the time period specified, the reactor shall be placed in the hot shutdown condition. If the requirements of 3.4.1a are not satisfied within an additional 48 hours the reactor shall be placed in the cold shutdown condition.** Specification 3.0.1 applies to 3.4.1.b.
 - ONE accumulator may be out of service for a period of up to 4 hours.
 - 2. ONE of FOUR safety injection pumps may be out of service for 30 days. A second safety injection pump may be out of service, provided the pump is restored to operable status within 24 hours. TWO of the FOUR safety injection pumps shall be tested to demonstrate operability before initiating maintenance of the inoperable pumps.
 - 3. ONE channel of heat tracing on the flow path may be out of service for 24 hours.*
 - 4. ONE residual heat removal pump may be out of service, provided the pump is restored to operable status within 24 hours. In addition the other residual heat removal pump shall be tested to demonstrate operability prior to initiating maintenance of the inoperable pump.

^{*}See reference (11) on page B.3.4-2

^{**} For the 30-day period ending at midnight 11-12-83, placing the plant in cold shutdown due to one RHR pump being inoperable is not required providing that 3509F > Tave > 200.

3.4-2

Amendments 87 & 81