



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-250

TURKEY POINT PLANT UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 102
License No. DPR-31

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated December 28, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-31 is hereby amended to read as follows:

8404270062 840413
PDR ADOCK 05000250
P PDR




1954

(B) Technical Specifications

The Technical Specifications contained in Appendix A and B, as revised through Amendment No.102, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective immediately.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 13, 1984



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER AND LIGHT COMPANY

DOCKET NO. 50-251

TURKEY POINT PLANT UNIT NO. 4

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 96
License No. DPR-41


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power and Light Company (the licensee) dated December 28, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-41 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendix A and B, as revised through Amendment No. 96, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective immediately.

FOR THE NUCLEAR REGULATORY COMMISSION


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: April 13, 1984

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 102 FACILITY OPERATING LICENSE NO. DPR-31

AMENDMENT NO. 96 FACILITY OPERATING LICENSE NO. DPR-41

DOCKET NO. 50-250 AND 50-251

Revise Appendix A as follows:

Remove Page

Table 3.5-2

Insert Page

Table 3.5-2




TABLE 3.5-2

ENGINEERED SAFETY FEATURES ACTUATION

<u>NO.</u>	<u>FUNCTIONAL UNIT</u>	<u>1</u> MIN. <u>OPERABLE</u> <u>CHANNELS</u>	<u>2</u> MIN. <u>DEGREE</u> <u>OF</u> <u>REDUN-</u> <u>DANCY</u>	<u>3</u> <u>OPERATOR ACTION</u> <u>IF CONDITIONS OF</u> <u>COLUMN 1 OR 2</u> <u>CANNOT BE MET</u>
1.	SAFETY INJECTION			
1.1	Manual	1	0	Cold Shutdown
1.2	High Containment Pressure	2	1	Cold Shutdown
1.3	High Differential Pressure between any Steam Line and the Steam Line Header*	2	1	Cold Shutdown
1.4	Pressurizer Low Pressure*	2	1	Cold Shutdown
1.5	High Steam Flow in 2/3 Steam Lines with Low T_{avg} or Low Steam Line Pressure**	1/line in each of 2 lines	-1	Cold Shutdown
2.	CONTAINMENT SPRAY			
2.1	High Containment Pressure and High-High Containment Pressure (coincident)	2 per set	1/set	Cold Shutdown
3.	AUXILIARY FEEDWATER			
3.1	Low-Low Steam Generator Level	2	1	Hot Shutdown
3.2	Loss of Voltage (both 4KV busses)	2	0	Cold Shutdown
3.3	Safety Injection		(---See 1 above---)	
3.4	Trip of both Main Feedwater Pump Breakers	2	0	Cold Shutdown

* This signal may be manually bypassed, when cooling down the reactor and RCS pressure is below 2000 psig.

** This signal may be manually bypassed, when cooling down the reactor and T_{avg} is below 543°F.

13