

Docket Nos. 50-250 June 20, 1984  
and 50-251

DISTRIBUTION

Docket File

JNGrace

NRC PDR

L PDR

Gray File

ORB#1 Rdg

CParrish

DMcDonald

DEisenhut

OELD

ACRS 10

EJordan

Mr. J. W. Williams, Jr., Vice President  
Nuclear Energy Department  
Florida Power and Light Company  
Post Office Box 14000  
Juno Beach, Florida 33408

Dear Mr. Williams:

SUBJECT: RELIEF REQUEST FROM TECHNICAL SPECIFICATION  
INSERVICE INSPECTION REQUIREMENTS

By letter dated December 16, 1983, (L-83-591) you proposed to perform a visual (VT-2) examination of the regenerative heat exchanger, in lieu of Code required volumetric and surface examinations, to provide assurance that the required level of structural integrity has been maintained. We do not consider that a VI-2 examination alone will provide such assurance. Therefore, we request that you submit a revised program that includes inspections in addition to, or in lieu of, the VT-2 examination.

We request that the information be provided within 60 days from receipt of this letter. The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

/s/SVarga

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

cc [redacted]  
See next page

ORB#1:DL  
DMcDonald;ps  
6/29/84

C-ORB#1:DL  
SVarga  
6/29/84

8407120250 840620  
PDR ADDCK 05000250  
Q PDR

1950 10 1  
10 10 10

Wachmann:



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

Docket Nos. 50-250  
and 50-251

Mr. J. W. Williams, Jr., Vice President  
Nuclear Energy Department  
Florida Power and Light Company  
Post Office Box 14000  
Juno Beach, Florida 33408

Dear Mr. Williams:

SUBJECT: RELIEF REQUEST FROM TECHNICAL SPECIFICATION  
INSERVICE INSPECTION REQUIREMENTS

By letter dated December 16, 1983, (L-83-591) you proposed to perform a visual (VT-2) examination of the regenerative heat exchanger, in lieu of Code required volumetric and surface examinations, to provide assurance that the required level of structural integrity has been maintained. We do not consider that a VI-2 examination alone will provide such assurance. Therefore, we request that you submit a revised program that includes inspections in addition to, or in lieu of, the VT-2 examination.

We request that the information be provided within 60 days from receipt of this letter. The reporting and/or recordkeeping requirements of this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script, appearing to read "Steven A. Varga", with a diagonal slash and the letters "for" written below it.

Steven A. Varga, Chief  
Operating Reactors Branch #1  
Division of Licensing

cc: See next page

J. W. Williams, Jr.  
Florida Power and Light Company

Turkey Point Plants  
Units 3 and 4

cc: Harold F. Reis, Esquire  
Lowenstein, Newman, Reis and Axelrad  
1025 Connecticut Avenue, N.W.  
Suite 1214  
Washington, DC 20036

Bureau of Intergovernmental Relations  
660 Apalachee Parkway  
Tallahassee, Florida 33130

Norman A. Coll, Esquire  
Steel, Hector and Davis  
1400 Southeast First National  
Bank Building  
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager  
Turkey Point Plant  
Florida Power and Light Company  
P.O. Box 013100  
Miami, Florida 33101

Mr. M. R. Stierheim  
County Manager of Metropolitan  
Dade County  
Miami, Florida 33130

Resident Inspector  
Turkey Point Nuclear Generating Station  
U.S. Nuclear Regulatory Commission  
Post Office Box 1207  
Homestead, Florida 33030

Regional Radiation Representative  
EPA Region IV  
345 Courtland Street, N.W.  
Atlanta, GA 30308

Mr. Jack Shreve  
Office of the Public Counsel  
Room 4, Holland Building  
Tallahassee, Florida 32304

Administrator  
Department of Environmental  
Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

James P. O'Reilly  
Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta Street  
Atlanta, GA 30303

Martin H. Hodder, Esquire  
1131 N.E. 86th Street  
Miami, Florida 33138

Joette Lorion  
7269 SW 54 Avenue  
Miami, Florida 33143