



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Enclosure

SAFETY EVALUATION

TEST REQUIREMENTS FOR VALVES

MOV-750 AND 751

TURKEY POINT UNITS 3 AND 4

I. Background

By letter dated May 20, 1985, FPL requested that valves, MOV 750 and 751 not be required to be Type C tested. FPL re-evaluated the requirements for the valves and determined that Type C testing in accordance with 10 CFR 50, Appendix J, is not required. They further indicated that the valves will be tested as pressure isolation valves.

II. Evaluation

FPL provided a detailed evaluation to support their determination that valves, MOV 750 and 751, are not required to be Type C tested. FPL states and the Containment Systems Branch concurs, that the valves are not required to perform a containment isolation function and would not become a potential containment atmosphere leak path as long as the Emergency Core Cooling System (ECCS) is operable. These two valves are locked closed both during normal operation and following a Loss of Coolant Accident to provide the system isolation function for proper ECCS operation. In addition, these valves are located inside containment and will always be filled with water from either the refueling water storage tank or the containment sumps.

III. Conclusion

Based on the licensee's submittal and the above evaluation, we have concluded that the valves, MOV 750 and 751 are not required to have the Type C test. Therefore, the FPL request that they be removed from the Type C test program is acceptable. These valves will be tested as pressure isolation valves.

Dated May 1985

Principal Contributors:

J. Huang

8506040056 850521
PDR ADDCK 05000250
P PDR

