

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8704200352 DDC DATE: 87/04/14 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME: WOODY, C. O. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Discusses aspects of util surveillance program to periodically verify operability of control room emergency radios.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-2 LA		1	0		PD2-2 PD		1	1
	McDONALD, D		1	1					
INTERNAL:	AEOB		1			DEDRO		1	1
	ENF LIEBERMAN		1			NRR ROE, M. L		1	1
	NRR/ADT		1			NRR/DOEA DIR		1	1
	NRR/DREP/EPB		1			NRR/DREP/RPB		2	2
	NRR/DRIS DIR		1			NRR/PMAS/ILRB		1	1
	OCC/HDS2		1			REC FILE		1	1
	RES SPEIS, T		1			RON2 FILE 01		1	1
EXTERNAL:	LPDR		1			NRC PDR		1	
	NSIC		1						

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 0



FLORIDA POWER & LIGHT COMPANY

APRIL 14 1987

L-87-169

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Control Room Emergency Radios

The proper functioning of control room radios is the subject of a proposed inspector follow up item which resulted from a recent NRC inspection at Turkey Point Units 3 and 4. During that inspection Florida Power & Light agreed to develop a surveillance program to periodically verify operability of these radios. The purpose of this letter is to discuss the aspects of that surveillance program.


The surveillance program includes the following elements which are included in Procedure OSP 200.1:

1. The radios will be checked daily to ensure functionality.
2. The repeater will be checked daily to ensure functionality and power availability.
3. On a weekly basis radios will be taken to several different locations on the site to ensure communications can be maintained between the field locations.
4. Administrative controls have been established regarding access to the repeater unit and corresponding power supply. The purpose of these controls will be to ensure that the Operations Department has access to the cabinet with this equipment and to ensure that the Plant Supervisor-Nuclear or his representative will be advised prior to any work on this equipment.

The program discussed above will provide a high degree of assurance that the emergency radios will be available and functioning when called for.

Should there be any questions on this information, please contact us.

Very truly yours,


C. O. Woody
Group Vice President
Nuclear Energy

COW/PLP/gp

cc: Dr. J. Nelson Grace, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE01
1/2

PLP1/043/1

8704200352 870414
PDR ADDCK 05000250
Q PDR