REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8803220385 DOC. DATE: 88/03/17 NOTARIZED: NO DOCKET #
FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH. NAME AUTHOR AFFILIATION
CONWAY, W. F. Florida Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Forwards revised Tech Specs Table 4.8-2, "Battery surveillance requirements" re 860929 application for amend to Licenses DPR-31 & DPR-41.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+1
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
	PD2-2 LA	1	0	PD2-2 PD	5	5
	EDISON, G	1	1			
INTERNAL:	ARM/DAF/LFMB	1	0	NRR/DEST/ADS7E4	1	1
	NRR/DEST/CEB8H7	1	1	NRR/DEST/ESB 8D	1	1
	NRR/DEST/MTB 9H	1	1	NRR/DEST/RSB 8E	1	1
	NRR/DOEA/TSB11F	1	1	NRR/PMAS/ILRB12	1	1
	OGC 15-B-18	1	0	REG FILE 01	1	1
	RES/DE/EIB	1	1			
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 18

FLORIDA POWER & LIGHT COMPANY

MARCH 17 1988

L-88-135

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Proposed License Amendment
D. C. Sources - Surveillance Requirements

By letter dated September 29, 1986 (FPL letter L-86-393) Florida Power & Light Company (FPL) submitted a request to amend Appendix A of Facility Operating Licenses DPR-31 and DPR-41 to upgrade the current plant Technical Specifications and include, within limitations, the guidance of NUREG-0452, Standard Technical Specifications for Westinghouse Pressurized Water Reactors (STS). FPL supplemented that request by letter dated November 28, 1986 (FPL letter L-86-475), which provided proposed specifications and supporting documentation for the Electrical Power Systems. By letter dated December 22, 1987, (FPL letter L-87-494) FPL requested that the NRC review and issue the D. C. Sources-Operating Surveillance Requirements (T.S. 4.8.2.1) independent of the Technical Specification Upgrade review effort. This specification reflected certain surveillance requirements for the station batteries that are more consistent with the manufacturer's recommendations.

In response to a question from the NRC Staff, FPL has revised the Category A and B electrolyte level limits specified in Table 4.8-2 to agree with the requirement in the STS. Specifically, the electrolyte level limits, for each designated pilot cell and connected cell were changed from "greater than minimum level indication mark, and no overflow" to "greater than minimum level indication mark, and less than 1/4 inch above maximum level indication mark". The attached Table 4.8-2 supersedes Table 4.8-2 included in the December 22, 1987 submittal.

TCG.DCS

A001
1/1

8803220385 880317
PDR ADOCK 05000250
P PDR

The revised requirement is more conservative in that an upper limit less than the overflow condition is imposed.

The conclusions reached in the Basis for No Significant Hazards Determination are not changed.

Very truly yours,

W. F. Conway
Acting Group Vice President
Nuclear Energy

WFC/TCG/gp

Enclosure

cc: Dr. J. Nelson Grace, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

TCG.DCS