

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SESSION NBR: 8907260207 DOC. DATE: 89/06/21 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251

AUTH. NAME: WODDY, C.O. AUTHORITY AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Forwards response to NRC 890418 request for addl info re
 util response to Insp Repts 50-250, 251/89-02.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2

TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 PD	1 1	EDISON, G	1 1
INTERNAL:	AEOD	1 1	AEOD/DEIIB	1 1
	AEOD/TPAD	1 1	DEDRO	1 1
	NRR SHANKMAN, S	1 1	NRR/DEST DIR	1 1
	NRR/DLPQ/PEB	1 1	NRR/DOEA DIR 11	1 1
	NRR/DREP/EPB 10	1 1	NRR/DREP/RPB 10	2 2
	NRR/PMAS/ILRB12	1 1	NUDOCS-ABSTRACT	1 1
	OE LIEBERMAN, J	1 1	OGC/HDS2	1 1
	REG FILE 02	1 1	RES MORISSEAU, D	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 23

R
I
D
S
/
A
D
D
S



JULY 21 1989

L-89-261


U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Additional Response to Inspection Report 89-02

By letter dated April 18, 1989, (Stewart D. Ebnetter to W. F. Conway), you requested an additional response to Florida Power & Light Company (FPL) letter L-89-108 dated March 27, 1989, which provided a response to Inspection Report 89-02. FPL's additional response is attached.

Very truly yours,



C. O. Woody
Acting Senior Vice President - Nuclear

COW/JRH/cm

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

8907260207 890621
PDR ADOCK 05000250
Q PIC

DEO1
11

ATTACHMENT 1

REQUEST FOR ADDITIONAL INFORMATION

NRC INSPECTION REPORT NOS. 50-250/89-02 AND 50-251/89-02

In an NRC letter dated April 18, 1989 to Mr. W. F. Conway the NRC requested additional information concerning the corrective actions FPL had taken in response to violation 50-250/89-02-01. Specifically, the NRC stated "during the week of April 3, 1989, your staff's capabilities to make prompt classifications were again evaluated by an NRC license examiner. The findings indicated that additional training in classifications was necessary. We understand that, in response to these findings, you are revising the applicable procedure and you are providing additional training to your staff regarding emergency classification. In view of this, we request that you provide a supplemental response to the Notice of Violation outlining the additional corrective actions you have taken and plan to undertake."

The following corrective actions have been taken, in addition to those outlined in the "Reply to Notice of Violation Inspection Report 89-02" dated March 27, 1989, to prevent the recurrence of this problem.

- 1) The Emergency Action Level (EAL) guidance contained in procedure EPIP-20101, "Duties of Emergency Coordinator," has been upgraded to be clearer and more "user friendly." An "approved for training purposes only" version of this upgraded guidance was used during the retraining provided, between April 17 and May 5, 1989, to the potential Emergency Coordinators. This allowed the procedure to be thoroughly validated prior to its implementation on May 5, 1989.
- 2) All personnel who are currently expected to act as the Emergency Coordinator have been retrained in the area of emergency classification. The retraining included both classroom and simulator training. A written examination was given to all personnel attending the training. Additionally, the Assistant Plant Supervisor-Nuclear (APSNs) and Plant Supervisor-Nuclear (PSNs) were given a simulator examination on this subject.

