

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power and Light Company
Turkey Point Units 3 and 4

Docket Nos. 50-250, 50-251
License Nos. DPR-31, DPR-41

During the NRC inspection conducted on August 26, 1989 through September 29, 1989, a violation of NRC requirements was identified. The violation involved: One example of failure to meet the requirements of Technical Specification (TS) 6.8.1, in that failure to follow a procedure resulted in an inadequate equipment clearance and subsequent injury to a plant worker. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions". 10 CFR Part 2, Appendix C (1989), the violation is listed below:

TS 6.8.1 requires that written procedures and administrative policies shall be established, implemented and maintained that meet or exceed the requirements and recommendations of Appendix a of USNRC Regulatory Guide 1.33 and Sections 5.1 and 5.3 of ANSI N18.7-1972.

NRC Regulatory Guide 1.33, Appendix A, item 1, specifies that procedures should be written for equipment control.

Section 5.1.2 of ANSI N18.7-1972 requires that procedures be followed.

Administrative Procedure 0103.4, In-Plant Equipment Clearance Orders, dated July 27, 1989, specified that In-Plant Equipment Clearance Orders shall be required for the safety and protection of plant personnel and equipment.

Contrary to the above, clearance number 4-89-09-069 was inadequate on September 20, 1989, in that MOV-4-1420 was not fully isolated. This allowed the line to remain pressurized which caused the valve stem to be ejected resulting in serious injury to a plant electrician.

This is a Severity Level IV Violation (Supplement I)

Pursuant to the provisions of 10 CFR 2.201, Florida Power and Light Company is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include [for each violation]: (1) admission or denial of the violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full




Florida Power and Light Company
Turkey Point Units 3 and 4

2

Docket Nos. 50-250, 50-251
License Nos. DPR-31, DPR-41

compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION



Luis A. Reyes, Director
Division of Reactor Projects

Dated at Atlanta, Georgia
this 27th day of October 1989

