

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9005180076 DOC. DATE: ~~90/05/90~~ NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 BONETT, D.M. Florida Power & Light Co.
 HARRIS, K.N. Florida Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Apr 1990 for Turkey Point, Units 2 & 3. W/900515 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL		ID	CODE/NAME	LTR	ENCL
	PD2-2	LA	3	3		PD2-2	PD	1	1
	EDISON,	G	1	1					
INTERNAL:	AEOD/DOA		1	1	AEOD/DSP/TPAB			1	1
	IRM TECH ADV		2	2	NRR/DLPQ/LPEB10			1	1
	NRR/DOEA/OEAB11		1	1	<u>REG FILE</u> 01			1	1
	RGN2		1	1					
EXTERNAL:	EG&G STUART, V.A		1	1	LPDR			1	1
	NRC PDR		1	1	NSIC			1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 17

*mf
wt*

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



MAY 15 1990

L-90-178
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

RE: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.c, and the guidance of NUREG 0020, attached are the April 1990 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,

A handwritten signature in dark ink, appearing to read "K. N. Harris", is written over the typed name.

K. N. Harris
Vice President
Turkey Point Plant Nuclear

KNH/DRP/RAT/rat

attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

9005180076 900430
PDR ADOCK 05000250
R PDC

JE24
11

SECRET YAM

|||||

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250

UNIT Turkey Point #3

DATE May 15, 1990

COMPLETED BY R. A. Tierney

TELEPHONE (305) 246-7103

REPORT MONTH April, 1990

Unit 3 was shutdown for a scheduled refueling and maintenance outage.

OPERATING DATA REPORT

DOCKET NO 50 - 250
 DATE 5/ 8/90
 COMPLETED BY D. M. BONETT
 TELEPHONE 407/694/4432

OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 3
2. REPORTING PERIOD: APRIL 1990
3. LICENSED THERMAL POWER (MWT): _____ 2200
4. NAMEPLATE RATING (GROSS MWE): _____ 760
5. DESIGN ELECTRICAL RATING (NET MWE): _____ 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): _____ 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): _____ 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: _____
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) _____
10. REASONS FOR RESTRICTIONS, IF ANY: _____

MONTHLY -YTD- CUMULATIVE

	MONTHLY	-YTD-	CUMULATIVE
11. HOURS IN REPORT PERIOD: _____	719	2879	152552.6
12. NUMBER OF HOURS REACTOR WAS CRITICAL _____	0.0	814.9	100005.0
13. REACTOR RESERVE SHUTDOWN HOURS _____	0.0	0.0	844.4
14. HOURS GENERATOR ON-LINE _____	0.0	814.3	98669.0
15. UNIT RESERVE SHUTDOWN HOURS _____	0.0	0.0	121.8
16. GROSS THERMAL ENERGY GENERATED (MWH) _____	0	1791182	204825985
17. GROSS ELECTRICAL ENERGY GENERATED (MWH) _____	0	575155	65636031
18. NET ELECTRICAL ENERGY GENERATED (MWH) _____	-4400	540404	62057253
19. UNIT SERVICE FACTOR _____	0.0	28.3	64.7
20. UNIT AVAILABILITY FACTOR _____	0.0	28.3	64.8
21. CAPACITY FACTOR (USING MDC NET) _____	0.0	28.2	62.4
22. CAPACITY FACTOR (USING DER NET) _____	0.0	27.1	58.7
23. UNIT FORCED OUTAGE RATE _____	0.0	0.0	12.8
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: 5/28/90



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250

UNIT Turkey Point #3

DATE May 15, 1990

COMPLETED BY R. A. Tierney

TELEPHONE (305) 246-7103

MONTH April, 1990

DAY AVERAGE DAILY POWER LEVEL

(MWe-Net)

4/01/90	-2
4/02/90	-2
4/03/90	-2
4/04/90	-2
4/05/90	-2
4/06/90	-2
4/07/90	-2
4/08/90	-2
4/09/90	-2
4/10/90	-2
4/11/90	-2
4/12/90	-3
4/13/90	-2
4/14/90	-3
4/15/90	-2
4/16/90	-3
4/17/90	-3
4/18/90	-2
4/19/90	-2
4/20/90	-4
4/21/90	-14
4/22/90	-14
4/23/90	-16
4/24/90	-18
4/25/90	-15
4/26/90	-10
4/27/90	-11
4/28/90	-13
4/29/90	-16
4/30/90	-12

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250

UNIT NAME Turkey Point #3

DATE May 15, 1990

COMPLETED BY R. A. Tierney

TELEPHONE (305) 246-7103

REPORT MONTH April, 1990

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
15	900203	S	719	C	4	N/A	RC	FUEL XX	UNIT WAS SHUTDOWN FOR A SCHEDULED REFUELING AND MAINTENANCE OUTAGE


1
F Forced
S Scheduled

2
Reason
A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training & License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3
Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued
5 - Load Reduction
9 - Other (Explain)

4
Exhibit G- Instructions for Preparation of Data Entry Scheets Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source



SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251

UNIT Turkey Point #4

DATE May 15, 1990

COMPLETED BY R. A. Tierney

TELEPHONE (305) 246-7103

REPORT MONTH April, 1990

Unit 4 tripped on April 9, 1990 due to an internal failure of the Underfrequency Relay on the Reactor Coolant Pump. While in cold shutdown Safeguards testing was performed on Unit 3. Unanticipated holds were encountered during heatup caused by a RHR Pump Seal leak, following the resolution of these holds Unit 4 returned to power.

OPERATING DATA REPORT

DOCKET NO 50 - 251
 DATE 5/ 8/90
 COMPLETED BY D. M. BONETT
 TELEPHONE 407/694/4432

OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 4
2. REPORTING PERIOD: APRIL 1990
3. LICENSED THERMAL POWER (MWT): _____ 2200
4. NAMEPLATE RATING (GROSS MWE): _____ 760
5. DESIGN ELECTRICAL RATING (NET MWE): _____ 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): _____ 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): _____ 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: _____

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) _____
10. REASONS FOR RESTRICTIONS, IF ANY: _____

MONTHLY -YTD- CUMULATIVE

	MONTHLY	-YTD-	CUMULATIVE
11. HOURS IN REPORT PERIOD: _____	719	2879	146284.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL _____	519.2	2461.6	96845.2
13. REACTOR RESERVE SHUTDOWN HOURS _____	0.0	0.0	166.6
14. HOURS GENERATOR ON-LINE _____	504.4	2434.9	93307.7
15. UNIT RESERVE SHUTDOWN HOURS _____	0.0	0.0	32.1
16. GROSS THERMAL ENERGY GENERATED (MMH) _____	1086308	5307126	196531470
17. GROSS ELECTRICAL ENERGY GENERATED (MMH) _____	350599	1734229	62728060
18. NET ELECTRICAL ENERGY GENERATED (MMH) _____	329874	1647574	59318734
19. UNIT SERVICE FACTOR _____	70.2	84.6	63.8
20. UNIT AVAILABILITY FACTOR _____	70.2	84.6	63.8
21. CAPACITY FACTOR (USING MDC NET) _____	68.9	85.9	62.1
22. CAPACITY FACTOR (USING DER NET) _____	66.2	82.6	58.5
23. UNIT FORCED OUTAGE RATE _____	26.3	5.5	11.8
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: _____



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251

UNIT Turkey Point #4

DATE May 15, 1990

COMPLETED BY R. A. Tierney

TELEPHONE (305) 246-7103

MONTH April, 1990

DAY AVERAGE DAILY POWER LEVEL

(MWe-Net)

4/01/90	685
4/02/90	680
4/03/90	679
4/04/90	683
4/05/90	692
4/06/90	692
4/07/90	685
4/08/90	681
4/09/90	513
4/10/90	-17
4/11/90	-16
4/12/90	-14
4/13/90	-17
4/14/90	-21
4/15/90	-23
4/16/90	-24
4/17/90	-23
4/18/90	47
4/19/90	448
4/20/90	669
4/21/90	679
4/22/90	682
4/23/90	680
4/24/90	676
4/25/90	675
4/26/90	678
4/27/90	678
4/28/90	679
4/29/90	677
4/30/90	671



Handwritten marks and scribbles in the top right corner, possibly including the number '10'.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251

UNIT NAME Turkey Point #4

DATE May 15, 1990

COMPLETED BY R. A. Tierney

TELEPHONE (305) 246-7103

REPORT MONTH April, 1990

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
2	900409	F	214.6	A	3	LER 90-003	AB	CAP	CAUSE OF TRIP WAS THE INTERNAL FAILURE OF AN UNDERFREQUENCY RELAY ON THE REACTOR COOLANT PUMP

1
F Forced
S Scheduled

2
Reason
A - Equipment Failure (Explain)
B - Maintenance or Test
C - Refueling
D - Regulatory Restriction
E - Operator Training & License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3
Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued
5 - Load Reduction
9 - Other (Explain)

4
Exhibit G - Instructions for Preparation of Data Entry Sheets Licensee Event Report (LER) File (NUREG-0161)

5
Exhibit 1 - Same Source



10

11

12