

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9010090192 DOC. DATE: 90/09/28 NOTARIZED: YES DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light Co. 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light Co. 05000251
 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389

AUTH. NAME AUTHOR AFFILIATION
 BOHLKE, W.H. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards response to Generic Ltr 90-03 re relaxation of staff position in GL 83-28, Item 2.2 Part 2.

DISTRIBUTION CODE: A016D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: Generic Ltr 90-03, Relaxation of Staff Position in GL-83-28, Item 2.2

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 1	PD2-2 PD	1 1
	PM-LA BARGE, D	1 1		
INTERNAL:	ACRS	6 6	NRR/DST 8E2	1 1
	NRR/DST/SICB 7E	1 1	NRR/LA BARGE, D	1 1
	OC/LEMB	1 0	OGC/HDS2	1 0
	<u>REG FILE</u>	1 1		
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 17 ENCL 15

MA 4 sub



FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

SEPTEMBER 28 1990

L-90-336
10CFR50.54(f)

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Re: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Generic Letter No. 90-03, Relaxation
of Staff Position in Generic Letter
83-28, Item 2.2 Part 2 "Vendor Interface
for Safety-Related Components"

NRC Generic Letter No. 90-03, Relaxation of Staff Position in Generic Letter 83-28, Item 2.2 Part 2 "Vendor Interface for Safety-Related Components", issued March 20, 1990, provided the elements that the NRC staff has concluded should be contained in a vendor interface program for safety-related components. Florida Power and Light Company's response to the recommendations in GL 90-03 for St. Lucie Units 1 and 2 and Turkey Point Units 3 and 4 is attached.

Should there be any questions, please contact us.

Very truly yours,

W. H. Bohlke
Vice President
Nuclear Engineering and Licensing

WHB/lef

Attachment

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant
Senior Resident Inspector, USNRC, Turkey Point Plant



24

24

24


24

STATE OF FLORIDA)
)
COUNTY OF PALM BEACH) ss.

W. H. Bohlke being first duly sworn, deposes and says:


That he is Vice President, Nuclear Engineering and Licensing of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.



W. H. Bohlke

Subscribed and sworn to before me this
28TH day of SEPTEMBER, 1990.



NOTARY PUBLIC, in and for the County of
Palm Beach, State of Florida

My Commission expires _____

NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. OCT.30,1991
BONDED THRU GENERAL INS. UND.



Attachment

Response to Generic Letter 90-03

Generic Letter 90-03 identifies two specific areas requiring response. To summarize, the NRC staff concluded that an adequate vendor interface program should include:

- a. A program with the NSSS vendor as described in VETIP, which covers all safety-related components within the NSSS scope of supply. This program should include provisions for assuring receipt by the licensee/applicant of all technical information provided by the NSSS vendor.

Response:

Florida Power and Light Company (FPL) actively participated in the Nuclear Utility Task Action Committee (NUTAC) on Generic Letter 83-28, "Required Actions Based on Generic Implications of Salem ATWS Events" Section 2.2.2 for the specific purpose of defining an appropriate vendor interface program. A result of the NUTAC efforts was the development of the Vendor Equipment Technical Information Program (VETIP) as described in Institute of Nuclear Power Operations (INPO) Report 84-10, issued in March 1984. The FPL program for safety-related components within the NSSS scope of supply is in line with the VETIP as developed by NUTAC.

The FPL program includes an established NSSS Vendor Interface Program (Combustion Engineering for St. Lucie Units 1 and 2, Westinghouse for Turkey Point Units 3 and 4) which assures that the most current NSSS vendor information is provided to FPL in information bulletins. FPL provides feedback to the NSSS vendor in the form of a signed receipt for technical information received in these bulletins.

- b. A program of periodic contact with vendors of other key safety-related components not included in (a) above.

Response:

FPL is establishing a program to assure that vendors of "other key safety-related components" are contacted on a periodic basis. Vendors of the Diesel Generators, Auxiliary Feedwater Pumps, Safety-Related Batteries, Inverters and Battery Chargers, Essential Component Cooling Water Pumps, Safety-Related Electrical Switchgear and Safety-Related Non-Manual Valve Operators are considered "other key safety-related component" vendors. This program will consist of periodic direct mailings with additional mailings and/or phone calls until a response is received or all reasonable means of contact prove unsuccessful. The contacts will be documented and filed for future reference. This program will be in place by January 1, 1991.

