

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210190280 DOC. DATE: 92/09/30 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 GOLDIE, M.E. Florida Power & Light Co.
 PLUNKETT, T.F. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Sept 1992 for Turkey Point Units
 1 & 2. W/921012 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: NRR RAGHAVAN, L 05000250
 NRR RAGHAVAN, L 05000251 /

	RECIPIENT	COPIES	RECIPIENT	COPIES
	ID CODE/NAME	LTR ENCL	ID CODE/NAME	LTR ENCL
	PD2-2 LA	3 3	PD2-2 PD	1 1
	AULUCK, R	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP/TPAB	1 1
	NRR/DLPQ/LPEB10	1 1	NRR/DOEA/OEAB	1 1
	<u>REG FILE</u> 01	1 1	RGN2	1 1
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		
NOTES:		1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 15 ENCL 15

Mog
[Handwritten signature]

R
I
D
S
/
A
D
D
S
/
A
D
D
S





OCT 12 1992

L-92-289
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

RE: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of NUREG 0020, attached are the September 1992 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,

T. F. Plunkett
Vice President
Turkey Point Nuclear

TFP/EJW/MEG

attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Ross C. Butcher, Senior Resident Inspector, USNRC, Turkey Point
Plant

9210190280 920930
PDR ADDOCK 05000250
R PDR

an FPL Group company

IE24
11

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250

UNIT Turkey Point #3

DATE October 5, 1992

COMPLETED BY M.E. Goldie

TELEPHONE (305) 246-6089

MONTH September 1992

AVERAGE DAILY POWER LEVEL

(MWe-Net)

9/01/92	0
9/02/92	0
9/03/92	0
9/04/92	0
9/05/92	0
9/06/92	0
9/07/92	0
9/08/92	0
9/09/92	0
9/10/92	0
9/11/92	0
9/12/92	0
9/13/92	0
9/14/92	0
9/15/92	0
9/16/92	0
9/17/92	0
9/18/92	0
9/19/92	0
9/20/92	0
9/21/92	0
9/22/92	0
9/23/92	0
9/24/92	0
9/25/92	0
9/26/92	0
9/27/92	0
9/28/92	0
9/29/92	0
9/30/92	0



OPERATING DATA REPORT

DOCKET NO 50 - 250
 DATE 10/ 6/92
 COMPLETED BY M. E. GOLDIE
 TELEPHONE 305/246/6089

OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 3
2. REPORTING PERIOD: SEPTEMBER 1992
3. LICENSED THERMAL POWER (MWT): _____ 2200
4. NAMEPLATE RATING (GROSS MWE): _____ 760
5. DESIGN ELECTRICAL RATING (NET MWE): _____ 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): _____ 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): _____ 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7)
 SINCE LAST REPORT, GIVE REASONS: _____
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) _____
10. REASONS FOR RESTRICTIONS, IF ANY: _____

	MONTHLY	-YTD-	CUMULATIVE
11. HOURS IN REPORT PERIOD:	720	6575	173768.6
12. NUMBER OF HOURS REACTOR WAS CRITICAL	0.0	5298.7	112024.0
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	844.4
14. HOURS GENERATOR ON-LINE	0.0	5281.6	110493.1
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	121.8
16. GROSS THERMAL ENERGY GENERATED (MWH)	0	10152700	228722766
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	0	3236870	73255256
18. NET ELECTRICAL ENERGY GENERATED (MWH)	-2575	3060583	69253669
19. UNIT SERVICE FACTOR	0.0	80.3	63.6
20. UNIT AVAILABILITY FACTOR	0.0	80.3	63.7
21. CAPACITY FACTOR (USING MDC NET)	0.0	69.9	60.9
22. CAPACITY FACTOR (USING DER NET)	0.0	67.2	57.5
23. UNIT FORCED OUTAGE RATE	100.0	17.2	12.6
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			
UNIT 3 REFUELING OUTAGE - STARTED 10/01/92			

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: 11/22/92

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-250

UNIT Turkey Point Unit 3

DATE October 12, 1992

COMPLETED BY: M.E. Goldie

TELEPHONE: (305) 246-6089

REPORT MONTH September 1992

Unit 3 did not operate in the month of September due to recovery operations in the aftermath of Hurricane Andrew.

Unit 3 will commence its Cycle 13 refueling outage on October 1, 1992.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250
 UNIT NAME Turkey Point #3
 DATE October 12, 1992
 COMPLETED BY M. Goldie
 TELEPHONE (305) 246-6089

REPORT MONTH September 1992

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report#	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
12	920823	F	720.0	H	4	N/A	ZZ	ZZZZZ	Unit Shutdown due to Hurricane Andrew

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

4

Exhibit G - Instructions for Preparation of Data Entry Sheets Licensee Event Report (LER) File (NUREG-0161)

5

Exhibit I - Same Source



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251

UNIT Turkey Point #4

DATE October 5, 1992

COMPLETED BY M.E. Goldie

TELEPHONE (305)-246-6089

MONTH September 1992

AVERAGE DAILY POWER LEVEL

(MWe-Net)

9/01/92	0
9/02/92	0
9/03/92	0
9/04/92	0
9/05/92	0
9/06/92	0
9/07/92	0
9/08/92	0
9/09/92	0
9/10/92	0
9/11/92	0
9/12/92	0
9/13/92	0
9/14/92	0
9/15/92	0
9/16/92	0
9/17/92	0
9/18/92	0
9/19/92	0
9/20/92	0
9/21/92	0
9/22/92	0
9/23/92	0
9/24/92	0
9/25/92	0
9/26/92	0
9/27/92	0
9/28/92	0
9/29/92	0
9/30/92	0

OPERATING DATA REPORT

DOCKET NO 50 - 251
 DATE 10/ 6/92
 COMPLETED BY M. E. GOLDIE
 TELEPHONE 305/246/6089

OPERATING STATUS

1. UNIT NAME: TURKEY POINT UNIT 4
2. REPORTING PERIOD: SEPTEMBER 1992
3. LICENSED THERMAL POWER (MWT): _____ 2200
4. NAMEPLATE RATING (GROSS MWE): _____ 760
5. DESIGN ELECTRICAL RATING (NET MWE): _____ 693
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): _____ 699
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): _____ 666
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS: _____
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) _____
10. REASONS FOR RESTRICTIONS, IF ANY: _____

	MONTHLY	-YTD-	CUMULATIVE
11. HOURS IN REPORT PERIOD: _____	720	6575	167500.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL _____	37.1	5553.6	108166.1
13. REACTOR RESERVE SHUTDOWN HOURS _____	0.0	0.0	166.6
14. HOURS GENERATOR ON-LINE _____	0.0	5482.1	104385.5
15. UNIT RESERVE SHUTDOWN HOURS _____	0.0	0.0	32.1
16. GROSS THERMAL ENERGY GENERATED (MWH) _____	0	11799592	220113929
17. GROSS ELECTRICAL ENERGY GENERATED (MWH) _____	0	3779530	70251840
18. NET ELECTRICAL ENERGY GENERATED (MWH) _____	-5103	3591938	66443700
19. UNIT SERVICE FACTOR _____	0.0	83.4	62.3
20. UNIT AVAILABILITY FACTOR _____	0.0	83.4	62.3
21. CAPACITY FACTOR (USING MDC NET) _____	0.0	82.0	60.6
22. CAPACITY FACTOR (USING DER NET) _____	0.0	78.8	57.2
23. UNIT FORCED OUTAGE RATE _____	100.0	16.5	12.1
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS :			

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: 10/01/92



SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251

UNIT Turkey Point Unit 4

DATE October 5, 1992

COMPLETED BY: M.E. Goldie

TELEPHONE: (305) 246-6089

REPORT MONTH September 1992

Unit 4 did not operate from September 1 to September 29 due to continued recovery operations in the aftermath of Hurricane Andrew.

Unit 4 did commence startup sequence on September 30 and attain criticality.



UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251
 UNIT NAME Turkey Point #4
 DATE October 6, 1992
 COMPLETED BY M. Goldie
 TELEPHONE (305) 246-6089

REPORT MONTH September 1992

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report#	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
10	920823	F	720.0	H	4	N/A	ZZ	ZZZZZ	Unit Shutdown due to Hurricane Andrew.

1
 F - Forced
 S - Scheduled

2
 Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error
 (Explain)
 H - Other (Explain)

3
 Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

4
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets Licensee
 Event Report (LER) File
 (NUREG-0161)

5
 Exhibit 1 - Same Source

