

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power and Light Company
Turkey Point, Units 3 and 4

Docket Nos. 50-250, 50-251
License Nos. DPR-31, DPR-41

During an NRC inspection conducted on October 3 through 30, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.8.1 requires that written procedures be established, implemented, and maintained covering activities recommended in Appendix A of Regulatory Guide 1.33, Revision 2, February, 1978.

Section 9 of Appendix A of Regulatory Guide 1.33 recommends procedures for performing maintenance.

Administrative Procedure 0190.19, Control of Maintenance and Construction Work on Safety Related and Quality Related Systems, paragraph 3.2.1, states that work activities which can affect the performance of safety related and quality related equipment shall be appropriately preplanned and shall be performed in accordance with written procedures, documented instructions, or drawings appropriate to the circumstances.

Procedure O-GMI-102.26, Alteration of Eagle 21 Protection System Parameters, Section 6.6, Protection Set III Parameter Update, on page 38, requires that the field supervisor verify that the correct parameters were updated and the correct values for parameters were entered.

Contrary to the above, on September 19, 1992, incorrect scaling constants for the channel III resistance temperature detectors were entered into the Eagle 21 protection system and were improperly verified as correct by the field supervisor.

This is a Severity Level IV violation (Category 1).

Pursuant to the provisions of 10 CFR 2.201, Florida Power and Light Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector at the facility that is the subject of this notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the

9212170069 921125
PDR ADDCK 05000250
G PDR

Florida Power and Light Company
Turkey Point, Units 3 and 4

2

Docket Nos. 50-250, 50-251
License Nos. DPR-31, DPR-41

corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 25th day of November 1992

