

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power and Light Company  
Turkey Point Units 3 and 4

Docket Nos. 50-250, 50-251  
License Nos. DPR-31, DPR-41

During an NRC inspection conducted on October 31 through December 4, 1992, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.8.1.h requires that written procedures be established, implemented, and maintained covering activities referenced in the facility Fire Protection Program.

The Fire Protection Program, described in Appendix 9.6A of the facility Final Safety Analysis Report, paragraph 7.1, states:

The Fire Protection Program at Turkey Point Units 3 and 4 is established by procedure. The procedures shall provide surveillance and maintenance requirements for fire protection equipment and systems.

Procedure O-OP-16.1, Fire Protection Water System, Attachment 1, Fire Protection Water System Valve Alignment, requires that valves 10-753, Raw Water Tanks Tie; 10-759, Full Flow Recirculation Isolation; and 10-777, Raw Water Tank II Outlet to Jockey Pumps, be locked in the closed position.

Contrary to the above, on November 10, 1992, valves 10-753, 10-759, and 10-777 were found in the closed position, but were not properly locked in position. The locks were secured to the valve yokes, and not through the handwheels as required to lock the valves in the closed position.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Florida Power and Light Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector at the facility that is the subject of this notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the



Florida Power and Light Company  
Turkey Point Units 3 and 4

2

Docket Nos. 50-250, 50-251  
License Nos. DPR-31, DPR-41

corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia  
this *30<sup>th</sup>* day of December, 1992

