

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power and Light Company  
Turkey Point, Units 3 and 4

Docket Nos. 50-250, 50-251  
License Nos. DPR-31, DPR-41

During an NRC inspection conducted on January 1-29, 1993, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 6.8.1 requires that written procedures be established, implemented, and maintained covering the activities referenced in Appendix A of Regulatory Guide 1.33, revision 2, February 1978, which include: administrative procedures for authorities and responsibilities for safe operation and shutdown, and operating procedures for going from Hot Shutdown to Cold Shutdown.

Administrative procedure O-ADM-200, Conduct of Operations, paragraph 5.6.20, states that communications to operating personnel must be clear and concise. These directions shall be given in such a manner that they are explicit and understandable. This should be verified for complex orders and those orders that include numbers by having the operator repeat them back or by providing written direction so that the director is satisfied that the orders are understood. Upon completion of the directed evolution, the operator shall report back to the controlling station the exact action that he/she has taken.

Contrary to the above, at approximately 5:00 a.m. on January 16, 1993, with the reactor coolant temperature at approximately 350 degrees F, the reactor control operator failed to follow Administrative Procedure O-ADM-200 when he directed the senior nuclear plant operator to accomplish the highlighted portions of Attachment 1 to procedure 3-GOP-305, Hot Standby to Cold Shutdown. No explicit directions were provided and no report back of the exact action taken was accomplished, resulting in the inadvertent isolation of the containment spray system prior to reactor coolant temperature being less than 200 degrees F.

This is a Severity Level IV violation (Supplement 1).

Pursuant to the provisions of 10 CFR 2.201, Florida Power and Light Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector at the facility that is the subject of this notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the



Florida Power and Light Company  
Turkey Point, Units 3 and 4

2

Docket Nos. 50-250, 50-251  
License Nos. DPR-31, DPR-41

corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or demand for information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia  
this 17th day of February 1993

