

ENCLOSURE 1

NOTICE OF VIOLATION

Florida Power and Light Company
Turkey Point Nuclear Plant

Docket Nos. 50-250 and 50-251
License Nos. DPR-31 and DPR-41

During an NRC inspection conducted on February 28 - March 4, 1994, and subsequent April 5, 1994 teleconference, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," the violation is listed below:

Technical Specification (TS) 6.4.1 requires a retraining and replacement training program for the facility staff to be maintained under the direction of the Training Manager, and to meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971, 10 CFR Part 55 and ANSI 3.1, 1981, and to include familiarization with relevant industry operational experience. Section 5.5 of both ANSI 18.1-1971 and ANSI 3.8-1981 specify that training programs be established which maintain staff proficiency.

Contrary to the above, as of March 4, 1994, the licensee's specialized retraining program was inadequate in maintaining staff proficiency in that responsible chemistry personnel were not trained adequately regarding operation of the liquid scintillation counting system. Proficiency shortcomings were demonstrated by staff failure to describe properly efficiency calibration methods and quench and radioactive decay corrections used for the automatic analysis protocol established for analytical tritium (H-3) measurements.

This is a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Florida Power and Light Company is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or Demand for Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia.
this 5th day of MAY 1994

9405180137 940505
PDR ADDCK 05000250
Q PDR