

DMR Copy of Record

Permit

Permit #: LA0042731	Permittee: Entergy Operations, Inc.- River Bend Station	Facility: ENTERGY OPERATIONS, INC.- RIVER BEND STATION
Major: Yes	Permittee Address: 5485 US Highway 61 St. Francisville, LA 70775	Facility Location: 5485 US HWY 61 ST. FRANCISVILLE, LA 70775
Permitted Feature: 101 Internal Outfall	Discharge: 101-A Low level radioactive low volume ww	

Report Dates & Status

Monitoring Period: From 06/01/17 to 06/30/17	DMR Due Date: 07/15/17	Status: NetDMR Validated
---	-------------------------------	---------------------------------

Considerations for Form Completion

*WHEN DISCHARGING

Principal Executive Officer

First Name:	Title:	Telephone:
Last Name:		

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Typ	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	0.1	=	0.3	19 - mg/L		01/30 - Monthly	GR - GRAB
					Permit Req.						<=	30 MO AVG	<=	100 DAILY MX	19 - mg/L			
					Value NODI													
03582	Oil and grease	1 - Effluent Gross	0	--	Sample						=	1.05	=	1.71	19 - mg/L		01/30 - Monthly	GR - GRAB
					Permit Req.						<=	15 MO AVG	<=	20 DAILY MX	19 - mg/L			
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.026	=	0.058	03 - MGD						01/30 - Monthly	ES - ESTIMA	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD								
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

One TSS hold time for a sample pulled on 6/12/17 exceeded the 7 day hold time. When analyzed on 6/20/17 the results were 0.0 mg/L. These results were aligned with other results from this outfall. The station is modifying the scheduling process to an automated schedule and tracking. Increased oversight has been initiated.

Attachments

No attachments.

Report Last Saved By

Entergy Operations, Inc.- River Bend Station

User: rhillia@entergy.com	Date/Time: 2017-07-13 14:13 (Time Zone: -05:00)
Name: Robert Hilliard	
E-Mail: rhillia@entergy.com	