

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508100105 DOC. DATE: 95/08/02 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 50-302 Crystal River Nuclear Plant, Unit 3, Florida Power Co 05000302
 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389

AUTH. NAME MERSCHOFF, E. AUTHORITY AFFILIATION Region 2 (Post 820201)
 RECIP. NAME RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: PNO-II-95-046D: on 950801, both Units to plant had been placed in Mode 3 in anticipation of Hurricane Erin. All hurricane warnings have been discontinued. Region II continues to monitor conditions at plant.

DISTRIBUTION CODE: IE34D COPIES RECEIVED: LTR ϕ ENCL 1 SIZE: 1
 TITLE: Preliminary Notification-Occurrence/Non-Routine Event/Safeguards Even

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
INTERNAL:	ACRS	1	FILE-CENTER	1
	NRR/DISP/PIPB	1	NRR/DOTS/TERB	1
	NUDOCS-ABSTRACT	1	OE DIR	1
	RES/DRA	1	RES/DSIR/EIB	1
	RES/DSR DEPY	1	RES/DST	1
	RES/FMPAS	1	RES/RPHEB	1
	RGN2 FILE 01	1		
EXTERNAL:	LITCO BRYCE, J H	1	NOAC	1
	NRC PDR	1	NUDOCS FULL TXT	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2033) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 9 ENCL 17

A04

F
F
I
C
F
I
T
Y
2
D
C
C
U
M
E
N
T

August 2, 1995

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-95-046D

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by Region II staff (Atlanta, Georgia) on this date.

Facility

Florida Power & Light Co.
Turkey Point 3 4
Miami, Florida
Dockets: 50-250, 50-251

Licensee Emergency Classification

Notification of Unusual Event
Alert
Site Area Emergency
General Emergency
X Not Applicable

Florida Power & Light Co.
Saint Lucie 1 2
Florida
Dockets: 50-335, 50-389

Florida Power Corporation
Crystal River 3
Crystal River, Florida
Dockets: 50-302

Subject: HURRICANE ERIN

Region II monitored the progress of Hurricane Erin throughout the evening. At 10:50 p.m. on August 1, 1995, an open communications line was established among the St. Lucie Site, the Florida Power and Light Company Emergency offsite facility, Nuclear Regulatory Commission Headquarters and Region II Incident Response Center. In anticipation of the storm's arrival, St. Lucie Units 1 and 2 were placed in Mode 3 by 3:00 p.m. on August 1, 1995. Hurricane Erin came ashore about 20 miles north of the St. Lucie Plant at 2:00 a.m. August 2, 1995. Maximum wind speed at the St. Lucie site was approximately 40 mph. On-site damage assessments were conducted at 4:00 a.m. with no damage noted. Off-site damage assessment is underway.

The storm is expected to pass almost directly over Crystal River around noon today. The Crystal River Technical Support Center has been staffed since about 3:00 a.m. and has maintained an open line of communication with the NRC since that time. The Senior Resident Inspector is on site and monitoring licensee activities.

The 5:00 a.m. report from the National Weather Service downgraded the hurricane to a tropical storm and discontinued all hurricane warnings. St. Lucie secured from an Unusual Event at 5:42 a.m. Region II continues to monitor conditions at Crystal River.

This information is current as of 7:00 a.m.

Contact: E. Merschoff
(404) 331-5089

050036

9508100105 950802
PDR I&E
PNO-II-95-046D PDR

o/l
7230