

ATTACHMENT 3 to L-96-200

PROPOSED LICENSE AMENDMENTS FOR
DEFERRAL OF REACTOR COOLANT PUMP FLYWHEEL INSPECTION

PROPOSED TECHNICAL SPECIFICATIONS PAGE

3/4 4-38

9610100215 961003
PDR ADCK 05000250
P PDR



REACTOR COOLANT SYSTEM

3/4.4.10. STRUCTURAL INTEGRITY

LIMITING CONDITION FOR OPERATION

3.4.10 The structural integrity of ASME Code Class 1, 2 and 3 components shall be maintained in accordance with Specification 4.4.10.

APPLICABILITY: ALL MODES

ACTION:

- a. With the structural integrity of any ASME Code Class 1 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature more than 50°F above the minimum temperature required by NDT considerations.
- b. With the structural integrity of any ASME Code Class 2 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) prior to increasing the Reactor Coolant System temperature above 200°F.
- c. With the structural integrity of any ASME Code Class 3 component(s) not conforming to the above requirements, restore the structural integrity of the affected component(s) to within its limit or isolate the affected component(s) from service.

SURVEILLANCE REQUIREMENTS

4.4.10 In addition to the requirements of Specification 4.0.5, each reactor coolant pump flywheel shall be inspected per the recommendations of Regulatory Position C.4.b of Regulatory Guide 1.14, Revision 1, August 1975,

except, the volumetric examination of the Turkey Point Units 3 and 4 flywheels may be delayed one cycle to coincide with the refueling outages currently scheduled for September 1998 and March 1999 respectively.

