

November 8, 1996

Florida Power and Light Company
ATTN: Mr. T. F. Plunkett
President - Nuclear Division
P. O. Box 14000
Juno Beach, FL 33408-0420

SUBJECT: PLANT PERFORMANCE REVIEW (PPR) - TURKEY POINT 3 and 4

Dear Mr. Plunkett:

On October 2, 1996, the regional staff completed the semiannual Plant Performance Review (PPR) of Turkey Point 3 and 4. The staff conducts these reviews for all operating nuclear power plants to develop an integrated understanding of safety performance. The results are used by regional management to facilitate planning and allocation of inspection resources. The PPR for Turkey Point 3 and 4 involved the participation of all technical divisions in evaluating inspection results and safety performance information for the period from March 1996 to September 1996. PPRs provide regional management with a current summary of licensee performance and serve as inputs to the NRC Systematic Assessment of Licensee Performance (SALP) and senior management meeting (SMM) reviews.

This letter advises you of our planned inspection effort resulting from the Turkey Point 3 and 4 PPR review. It is provided in an attempt to minimize the resource impact on your staff and to allow for scheduling conflicts to be resolved in advance of inspection dates. The enclosure presents our inspection plan for the next six months. Specific dates are included for near term inspections. Long term inspection dates will be announced prior to the inspections and any scheduling conflicts will be resolved with your staff. The rationale or basis for each inspection outside the core inspection program is provided so that you are aware of the reasons for emphasis in these program areas. Resident inspections are not listed due to their ongoing and continuous nature, nor are region based inspections which accomplish Resident Core Modules to compensate for Resident Inspector absences due to training.

During each NRC inspection planned during this period, specific attention will continue to be given to the verification of selected Updated Final Safety Analysis Report (UFSAR) commitments. Applicable portion(s) of the UFSAR that relate to the inspection activities will be reviewed and verification made that the UFSAR commitments have been properly implemented into plant practices, procedures and/or parameters.

OFFICIAL COPY

9611150292 961108
PDR ADOCK 05000250
G PDR

11
IE 01

FP&L

2

We will inform you of any changes to the inspection plan. If you have any questions, please contact Kerry Landis at 404-331-5509.

Sincerely,

Orig signed by Kerry D. Landis

Kerry D. Landis, Chief
Reactor Projects Branch 3
Division of Reactor Projects

Docket No. 50-250 and 251
License Nos. DPR-31 and DPR 41

Enclosure: Inspection Plan

cc w/encl:
H. N. Paduano, Manager
Licensing & Special Programs
Florida Power and Light Company
P. O. Box 14000
Juno Beach, FL 33408-0420

Plant General Manager
Turkey Point Nuclear Plant
P. O. Box 029100
Miami, FL 33102

R. J. Hovey
Site Vice President
Turkey Point Nuclear Plant
P. O. Box 029100
Miami, FL 33102

G. E. Hollinger
Licensing Manager
Turkey Point Nuclear Plant
P. O. Box 4332
Miami, FL 33032-4332

M. S. Ross, Attorney
Florida Power & Light
11770 US Highway 1
North Palm Beach, FL 33408

John T. Butler, Esq.
Steel, Hector and Davis
4000 Southeast Financial Center
Miami, FL 33131-2398

Attorney General
 Department of Legal Affairs
 The Capitol
 Tallahassee, FL 32304

Bill Passetti
 Office of Radiation Control
 Department of Health and
 Rehabilitative Services
 1317 Winewood Boulevard
 Tallahassee, FL 32399-0700

Armando Vidal
 County Manager of Metropolitan
 Dade County
 111 NW 1st Street, 29th Floor
 Miami, FL 33128

Joe Myers, Director
 Division of Emergency Preparedness
 Department of Community Affairs
 2740 Centerview Drive
 Tallahassee, FL 32399-2100

Distribution w/encl:

R. Croteau, NRR
 B. Crowley, RII
 G. Hopper, RII
 G. Hallstrom, RII
 PUBLIC

Thomas P. Johnson
 Senior Resident Inspector
 U.S. Nuclear Regulatory Commission
 P. O. Box 1448
 Homestead, FL 33090

SEND TO PUBLIC DOCUMENT ROOM?		YES	NO								
OFFICE											
SIGNATURE	<i>SM</i>	<i>H</i>		<i>D</i>	<i>CB</i>	<i>KB</i>	<i>TP</i>				
NAME	Smith	HChristensen	CCasto	PFredrickson	KBarr	TPeebles					
DATE	11 / 1 / 96	11 / 1 / 96	11 / 1 / 96	11 / 1 / 96	11 / 1 / 96	11 / 1 / 96	11 / 1 / 96				
COPY?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO				
OFFICE											
SIGNATURE											
NAME	EHerschoff	SEbnetter									
DATE	11 / / 96	11 / / 96	11 / / 96	11 / / 96	11 / / 96	11 / / 96	11 / / 96				
COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO				

TURKEY POINT INSPECTION PLAN

INSPECTION PROCEDURE/ TEMPORARY INSTRUCTION	TITLE/PROGRAM AREA	NUMBER OF INSPECTORS	PLANNED INSPECTION DATES	TYPE OF INSPECTION - COMMENTS
IP 37550	POWER CURVES AND UPRATE CURVES INSPECTION	2	9/29/96 - 10/27/96	REGIONAL INITIATIVE - TO MONITOR EQUIPMENT RECALIBRATION AND REVIEW POWER CURVES RELATED TO POWER UPRATE.
IP 62700	REMOTE SAFE SHUTDOWN PANEL	1	11/4-8/96	REGIONAL INITIATIVE - TO REVIEW MAINTENANCE AND TESTING OF SAFE SHUTDOWN PANELS
IP 81700	SECURITY PROGRAM	1	12/16-20/96	CORE- SECURITY AUDITS, CORRECTIVE ACTIONS, MANAGEMENT SUPPORT AND EFFECTIVENESS, AND REVIEW PROTECTED AREA DETECTION EQUIPMENT.
IP 71001	LICENSED OPERATOR REQUALIFICATION PROGRAM EVALUATION	1	1/13-16/97	REQUALIFICATION PROGRAM INSPECTION
IP 81700	SECURITY PROGRAM/RA	4	2/3-7/97	REGIONAL INITIATIVE WITH NRR ASSIST TO EXERCISE SECURITY SYSTEMS AND EQUIPMENT.
IP 82301/82302	BIENNIAL EXERCISE FEMA EVALUATED	3	2/3-7/97	CORE - EP
IP 73753	INSERVICE INSPECTION	1	3/24-28/97	CORE- MAINTENANCE
TI2515/109	MOV INSPECTION	1	3/24-28/97	REGIONAL INITIATIVE
IP 62700	OUTAGE MAINTENANCE AND STEAM RELIEF VALVES INSPECTION	1	3/31-4/4/97	REGIONAL INITIATIVE - TO REVIEW MAINTENANCE AND TESTING OF MAIN STEAM RELIEFS

