

Proposed Technical Specification Pages

6-21

6-22

9703040221 970224
PDR ADOCK 05000250
P PDR

PEAKING FACTOR LIMIT REPORT

6.9.1.6 The W(Z) function(s) for Base-Load Operation corresponding to a $\pm 2\%$ band about the target flux difference and/or a $\pm 3\%$ band about the target flux difference, the Load-Follow function $F_z(Z)$ and the augmented surveillance turnon power fraction, P_T , shall be provided to the U.S. Nuclear Regulatory Commission, whenever P_T is < 1.0 . In the event, the option of Baseload Operation (as defined in Section 4.2.2.3) will not be exercised, the submission of the W(Z) function is not required. Should these values (i.e., W(Z), $F_z(Z)$ and P_T) change requiring a new submittal or an amended submittal to the Peaking Factor Limit Report, the Peaking Factor Limit Report shall be provided to the NRC Document Control desk with copies to the Regional Administrator and the Resident Inspector within 30 days of their implementation, unless otherwise approved by the Commission.

The analytical methods used to generate the Peaking Factor limits shall be those previously reviewed and approved by the NRC. If changes to these methods are deemed necessary they will be evaluated in accordance with 10 CFR 50.59 and submitted to the NRC for review and approval prior to their use if the change is determined to involve an unreviewed safety question or if such a change would require amendment of previously submitted documentation.

CORE OPERATING LIMITS REPORT

6.9.1.7 Core operating limits shall be established and documented in the CORE OPERATING LIMITS REPORT (COLR) before each reload cycle or any remaining part of a reload cycle for the following:

1. Axial Flux Difference for Specification 3.2.1.
2. Control Rod Insertion Limits for Specification 3.1.3.6.
3. Heat Flux Hot Channel Factor - $F_0(Z)$ for Specification 3/4.2.2.
4. All Rods Out position for Specification 3.1.3.2.
5. Nuclear Enthalpy Rise Hot Channel Factor for Specification 3/4.2.3

The analytical methods used to determine the AFD limits shall be those previously reviewed and approved by the NRC in:

1. WCAP-10216-P-A, "RELAXATION OF CONSTANT AXIAL OFFSET CONTROL F_0 SURVEILLANCE TECHNICAL SPECIFICATION," June 1983.
2. WCAP-8385, "POWER DISTRIBUTION CONTROL AND LOAD FOLLOWING PROCEDURES - TOPICAL REPORT," September 1974.

The analytical methods used to determine $F_0(Z)$, $F_{\Delta H}$ and the K(Z) curve shall be those previously reviewed and approved by the NRC in:

1. WCAP-9220-P-A, Rev. 1, "Westinghouse ECCS Evaluation Model - 1981 Version," February 1982.

DELETE
→

2. WCAP-9561-P-A, ADD. 3, Rev. 1, "BART A-1: A Computer Code for the Best Estimate Analysis of Reflood Transients - Special Report: Thimble Modeling & ECCS Evaluation Model."
--

→ 2. REPLACE

1. WCAP-10054-P-A, (proprietary), "Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code", August 1985.

ADMINISTRATIVE CONTROLS

3. REPLACE

WCAP-10054-P, Addendum 2, Revision 1 (proprietary), "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code: Safety Injection in the Broken Loop and Improved Condensation Model", October 1995.*

DELETE

5.	WCAP-10266-P-A, Rev 2 (proprietary), and WCAP-11524-NP-A, Rev 2 (non-proprietary), "The 1981 Version of the Westinghouse ECCS Evaluation Model Using the BASH Code," May 1988.
6.	NTD-NRC-94-4143, "Change in Methodology for Execution of BASH Evaluation Model," May 23, 1994.

INSERT → A

The analytical methods used to determine Rod Bank Insertion Limits and the All Rods Out position shall be those previously reviewed and approved by the NRC in:

1. WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.

The ability to calculate the COLR nuclear design parameters are demonstrated in:

1. Florida Power & Light Company Topical Report NF-TR-95-01, "Nuclear Physics Methodology for Reload Design of Turkey Point & St. Lucie Nuclear Plants".

Topical Report NF-TR-95-01 was approved by the NRC for use by Florida Power & Light Company in:

1. Safety Evaluation by the Office of Nuclear Reactor Regulations Related to Amendment No. 174 to Facility Operating License DPR-31 and Amendment No. 168 to Facility Operating License DPR-41, Florida Power & Light Company Turkey Point Units 3 and 4, Docket Nos. 50-250 and 50-251.

The AFD, $F_0(Z)$, $F_{\Delta H}$, $K(Z)$, and Rod Bank Insertion Limits shall be determined such that all applicable limits of the safety analyses are met. The CORE OPERATING LIMITS REPORT, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, for each reload cycle, to the NRC Document Control Desk with copies to the Regional Administrator and Resident Inspector, unless otherwise approved by the Commission.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator of the Regional Office of the NRC within the time period specified for each report as stated in the Specifications within Sections 3.0, 4.0, or 5.0.

*This reference is only to be used subsequent to NRC approval.



Insert A

4. WCAP-12945-P, "Westinghouse Code Qualification Document For Best Estimate LOCA Analysis," Volumes I-V.
5. USNRC Safety Evaluation Report, Letter from R. C. Jones (USNRC) to N. J. Liparulo (W), "Acceptance for Referencing of the Topical Report WCAP-12945(P) 'Westinghouse Code Qualification Document for Best Estimate Loss of Coolant Analysis,'" June 28, 1996.



[Faint, illegible text scattered across the upper portion of the page, possibly bleed-through from the reverse side.]