

December 21, 2017

NRC Supplement to NRC Letter – INFORMATION REQUEST FOR AN NRC TRIENNIAL 10 CFR 50.59 BASELINE INSPECTION DATED November 17, 2017 (Hereafter Items referred to are from this NRC Letter).

NRC Supplemental Information Requests for – Dresden Station

The following Evaluations, Screenings, and Applicability Determinations are requested:

Evaluations:

2016-04-001	EC 405313	ESSENTIAL SERVICES BUS UFSAR AND TECHNICAL SPECIFICATION BASES UPDATE
2016-03-002	TCCP 405013	UTILIZE MSIV 2A SWITCH AS THE RPS SIGNAL FOR FAILED 1B CONTACT
2016-03-001	EC 380008, 383022, UFSAR Change 16-002	On-Line Noble Metals Chemical (OLNC) Injection for Unit 2 and Unit 3
2016-10-001	EC 391644	Reactor and Diesel Building Flood Barriers
2016-05-001	UFSAR tracking number 15-019	Revise references within UFSAR Section 9.6.4.1.5
2016-03-002	TCCP 405013	Reactor and Diesel Building Flood Barriers

Screenings:

13085	2017-212	DOA 6900-02	Procedure	FAILURE OF UNIT 2 125 VDC POWER SUPPLY
13058	2017-187	EC 402740	Facility Change	Basis for Declassification of Power Supplies for RWCU Leak Detection Panels to Non-EQ
12751	2016-228	EC 406198	Facility Change	INSTALL TEMPORARY 120V FEED FROM UNIT 2 SBO UPS TO UNIT 3 SBO ENGINE CONTROL CIRCUIT
12566	2016-059	405048,405049, 405050,405051, 405052,405053, 405054	Facility Change	UTILIZE 2A SWITCH AS THE RPS SIGNAL FOR THE FAILED 1A and 1B CONTACT

12475	2015-356	TRM Change 15-014		Revise TRM Sections 3.3.e, and Section 3.7.k
12242	2015-144	EC 402314	Facility Change	Temporary Installation of Emergency Lighting Units (ELU) for the 903-39 Panels
12993	2017-123	MR90 618106	Facility Change	MR90 CONNECT BATTERY CHARGER 3-8350-3B DIRECTLY TO CHARGE NEW U3 BOP 250VDC BATTERY
12970	2017-101	DOS 6620-08 Rev 03	Procedure	SBO 2(3) DIESEL GENERATOR OVERSPEED TRIP TEST
12908	2017-041	DOP 6900-06 Rev 39	Procedure	125 VDC GROUND DETECTION UNIT 2
12836	2016-51	EC 407161	Facility	Jumper Cell 3 and Cell 110 on 250 VDC Station Battery
13061	2017-190	EC 618606	Facility Change	Unit 1 Fuel Oil Transfer System Replacement
13031	2017-160	DOP 3200-09, rev 27	Procedure	ZINC INJECTION SYSTEM OPERATION
13018	2017-147	DGA-12 rev76	Procedure	LOSS OF OFFSITE POWER
12995	2017-125	DSSP 0200-S rev 17	Procedure	SDC COLD SHUTDOWN METHOD
12890	2017-023	17-002	Facility Change	Largest Single Load For Emergency Diesel Generators
12789	2016-46	EC 393280	Facility Change	NUCLEAR FUEL TRANSITION TO AREVA ATRIUM 10XM
12269	2015-169	DGP 04-01 Rev 32	Procedure	FUEL MOVES AND REFUELING
12193	2015-093	DOP 5750-02 Rev 44	Procedure	REACTOR BUILDING VENTILATION
12233	2015-135	DOP 0220-01 Rev 12	Procedure	RPV HEAD COOLING
12491	2015-372	EC 402480	Facility Change	RWCU HELB CALC IN EQ ZONE 28/ REVISION 1 OF CALC.DR-067-M-001

12214	2015-116	EC 399633	Facility Change	FW Check Valve Test Taps "A" Line - U2
12283	2015-182	WO 1312947-01	Facility Change	Installation of New 2-1201-1 Valve During D2R24
12587	2016-080	UFSAR 5.4.6.3	Facility Change	Revision to UFSAR section 5.4.6.3
12261	2015-161	DAN 902(3)-3 D-4 Rev13	Procedure	ISOL CONDR LVL HI/LO
12262	2015-162	DOP 1300-02 Rev 27	Procedure	AUTOMATIC OPERATION OF ISOLATION CONDENSER
12263	2015-163	DOP 1300-03 Rev 36	Procedure	MANUAL OPERATION OF THE ISOLATION CONDENSER
12404	2015-289	EC 400578	Facility Change	Hardened Containment Vent System – Modification – U3 Online
12510	2016-005	DOP 6620-21 Rev 08	Procedure	UNIT 2(3) SBO VENTILATION
12539	2016-033	DOP 0010-13 Rev 07	Procedure	SEISMIC EVENT RETRIEVAL/EVALUATION
12593	2016-083	EC 404969	Facility Change	MOV 2-3906 TO BE CHANGED TO MANUALLY OPERATED VALVE
12570	2016-167	DOP 1500-02	Procedure	TORUS WATER COOLING MODE OF LOW PRESSURE COOLANT INJECTION SYSTEM
12723	2016-205	UFSAR Change No. 16-012	Procedure	Appendix R Elevated Temperature and HPCI Operation
12912	2017-045	EC 618693	Facility Change	DISPOSITION OF 175 FT-LBF FOR THE MOUNTING BOLTS ON U3 MSIVS LIMIT SWITCH MOUNTING PLATES

Applicability Determinations:

0000388891	20171130	2013: UNIT 2 SR 480V MCC BUCKET REPLACEMENT PROJECT
0000622072	20171115	BREAKER TRIP SETTING CHANGE AT MCC 2-7826-1F3 FOR MOTOR FOR 2A REACTOR FEED PUMP DISCHARGE VALVE MOV 2-3201-A
0000388891	20171130	2013: UNIT 2 SR 480V MCC BUCKET REPLACEMENT PROJECT

