ACCESSION NBR:8306160116 DOC.DATE: 83/06/13 NOTARIZED: NO DOCKET # FACIL:50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400 50-401 Shearon Harris Nuclear Power Plant, Unit 2, Carolina 05000401

AUTH,NAME AUTHOR AFFILIATION MCDUFFIE,M.A. Carolina Power & Light Co. RECIP.NAME RECIPIENT AFFILIATION

DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards responses to Power Sys Branch draft SER Open Item 117 re cooling water leakage.Impact of flooding from postulated breaks in moderate energy fluid sys have no adverse effects on diesel generator areas.

DISTRIBUTION CODE: BOOIS COPIES RECEIVED:LTR _ ENCL _ SIZE:________ TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT		COPIES		RECIPIENT	COPI	IES
	ID CODE/NAME		LTTR	ENCL	 ID CODE/NAME 	LTTR	ENCL
	NRR/DL/ADL		1	0	NRR LB3 BC	1	0
	NRR LB3 LA		1	0	KADAMBI,P 01	1	1 -
INTERNAL:	ELD/HDS1		1	0	IE FILE	1	1.
	IE/DEPER/EPB	36	3	3	IE/DEPER/IRB 35	1	1
	IE/DEQA/QAB	21	1	1	NRR/DE/AEAB	1	0
	NRR/DE/CEB	11	1	1	NRR/DE/EHEB	1	1
	NRR/DE/EQB	13	2	2	NRR/DE/GB 28	2	2
	NRR/DE/MEB	18	1	1	NRR/DE/MTEB 17	1	. 1
	NRR/DE/SAB	24	1	1	NRR/DE/SGEB 25	1	1
	NRR/DE/SGEB	30	1	1	NRR/DHFS/HFEB40	1	1
	NRR/DHFS/LQB	32	1	1	NRR/DHFS/PSRB	1	1
	NRR/DL/SSPB	4	ĩ	0	NRR/DSI/AEB 26	1	1
	NRR/DSI/ASB		1	1	NRR/DSI/CPB 10	1	1
	NRR/DSI/CSB	09	ī	1	NRR/DSI/ICSB 16	1	1
	NRR/DSI/METB	12	ĩ	1	NRR/DSI/PSB 19	1	1
	NRR/DSI/RAB	22	ī	ĩ	NRR/DSI/RSB 23	1	1
C	REG FILE	04	1	Ĩ	RGN2	-3	3
	RM/DDAMI/MIB		ĩ	Ö	j		
EXTERNAL:	ACRS	41	6	6	BNL(AMDTS ONLY)	1	1
	DMB/DSS (AMD)	rs)	1	1	FEMA-REP DIV 39	1	1
	LPDR	03	ī	1	NRC PDR 02	1	1
	NSIC	05	ĩ	1	NTIS	1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 54 ENCL 47

الإسلال مالية المراجعة المراجع مراجعة المراجعة المراجع

۰. ب .



JUN 13 1983

SERIAL: LAP-83-201

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation United States Nuclear Regulatory Commission Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT UNIT NOS. 1 AND 2 DOCKET NOS. 50-400 AND 50-401 DRAFT SAFETY EVALUATION REPORT RESPONSES POWER SYSTEMS BRANCH

Dear Mr. Denton:

Carolina Power & Light Company (CP&L) hereby transmits one original and forty copies of a response to a Shearon Harris Nuclear Power Plant Draft Safety Evaluation Report Open Item. This response is for the Power Systems Branch, and is CP&L Open Item No. 117.

We will be providing responses to other Open Items in the Draft Safety Evaluation Report shortly.

Yours very truly,

mamor

M. A. McDuffie Senior Vice President Engineering & Construction

JDK/lcv (6939JDK)

Attachment

cc: Mr. N. Prasad Kadambi (NRC) Mr. G. F. Maxwell (NRC-SHNPP) Mr. J. P. O'Reilly (NRC-RII) Mr. Travis Payne (KUDZU) Mr. Daniel F. Read (CHANGE/ELP) Chapel Hill Public Library Wake County Public Library Mr. Wells Eddleman Dr. Phyllis Lotchin Mr. John D. Runkle Dr. Richard D. Wilson Mr. G. O. Bright (ASLB) Dr. J. H. Carpenter (ASLB) Mr. J. L. Kelley (ASLB)

Wake Cou B306160116 B30613 PDR ADUCK 05000400 E PDR

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

.

Splan in and

actual of the start of the star

- / ^{*} ^{*} ^{*}



SHEARON HARRIS NUCLEAR POWER PLANT DRAFT SER ITEM NO. 117 (FSAR SECTION 9.5.5., NRC QUESTION 430.35)

Consideration of cooling water leakage with respect to NRC Question 430.35 response.

NRC Clarification of SER Item No. 117

The conclusion in the response to NRC question 430.35 requires additional information. Did the evaluation consider floor drain removal of cooling water or were there facility design features provided to separate the diesel generators from flooding effects?

Response

The Emergency Diesel Generator Building cooling water flooding analysis did not take credit for removal of leaking cooling water by the building's floor drain system. Facility design features provide for the effects of potential flooding and the unaffected diesel generator area will not be affected by the leaking cooling water. Diesel generator building room arrangements, as shown on Figures 1.2.2-86, and 1.2.2-87, preclude large water inventory buildup in the building, and prevent flooding in one diesel generator area from impacting on other diesel generator areas.

As described in FSAR Section 9.5.5.3 the sumps in the diesel generator areas are provided with level switches for sump pump start-up. Pump actuation is annunciated in the control room. The sump pump annunciation will alert the operators to possible leaking fluid and potential flooding. Additionally, as shown on Figure 9.5.5-2, Amendment No. 5, the sump drain piping is valved and physically arranged so as to preclude the effects of flooding in one diesel generator area from affecting the other areas.

Therefore, the impact of flooding from postulated breaks in moderate energy fluid systems has been considered in system and facility design and has been determined by analysis to have no adverse effects on diesel generator areas where the postulated break did not occur. e e transfer and the second second

the matrix board of the state of the second se

ς.

.

.