

CP&L

Carolina Power & Light Company

P.O. Box 101, New Hill, NC 27562
February 8, 1985

33 FEB 11 AIO: 44

Dr. J. Nelson Grace
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 2900)
Atlanta, Georgia 30323

NRC-321

Dear Dr. Grace:

A

In our October 31, 1984 response to RII: GFM/RLP 50-400/84-31-01, we informed you of the actions taken and planned to resolve the referenced violation concerning the use of Scotch 33 tape in safety-related applications without adequate engineering review for environmental qualification. At the time of our response, it was projected that corrective actions would be completed by January 15, 1985.

In our January 15, 1985 letter, we informed you that via Field Change Request (FCR-E-2712 Rev. 4) the Harris Plant Engineering Section had identified the Containment and Main Steam Tunnel for which Scotch 33 tape, previously used in safety-related cable applications, must be removed and that efforts to remove the tape from these applications had been completed. We also stated that we were in the verification process to check completeness of the work.

This letter is to inform you that we have completed our verification check. On this basis, we consider the item to be resolved.

Thank you for your consideration in this matter.

Yours very truly,



R. M. Parsons
Project General Manager
Completion Assurance
Shearon Harris Nuclear Power Plant

RMP/dah

cc: Messrs. G. Maxwell/R. Prevatte (NRC-SHNPP)
Mr. B. C. Buckley (NRC)

8507170570 850208
PDR ADDCK 05000400
Q PDR

rt-4/1

1/0
IE01

SECRET

of active

SECRET

SECRET

SECRET