

REGULAR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707310050 DOC. DATE: 87/07/27 NOTARIZED: NO DOCKET #
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 AUTH. NAME AUTHOR AFFILIATION
 WATSON, R. A. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards rept containing brief description of change to Initial Test Program procedures & FSAR. Brief summary of safety evaluation showing that change to procedures does not require change to Tech Specs also encl.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES: Application for permit renewal filed. 05000400

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-1 LA		1	0		PD2-1 PD		5	5
	BUCKLEY, B		1	1					
INTERNAL:	ACRS		6	6		ARM/DAF/LFMB		1	0
	NRR/DEST/ADE		1	1		NRR/DEST/ADS		1	1
	NRR/DEST/CEB		1	1		NRR/DOEA/TSB		1	1
	NRR/RMAS/ILRB		1	1		OGC/HDS1		1	0
	<u>REG FILE</u> 01		1	1		RES/DE/EIB		1	1
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR		1	1
	NRC PDR		1	1		NSIC		1	1

MEMORANDUM FOR THE DIRECTOR, FBI
SUBJECT: [Illegible]
[Illegible text]

1. [Illegible]
2. [Illegible]

RECOMMENDATION: [Illegible]
ACTION: [Illegible]



Carolina Power & Light Company

HARRIS NUCLEAR PROJECT
P. O. Box 165
New Hill, North Carolina 27562

JUL 27 1987

File Number: SHF/10-13510C
Letter Number: HO-870471 (0)

U. S. Nuclear Regulatory Commission
Washington, DC 20555
ATTN: NRC Document Control Desk

SHEARON HARRIS NUCLEAR POWER PLANT UNIT 1
DOCKET NO. 50-400
LICENSE NO. NPF-63
REPORT IN ACCORDANCE WITH 10CFR50.59

Gentlemen:

In accordance with Title 10 to the Code of Federal Regulations, Part 50.59, the enclosed report is submitted. This report fulfills the requirement for a written report within thirty (30) days of a change to the Initial Test Program described in Section 14 of the FSAR as required by license condition 2.C.4.

The attached report contains a brief description of a change to procedures and the FSAR. The attachment also contains a brief summary of the safety evaluation which shows that the change does not involve an unreviewed safety question or require a change to Technical Specifications.

Very truly yours,

R. A. Watson
Vice President
Harris Nuclear Project

8707310050 870727
PDR ADOCK 05000400
P PDR

ONH/dd1

Enclosure

cc: Dr. J. N. Grace (NRC-RII)
Mr. G. Maxwell (NRC-SHNPP)
Mr. B. Buckley (NRR)

MEM/HO-8704710/Page 1/OS1

Accl 11

CHANGE TO PROCEDURES DESCRIBED IN FSAR

Titles: 1-7045-P-02, Volume Reduction
1-7045-P-05, Dry Products Storage and Transfer

Description: The purpose of these procedures, under the Start-Up Program, is to test portions of the Solid Waste Processing System prior to use of those portions of the system.

As discussed in CP&L letter dated June 19, 1987, Letter No. HO-870444(O), the start-up program was closed out and declared complete as of July 1, 1987. The responsibility for completion of the above two tests has been shifted from Start-Up to the System Engineers in the Technical Support Unit. The procedures will be revised to reflect this change.

Safety Summary: The substance of these tests is not being changed, only the responsibility for conduct. As a result, the change does not increase the probability or consequences of analyzed accidents, nor introduce a different type of accident or equipment malfunction than already evaluated in the FSAR. Thus no unreviewed safety question exists.