

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8806140269    DOC. DATE: 88/06/06    NOTARIZED: NO    DOCKET #  
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina    05000400  
 AUTH. NAME    AUTHOR AFFILIATION  
 LOFLIN, L.I.    Carolina Power & Light Co.  
 RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Provides revised relief requests for inservice testing program.

DISTRIBUTION CODE: A047D    COPIES RECEIVED: LTR 1 ENCL 1    SIZE: 3  
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES: Application for permit renewal filed. 05000400

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD2-1 LA	1	0		
	BUCKLEY, B	1	1		
INTERNAL:	ACRS	10	10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1	1	ARM/DAF/LFMB	1 0
	NRR/DEST/MEB 9H	1	1	NRR/DEST/MTB 9H	1 1
	NUDOCS-ABSTRACT	1	1	OGC 15-B-18	1 0
	<u>REG FILE</u> 01	1	1	RES/DE/EIB	1 1
EXTERNAL:	EG&G ROCKHOLD, H	1	1	LPDR	1 1
	NL 007 HEMMING	1	1	NRC PDR	1 1
	NSIC	1	1		

R  
I  
D  
S  
/  
A  
D  
D  
S

TOTAL NUMBER OF COPIES REQUIRED: LTR 31 ENCL 28



Carolina Power & Light Company

JUN 6 1988

SERIAL: NLS-88-134  
10CFR50.55a

United States Nuclear Regulatory Commission  
ATTENTION: Document Control Desk  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400/LICENSE NO. NPF-63  
IN-SERVICE PUMP AND VALVE TESTING PROGRAM

Gentlemen:

Carolina Power & Light Company (CP&L) hereby submits for your review revised relief requests for the Shearon Harris Nuclear Power Plant In-service Testing (IST) Program. The original relief request submitted for Auxiliary Feedwater discharge check valves was denied by NRC safety evaluation (SE) dated April 27, 1988 on the basis that the proposed testing did not provide reasonable assurance of individual valve closure.

The revised relief requests identify the proposed alternative method of testing as discussed with the NRC staff and its contractor on May 19, 1988. Your review and approval of the revised requests is requested by September 1, 1988 to support Cycle 2 operations.

CP&L has reviewed the SE and agrees with the evaluations and conclusions contained in the Technical Evaluation Report (TER) with one exception. Appendix C, item 1, last sentence suggests that the licensee make modifications to the program and submit them to the NRC for review. We agree with program modifications where compliance to requirements is impractical, but disagree that they need to be submitted to the NRC unless they involve denied relief. Resolution of the outstanding relief requests will complete the initial licensing process for the first ten-year interval of the IST program. The conclusion of the SE and Table 1 support this position.

If you have any questions on this subject, please contact Mr. D. B. Bates at (919) 836-6154.

Yours very truly,

L.A. Loflin  
Manager

Nuclear Licensing Section

DBB/dml (5421JDK)

cc: Mr. B. C. Buckley  
Dr. J. Nelson Grace  
Mr. G. F. Maxwell

A047  
||

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

8806140269 880606  
PDR ADCK 05000400  
P DCD

VALVE  
RELIEF REQUEST

RV-2

System:	Auxiliary Feedwater
Valve:	IAF-117
Category:	C
Class:	3
Function:	IC-SAB Discharge Check Valve
Test Requirements:	Verify reverse flow closure.
Basis for Relief:	The system has no design provision for verification of reverse flow closure. The only possible test method involves pressurizing the downstream section of pipe and monitoring an upstream tap for evidence of gross leakage. This method involves filling and draining large segments of the system. Because of the time involved, ALARA consideration, and large amounts of wastes, it is not practical to perform testing except at refueling. The only other alternative testing is to disassemble and visually inspect the valve.
Alternate Testing:	IAF-117 will be disassembled and visually inspected at each refueling to assure full closed position.

Handwritten marks and scribbles in the top right corner.

Faint, illegible text or markings in the middle left section.

Faint, illegible text or markings in the lower middle section.

Faint, illegible text or markings in the bottom left corner.

VALVE  
RELIEF REQUEST

RV-3

**System:** Auxiliary Feedwater

**Valve:** IAF-201, 202, 203  
204, 205, 206

**Category:** C

**Class:** 3

**Function:** Auxiliary Feedwater Pump Discharge Line to Feedwater Line Check Valves.

**Test Requirement:** Verify reverse flow closure.

**Basis for Relief:** The system has no design provision for verification of reverse flow closure. The only possible test method involves pressurizing the downstream section of pipe and monitoring on upstream tap for evidence of gross leakage. This method involves filling and draining large segments of the system. Because of the time involved, ALARA consideration, and large amounts of wastes, it is not practical to perform testing except at refueling. The only other alternative testing is to disassemble and visually inspect each valve.

**Alternate Testing:** During normal plant operation, the Valves IAF-201, 202, 203, 204, 205, and 206 will be verified to be in the closed position through the continual monitoring of installed temperature elements. Unacceptable conditions require action in accordance with Plant Operating Procedures. In addition, one valve off of the Motor-Driven Train and one valve off Turbine-Driven Train will be disassembled and inspected at each refueling, and alternate valves will be done during subsequent refuelings. Failure to pass inspection will initiate disassembly and inspection of the other valves on the same train.

