

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8811040167 DOC.DATE: 88/10/27 NOTARIZED: YES DOCKET #
 FACIL:50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 AUTH.NAME AUTHOR AFFILIATION
 MCDUFFIE,M.A. Carolina Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC Bulletin 88-002, "Rapidly Propagating Fatigue Cracks in Steam Generator Tubes."

DISTRIBUTION CODE: IE13D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 2
 TITLE: Bulletin Response, 88-02.Rapidly Propagating Fatigue Cracks in Steam

NOTES:Application for permit renewal filed.

05000400

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 LA	1 0	PD2-1 PD	1 1
	BUCKLEY, B	1 1		
INTERNAL:	AEOD/DSP/TPAB	1 1	NRR MURPHY, E	1 1
	NRR NEIGHBORS, D	1 1	NRR/DEST/ADE8H3	1 1
	NRR/DEST/ADS 7E	1 1	NRR/DEST/MEB 9H	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DOEA/GCB 11	1 1
	NRR/DREP/EPB10A	1 1	NRR/PMAS/ILRB12	1 1
	NUDOCS-ABSTRACT	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RGN2 FILE 01	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 19



Carolina Power & Light Company

OCT 27 1988

SERIAL: NLS-88-255
10CFR50.

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
RESPONSE TO NRC BULLETIN NO. 88-02

Gentlemen:

Carolina Power & Light Company (CP&L) hereby submits additional information in response to NRC Bulletin No. 88-02, "Rapidly Propagating Fatigue Cracks in Steam Generator Tubes," for the Shearon Harris Nuclear Power Plant (SHNPP). NRC Bulletin 88-02 requested that holders of operating licenses for Westinghouse designed nuclear power reactors with steam generators having carbon steel support plates review steam generator inspection data for evidence of denting of the uppermost support plate. By letter dated March 24, 1988, CP&L submitted its initial response to this Bulletin, which committed to complete an inspection of at least 3% of the steam generator U-tubes at the uppermost support plate. These inspections were completed on September 12, 1988, during the scheduled refueling outage.

The following number of tubes were inspected in each steam generator:

<u>Steam Generator No.</u>	<u>No. of Tubes Inspected</u>	<u>%</u>
1A-SN	939	20
1B-SN	928	20
1C-SN	926	20

The inspections indicated no evidence of tube denting at the uppermost support plate, and no evidence of excessive magnetite in the tube-to-support plate crevices.

Since the inspection did not indicate a problem at SHNPP, interim controls implemented as required by the Bulletin 88-02 could be discontinued. Carolina Power & Light Company intends to maintain these controls as a prudent measure to detect and respond to primary to secondary leakage. However, these are considered voluntary measures which can be discontinued or modified without prior notice to the NRC, unless future inspections reveal denting problems in the uppermost support plate region.

As required by Bulletin Item B, CP&L hereby commits to review the results of future steam generator tube inspections for evidence of denting at the uppermost support plate. If denting is found in the future, a program to satisfy the provisions of Bulletin Item C will be implemented.

8811040167 881027
PDR ADOCK 05000400
Q PDC

411 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

IE13
1/0

No further action is required by NRC Bulletin 88-02, and CP&L considers this item closed for SHNPP.

Yours very truly,

M. A. McDuffie

M. A. McDuffie
Senior Vice President
Nuclear Generation

MAM/JHE/lah (5479JHE)

cc: Mr. W. H. Bradford
Mr. B. C. Buckley
Mr. Malcolm L. Ernst (Acting Regional Administrator)

M. A. McDuffie, having been first duly sworn, did depose and say that the information contained herein is true and correct to the best of his information, knowledge and belief; and the sources of his information are officers, employees, contractors, and agents of Carolina Power & Light Company.

My commission expires: 11/27/89

Ruby R. Morgan
Notary (Seal)

