

ENCLOSURE 1

NOTICE OF VIOLATION

Carolina Power and Light Company
Shearon Harris Unit 1

Docket No. 50-400
License No. NPF-63

During the Nuclear Regulatory Commission (NRC) inspection conducted on October 7 - November 17, 1989, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1989), the violation is listed below:

Technical Specification 6.8.1.a requires that written procedures be established and implemented covering procedures outlined in Appendix A of Regulatory Guide 1.33, Revision 2, February 1978.

Regulatory Guide 1.33, Appendix A, paragraph 8.B.1.A requires that written procedures be provided for containment leak-rate tests.

Engineering Surveillance Test EST-212, Type C Local Leak Rate Test, provides the steps necessary to perform local leak rate testing under normal operating conditions.

Contrary to the above, EST-212 was inadequate, in that it did not provide the necessary procedural steps or precautions to ensure the satisfactory completion of this test during abnormal plant conditions, which resulted in the injection of borated/contaminated water into the plant instrument air system.

Pursuant to the provisions of 10 CFR 2.201, Carolina Power and Light Company is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, Harris, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include: (1) admission or denial of the violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved. Where good cause is shown, consideration will be




Carolina Power and Light Company
Shearon Harris Unit 1

2

Docket No. 50-400
License No. NPF-63

given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION


David M. Verrelli, Chief
Reactor Projects Branch 1
Division of Reactor Projects

Dated at Atlanta, Georgia
this 8th day of December 1989