

August 30, 1990

Docket No. 50-400

Mr. Lynn W. Eury  
Executive Vice President  
Power Supply  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

Dear Mr. Eury:

SUBJECT: INTEGRATED LEAK RATE TESTING SCHEDULE - SHEARON HARRIS  
NUCLEAR POWER PLANT, UNIT 1 (TAC NO. 77489)

By letter dated January 25, 1990, Carolina Power & Light Company (CP&L) submitted the results of the integrated leak rate tests (ILRT) performed during October 1989 at your Shearon Harris Nuclear Power Plant, Unit 1 (Harris). Since the first ILRT did not meet the acceptance criteria for leakage, after repairs a second test was performed which successfully met the acceptance criteria.

10 CFR Part 50, Appendix J, Section III.A.6, requires you to submit your proposed testing schedule for Commission approval when one ILRT is failed. In your January 25, 1990, letter you proposed a continuation of the normal 40 plus or minus 10 months interval. We have reviewed your proposal to continue the normal testing schedule of 40 plus or minus 10 months interval at Harris for ILRT. Since your first ILRT failure in the 1989 sequence represented no gross abnormality and was readily corrected, we find continuing the normal 40 plus or minus 10 months interval is acceptable.

Sincerely,

Original signed by:

Steve Hoffman for:  
Richard A. Becker, Project Manager  
Project Directorate II-1  
Division of Reactor Projects-I/II  
Office of Nuclear Reactor Regulation

cc: See next page

*m/a-4*

OFC	:LA:PD21:PDII-1	:PM:PD21:PDII-1:SPLB	:D:PD21:PDII-1	:	:
NAME	:PAnderson	:RBecker	:CMcCracken	:EAdensam	:
DATE	:8/27/90	:8/27/90	:8/27/90	:8/30/90	:

OFFICIAL RECORD COPY  
Document Name: MR. EURY SHARRIS

9009050004 900830  
PDR ADOCK 05000400  
P PDC

*LF01  
110*



Mr. L. W. Eury  
Carolina Power & Light Company

Shearon Harris

cc:

Mr. R. E. Jones, General Counsel  
Carolina Power & Light Company  
P. O. Box 1551  
Raleigh, North Carolina 27602

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta Street  
Suite 2900  
Atlanta, Georgia 30323

Resident Inspector/Harris NPS  
c/o U. S. Nuclear Regulatory Commission  
Route 1, Box 315B  
New Hill, North Carolina 27562

Mr. C. S. Hinnant  
Plant General Manager  
Harris Nuclear Plant  
P. O. Box 165  
New Hill, North Carolina 27562

Mr. R. B. Richey, Manager  
Harris Nuclear Project  
Harris Nuclear Plant  
P. O. Box 165  
New Hill, North Carolina 27562

Mr. Dayne H. Brown, Director  
Division of Radiation Protection  
N. C. Department of Environmental,  
Commerce & Natural Resources  
P. O. Box 27687  
Raleigh, North Carolina 27611-7687

Mr. H. A. Cole  
Special Deputy Attorney General  
State of North Carolina  
P. O. Box 629  
Raleigh, North Carolina 27602

DISTRIBUTION

~~Docket-File~~

NRC PDR

Local PDR

S. Varga 14-E-4

G. Lainas 14-H-3

E. Adensam 14-B-20

L. Reyes RII

P. Anderson 14-B-20

R. Becker 14-B-20

C. McCracken

OGC (For inform. Only) 15-B-18

E. Jordan MNBB-3302

ACRS (10) P-315

Shearon Harris Plant File

100-100000

RECEIVED  
FEB 10 1964

TO: DIRECTOR, FBI  
FROM: SAC, NEW YORK  
SUBJECT: [Illegible]

[Illegible body text]