Official

MAR 2 7 1991

Docket No. 50-400
License No. NPF-63

Carolina Power and Light Company
ATTN: Mr. Lynn W. Eury
Executive Vice President
Power Supply
P. O. Box 1551
Raleigh, NC 27602

Gentlemen:

SUBJECT: NOTICE OF VIOLATION AND NOTICE OF DEVIATION
(NRC INSPECTION REPORT NO. 50-400/91-03)

This refers to the inspection conducted by D. A. Seymour of this office on February 25 - March 1, 1991. The inspection included a review of activities authorized for your Harris facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Based on the results of this inspection, certain of your activities appeared to be in violation of NRC requirements and other activities appeared to deviate from commitments to the NRC, as specified in the enclosed Notice of Violation and Notice of Deviation. We are concerned about the violation and deviation because adequate procedures and training are fundamental to ensure that the Post Accident Sampling System will provide substantial information important to the efforts to assess and control the course of an accident.

You are required to respond to this letter and should follow the instructions specified in the enclosed Notices when preparing your response. In your response, you should document the specific actions taken and any additional actions you plan to prevent recurrence. After reviewing your response to this Notice, including your proposed corrective actions and the results of future inspections, the NRC will determine whether further NRC enforcement action is necessary to ensure compliance with NRC regulatory requirements.

In accordance with 10 CFR 2.790(a), a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

9105290095 910327
PDR ADOCK 05000400
Q PDR

IE06

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY
DOUGLAS M. COLLINS

Douglas M. Collins, Chief
Radiological Protection and
Emergency Preparedness Branch
Division of Radiation Safety
and Safeguards

Enclosures:
1. Notice of Violation
2. Notice of Deviation
3. NRC Inspection Report

cc w/encls:
R. B. Richey, Vice President
Harris Nuclear Project
Box 165
New Hill, NC 27562

C. S. Hinnant
General Manager
Harris Nuclear Plant
Box 165
New Hill, NC 27562

C. S. Olexik, Jr., Manager
Regulatory Compliance
Harris Nuclear Project
P. O. Box 165
New Hill, NC 27562

Richard E. Jones
General Counsel
Carolina Power & Light Company
P. O. Box 1551
Raleigh, NC 27602

Dayne H. Brown, Director
Division of Radiation Protection
N. C. Department of Environment,
Health & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

bcc w/encls:
Document Control Desk
H. Christensen, RII
R. Becker, NRR

NRC Resident Inspector
U.S. Nuclear Regulatory Commission
Route 1, Box 315B
New Hill, NC 27562

RII:DRSS	RII:DRSS	RII:DRP	
DSeymour	TDecker	HChristensen	G Jenkins
3/27/91	3/27/91	3/27/91	3/27