

CAROLINA POWER & LIGHT COMPANY

SHEARON HARRIS NUCLEAR POWER PLANT

PROCESS INSTRUMENTATION CONTROL SCALING CALCULATIONS

CALCULATION TYPE: NUCLEAR STEAM SUPPLY SYSTEM (NSSS)

CALCULATION NUMBER: SC-N-061

TITLE: RCS WIDE RANGE PRESSURE LOOP 1 P-403

REVISION 4

PREPARED BY	TITLE	<u>Engineer</u>	DATE	<u>10/2/92</u>
REVIEWED BY	TITLE	<u>System Eng</u>	DATE	<u>10/5/92</u>
APPROVED BY	TITLE	<u>Manager - Elect/ITC</u>	DATE	<u>10/5/92</u>

9210280216 921012
PDR ADOCK 05000400
PDR

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 PURPOSE	3
2.0 REFERENCES	3
3.0 GENERAL SCALING CALCULATIONS AND REVISION COMMENTS	3
4.0 SPECIFIC SCALING CALCULATIONS	4
4.1 PT-01RC-0403-IVW	4
4.2 PQY-403	6
4.3 PY-403	6
4.4 PY-403A	7
4.5 PY-403B	7
4.6 PI-01RC-0403-.1SBW	8
4.7 PI-01RC-0403-.2SB	8
4.8 PR-01RC-0402-SW	9
4.9 PS-01RC-0403-AW	10
4.10 PS-01RC-0403-B	11
5.0 ATTACHMENTS	None

1.0 PURPOSE

This document provides the Scaling necessary to calibrate the containment RCS Wide Range Pressure loop P-403, which includes inputs to the Main Control Board (MCB), Auxiliary Control Panel (ACP), and the Solid State Protection System (SSPS).

2.0 REFERENCES

1. MOD-110
2. MST-10081
3. NSSS EQUIPMENT REFERENCE MANUAL (VM-PYC)
4. NSSS BLOCK DIAGRAMS 1364-1328 SH 29
5. PL&S pg 49 (1364-53872, SH 56)
6. CAR-2166-B-432
7. CAR-2166-B-508
8. CAR-2166-S-3015
9. FCR-I-2229
- 10.. TECH SPEC pg 3/4 5-5, 3/4 3-65, 3/4 3-70
11. IS/1-RC-489
12. CAR-2166-G-452
13. CAR-2166-B-431 SH L-74
14. FSAR pg 5.4.7-4, 5.4.7-8, 5.4.7-13, 5.4.7-14, 7.4.1-12, 7.4.1-13, 7.6.1-1
15. CWD CAR-2166-B-401 SH's 325 thru 328
16. IR-85-1066
17. SC-N-178, SC-N-179
18. 1364-46577 SH 8
19. VM-PUK WESTINGHOUSE RECORDERS
20. VM-BFL TOBAR TRANSMITTERS
21. Calculation HNP-I/INST-1044
22. PCR-2898
23. PCR-6547

3.0 GENERAL SCALING CALCULATIONS AND REVISION COMMENTS

- 3.1 TOLERANCE - Most process cards are assigned a tolerance of $\pm 0.50\%$ or ± 0.050 VDC. This is obtained by $\pm 0.50\% \cdot 10$ VDC = ± 0.050 VDC. Computer points are $\pm 0.75\%$ of the span. All indicators and recorders are $\pm 2.0\%$ of the span.
- 3.2 Revision 5 incorporates PCR-6547. PCR-6547 adds a bistable for the CSIP Alternate Miniflow Permissive.

4.0 SPECIFIC SCALING CALCULATIONS

4.1 PT-01RC-0403-IVW

Description: Pressure Transmitter
Location: A1-R45B
Model: Tobar 32PA2

Known:

1. Input: 0.0 to 3000.0 PSIG.
2. Output: 4.0 to 20.0 mA (1.0 to 5.0 VDC @ input to NLP)
3. The following drawings were used to determine that the transmitter taps into the Reactor Coolant Hot Leg at elevation 252'-6 $\frac{1}{2}$ "; IS/1-RC-489, CAR-2166-G-452, CAR-2166-B-431 Sheet L-74 and CAR-2166-B-431 Sheet L-78. The transmitter is mounted in rack A1-R45B, which is located on elevation 236'. Field measurements place the centerline of the transmitter 5'9" from the floor.
4. Per ASME Steam Tables, the specific volume of water at 90.0°F is 0.016099 FT³/LB.

Determine the transmitter head correction by→

1. Determine the distance between the centerline of the transmitter and the centerline of where the transmitter impulse line taps into the Reactor Coolant System by →

$$\begin{array}{r} 252.0' + 6.25" \quad = 252.5208' \\ -236.0' + 5.0' + 9" \quad = 241.7500' \\ \hline \quad \quad \quad = 10.7708' \end{array}$$

2. Convert the 10.7708' into PSI by→

$$(0.016099 \text{ FT}^3/\text{LB})^{-1} \cdot (10.7708') / (144.0 \text{ IN}^2/\text{FT}^2) = 4.646 \text{ PSI}$$

NOTE: It is assumed the transmitter impulse line is at 90.0°F for the above calculation.

3. For calibration purposes the head corrections will be 4.6 PSIG.

4.1 PT-01RC-0403-IVW (continued)

Determine any 1-5 VDC output from any PSIG input to transmitter by →

$$(1-5 \text{ VDC Output}) = [(\text{PSIG Input}) - (4.6 \text{ PSIG})] \cdot (4 \text{ VDC}) / (3000 \text{ PSIG}) + 1 \text{ VDC}$$

Tolerance = ±0.50% = ±0.02 VDC

Percent of Input	RCS Pressure Represented PSIG	Input Pressure to Transmitter PSIG	Output @ NCT2 TPI CAB 04-0824 VDC (mA)
0.18%	5.4	10.0	1.007 (4.028)
24.85%	745.4	750.0	1.994 (7.976)
49.85%	1495.4	1500.0	2.994 (11.976)
74.85%	2245.4	2250.0	3.994 (15.976)
99.85%	2995.4	3000.0	4.994 (19.976)

4.2 PQY-403

Description: Loop Power Supply (Isolated & Non-Isolated)
Location: CAB 04-0241
Model: Westinghouse NLP2

Known:

1. INPUT: 1.0 to 5.0 VDC
2. OUTPUT: 0.0 to 10.0 VDC

Determine any 0-10 VDC output from any 1-5 VDC input by →

$$(0-10 \text{ VDC Output}) = [(1-5 \text{ VDC Input}) - 1] \cdot (10 \text{ VDC}) / (4 \text{ VDC})$$

$$\text{Tolerance} = \pm 0.50\% = \pm 0.05 \text{ VDC}$$

- Note:
1. See Section 4.5 for data table.
 2. Both Isolated and Non-Isolated outputs must be tested.

4.3 PY-403

Description: Isolator
Location: CAB 04-0242
Model: Westinghouse NLP3

Known:

1. INPUT: 0.0 to 10.0 or 1.0 to 5.0 VDC from input of PQY-403
2. OUTPUT: 0.00 to 10.00 VDC

Determine any 0-10 VDC output from any 1-5 VDC input by →

$$(0-10 \text{ VDC Output}) = [(1-5 \text{ VDC Input}) - 1] \cdot (10 \text{ VDC}) / (4 \text{ VDC})$$

$$\text{Tolerance} = \pm 0.50\% = \pm 0.05 \text{ VDC}$$

Note: See Section 4.5 for data table.

4.4 PY-403A

Description: Isolator
Location: CAB 04-0253
Model: Westinghouse NLP3

Known:

1. INPUT: 0.0 to 10.0 or 1.0 to 5.0 VDC from input of PQY-403
2. OUTPUT: 0.0 to 10.0 VDC

Determine any 0→10 VDC output from any 1→5 VDC input by →

$$(0 \rightarrow 10 \text{ VDC Output}) = [(1 \rightarrow 5 \text{ VDC Input}) - 1] \cdot (10 \text{ VDC}) / (4 \text{ VDC})$$

$$\text{Tolerance} = \pm 0.50\% = \pm 0.05 \text{ VDC}$$

Note: See Section 4.5 for data table.

4.5 PY-403B

Description: Isolator
Location: CAB 04-0254
Model: Westinghouse NLP3

Known:

1. INPUT: 0.0 to 10.0 or 1.0 to 5.0 VDC from input of PQY-403
2. OUTPUT: 0.00 to 10.00 VDC

Determine any 0→10 VDC output from any 1→5 VDC input by →

$$(0 \rightarrow 10 \text{ VDC Output}) = [(1 \rightarrow 5 \text{ VDC Input}) - 1] \cdot (10 \text{ VDC}) / (4 \text{ VDC})$$

$$\text{Tolerance} = \pm 0.50\% = \pm 0.05 \text{ VDC}$$

Percent of Input	Input @ TJ @ CAB 04-0824 1→5 VDC	Output PQY-403 0→10 VDC	Output PY-403 0→10 VDC	Output PY-403A 0→10 VDC	Output PT-403B 0→10 VDC
0%	1.000	0.000	0.000	0.000	0.000
25%	2.000	2.500	2.500	2.500	2.500
50%	3.000	5.000	5.000	5.000	5.000
75%	4.000	7.500	7.500	7.500	7.500
100%	5.000	10.000	10.000	10.000	10.000

Note: 1. Both Isolated and Non-Isolated outputs of PQY-403 must be tested.

4.6 PI-01RC-0403-.1SBW

Description: Pressure Indicator
Location: MCB 1A2
Model: Westinghouse VX-252

Known:

1. INPUT: 0.0 to 10.0 VDC or 1.0 to 5.0 VDC from input of PQY-403
2. OUTPUT: 0.0 to 3000.0 PSIG

Determine any 0-3000 PSIG output from any 1-5 VDC input by →

$$(0-3000 \text{ PSIG Output}) = [(1-5 \text{ VDC Input}) - 1] \cdot (3000 \text{ PSIG}) / (4 \text{ VDC})$$

Tolerance - ±2.00% - ±60 PSIG

Note: See Section 4.7 for data table.

4.7 PI-01RC-0403-.2SB

Description: Pressure Indicator
Location: ACP II
Model: Westinghouse VX-252

Known:

1. INPUT: 0.0 to 10.0 VDC or 1.0 to 5.0 VDC from input of PQY-403
2. OUTPUT: 0.0 to 3000.0 PSIG

Determine any 0-3000 PSIG output from any 1-5 VDC input by →

$$(0-3000 \text{ PSIG Output}) = [(1-5 \text{ VDC Input}) - 1] \cdot (3000 \text{ PSIG}) / (4 \text{ VDC})$$

Tolerance - ±2.00% - ±60 PSIG

Percent of Input	Input @ TJ @ CAB 04-0824 1-5 VDC	Output PI-01RC-0403-.1SBW PSIG	Output PI-01RC-0403-.2SB PSIG
0%	1.000	0.0	0.0
25%	2.000	750.0	750.0
50%	3.000	1500.0	1500.0
75%	4.000	2250.0	2250.0
100%	5.000	3000.0	3000.0

4.8 PR-01RC-0402-SW

Description: Pressure Recorder, Pen 2
Location: Recorder Panel
Model: Hagan 17450

Known:

1. INPUT: 0.0 to 10.0 VDC or 1.0 to 5.0 VDC from input of PQY-403
2. OUTPUT: 0.0 to 3000.0 PSIG

Determine any 0-3000 PSIG output from any 1-5 VDC input by →

$$(0 \rightarrow 3000 \text{ PSIG Output}) = [(1 \rightarrow 5 \text{ VDC Input}) - 1] \cdot (3000 \text{ PSIG}) / (4 \text{ VDC})$$

Tolerance = ±2.00% = ±60 PSIG

Percent of Input	Input @ TJ @ CAB 04-0824 1-5 VDC	Output, Pen 2 PR-01RC-0402-SW PSIG
0%	1.000	0.0
25%	2.000	750.0
50%	3.000	1500.0
75%	4.000	2250.0
100%	5.000	3000.0

4.9 PS-01RC-0402-AW

Description: Dual Comparator

Output 1: Open Permissive for RHR valves 1RH-1 & 1RH-39

Output 2: RGS High Pres Alarm for RHR valves 1RH-1 & 1RH-39

Location: CAB 04-0243

Model: Westinghouse NAL2

Known:

1. Input 1: 0 to 10 VDC or 1.0 to 5.0 VDC from input of PQY-403
Input 2: 0 to 10 VDC or 1.0 to 5.0 VDC from input of PQY-403
2. Output 1: On/Off De-energizes on DECR
Output 2: Off/On Energizes on INCR
3. Setpoint 1: 363.0 PSIG Open Permissive for valve 1RH-2
Reset 1: 393.0 PSIG
4. Setpoint 2: 425.0 PSIG High Pressure Alarm for valve 1RH-2
Reset 2: 410.0 PSIG

Determine any 1-5 VDC input from any PSIG setpoint by →

$$(1-5 \text{ VDC Input}) = [(\text{PSIG Setpoint}) \cdot (4 \text{ VDC}) / (3000 \text{ PSIG})] + 1 \text{ VDC}$$

$$\text{Tolerance 1} = \pm 0.50\% = \pm 0.02 \text{ VDC (1-5 VDC)} = 15 \text{ PSIG}$$

$$\text{Tolerance 2} = \pm 0.25\% = \pm 0.01 \text{ VDC (1-5 VDC)} = 7.5 \text{ PSIG}$$

Setpoint #1 Open Permissive for valves 1RH-1 & 1RH-39		Input @ TJ @ CAB 04-0824 (1-5 VDC)	Actuation #1
Trip	363.0 PSIG	1.484	DECR De-energize
Reset	393.0 PSIG	1.524	INCR Energize

Setpoint #2 High RGS Pressure Alarm for valves 1RH-1 & 1RH-39		Input @ TJ @ CAB 04-0824 (1-5 VDC)	Actuation #2
Trip	425.0 PSIG	1.567	INCR Energize
Reset	410.0 PSIG	1.547	DECR De-energize

4.10 PS-01RC-403-B

Description: Single Comparator, Open/Close Permissive for the Alternate Miniflow MOV 2CS-V759SB1
 Location: CAB 04-0256
 Model: Westinghouse NAL1

Known:

1. Input: 0 to 10 VDC or 1.0 to 5.0 VDC from input of PQY-403
2. Output: Off/On Energizes on INCR
3. Setpoint: 2300 PSIG Open Permissive Alt Miniflow MOV
 Reset: 1750 PSIG Close Permissive Alt Miniflow MOV

Determine any 1-5 VDC input from any PSIG setpoint by →

$$(1-5 \text{ VDC Input}) = [(\text{PSIG Setpoint}) \cdot (4 \text{ VDC}) / (3000 \text{ PSIG})] + 1 \text{ VDC}$$

$$\text{Tolerance} = \pm 0.50\% = \pm 0.02 \text{ VDC (1-5 VDC)} = \pm 15 \text{ PSIG}$$

Setpoint Open/Close Permissive for Alt Miniflow MOV		Input @ TJ @ CAB 04-0824 (1-5 VDC)	Actuation
Trip	2300 PSIG	4.067	INCR Energize
Reset	1750 PSIG	3.333	DECR De-energize

ENCLOSURE 3

FLOW TEST EQUIPMENT ACCURACY