

UNIT SHUTDOWNS AND POWER REDUCTION

UNIT NAME:

Harris

DATE:

01/06/93

COMPLETED BY:

A. P. Crenshaw

TELEPHONE:

(919) 362-2808

REPORT MONTH: December 1992

No.	Date	T ¹ y p e	Duration (Hours)	R ² e a s o n	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code 4	Component Code 5	Cause and Corrective Action to Prevent Recurrence
92-019	921129	S	18.27	C	5	N/A	N/A	N/A	Unit ramping up following the scheduled Cycle 5 Refueling Outage. Initial criticality was achieved on November 29, 1992, and the unit was synchronized to the grid on December 1, 1992, at 1816 hours. During ramping, a turbine overspeed trip test was performed. (See Event #92-020.) The unit reached 100% power on December 7, 1992.

1

F: Forced
S: Scheduled

2

Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3

Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continued
5-Reduced Load
6-Other

4

Exhibit G-Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File
(NUREG-0161)

5

Exhibit 1 -Same Source

UNIT SHUTDOWNS AND POWER REDUCTION

UNIT NAME:
DATE:
COMPLETED BY:
TELEPHONE:

Harris
01/06/93
A. P. Crenshaw
(919) 362-2808

REPORT MONTH: December 1992

No.	Date	Type	Duration (Hours)	Reason	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code 4	Component Code 5	Cause and Corrective Action to Prevent Recurrence
92-020	921203	S	.70	B	6*	N/A	HA	Valve	Unit went off line at 10:31 to perform a scheduled turbine overspeed trip test. The test was satisfactorily performed and the unit was back on line at 11:13 hours.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continued
5-Reduced Load
6-Other

4
Exhibit G-Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File
(NUREG-0161)

5
Exhibit 1 -Same Source

* Manual Turbine Trip

