



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

May 13, 1994

Docket No. 50-400

Mr. W. R. Robinson  
Vice President - Harris Plant  
Carolina Power & Light Company  
Shearon Harris Nuclear Power Plant  
Post Office Box 165 - Mail Code: Zone 1  
New Hill, North Carolina 27562-0165

Dear Mr. Robinson:

SUBJECT: RESPONSE TO GENERIC LETTER (GL) 92-01, REVISION 1, "REACTOR VESSEL STRUCTURAL INTEGRITY," SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 (TAC NO. M83468)

By letter dated July 6, 1992, Carolina Power & Light Company (CP&L) provided its response to GL 92-01, Revision 1, for the Shearon Harris Nuclear Power Plant (SHNPP). The NRC staff has completed its review of your response. Based on their review, the staff has determined that CP&L has provided the information requested in GL 92-01.

The GL is part of the staff's program to evaluate reactor vessel integrity for Pressurized Water Reactors (PWRs) and Boiling Water Reactors (BWRs). The information provided in response to GL 92-01, including previously docketed information, is being used to confirm that licensees satisfy the requirements and commitments necessary to ensure reactor vessel integrity for their facilities.


A substantial amount of information was provided in response to GL 92-01, Revision 1. These data have been entered into a computerized data base designated the Reactor Vessel Integrity Database (RVID). The RVID contains the following tables: A pressurized thermal shock (PTS) table for PWRs, a pressure-temperature limits table for BWRs and an upper-shelf energy (USE) table for PWRs and BWRs. Enclosure 1 provides the PTS table, Enclosure 2 provides the USE table for your SHNPP, and Enclosure 3 provides a key for the nomenclature used in the tables. The tables include the data necessary to perform USE and  $RT_{pts}$  evaluations. These data were taken from your response to GL 92-01 and previously docketed information. References to the specific source of the data are provided in the tables.

We request that you verify that the information that you have provided for the SHNPP has been accurately entered in the summary data files. No response is necessary unless an inconsistency is identified. If no comments are received within 30 days from the day of this letter, the staff will consider your actions related to GL 92-01, Revision 1, to be complete and the staff will use the information in the tables for future NRC assessments of your reactor pressure vessel.

NRC FILE CENTER COPY

160017  
9405180371 940513  
PDR ADOCK 05000400  
P PDR

MAY  
DFOI



May 13, 1994

Mr. W. R. Robinson

- 2 -

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,

Original Signed by:  
Ngoc B. Le, Project Manager  
Project Directorate II-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Pressurized Thermal Shock or Pressure-Temperature Limit Table
2. Upper-Shelf Energy Table
3. Nomenclature Key


cc w/enclosures:  
See next page

DISTRIBUTION

Docket File  
 NRC & Local PDRs  
 PD# II-1 Reading  
 S. Varga  
 G. Lainas  
 W. Bateman  
 P. Anderson  
 N. Le  
 D. McDonald  
 E. Hackett  
 J. Strosnider  
 OGC  
 ACRS (10)  
 E. Merschoff, Region II

OFC	LA:PD21:DRPE	PM:PD21:DRPE	D:PD21:DRPE	
NAME	PAnderson	NLe:jrm	WBateman	
DATE	5/9/94	5/11/94	5/12/94	1/94

OFFICIAL RECORD COPY  
DOCUMENT NAME: G:\HARRIS\HAR83468.LTR




Mr. W. R. Robinson

- 2 -

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,



Ngoc B. Le, Project Manager  
Project Directorate II-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosures:

1. Pressurized Thermal Shock or  
Pressure-Temperature Limit  
Table
2. Upper-Shelf Energy Table
3. Nomenclature Key

cc w/enclosures:  
See next page



Small, faint markings or artifacts in the top right corner of the page.

Mr. W. R. Robinson  
Carolina Power & Light Company

Shearon Harris Nuclear Power Plant  
Unit 1

cc:

Mr. H. Ray Starling  
Manager - Legal Department  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602

Admiral Kinnaird R. McKee  
214 South Morris Street  
Oxford, Maryland 21654

Resident Inspector/Harris NPS  
c/o U.S. Nuclear Regulatory Commission  
5421 Shearon Harris Road  
New Hill, North Carolina 27562-9998

Mr. Robert D. Martin  
3382 Sean Way  
Lawrenceville, Georgia 30244

Karen E. Long  
Assistant Attorney General  
State of North Carolina  
Post Office Box 629  
Raleigh, North Carolina 27602

Public Service Commission  
State of South Carolina  
Post Office Drawer 11649  
Columbia, South Carolina 29211

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
101 Marietta St., N.W. Suite 2900  
Atlanta, Georgia 30323

Mr. W. R. Robinson  
Vice President - Harris Plant  
Carolina Power & Light Company  
Shearon Harris Nuclear Power Plant  
Post Office Box 165, MC: Zone 1  
New Hill, North Carolina 27562-0165

Mr. Dayne H. Brown, Director  
Division of Radiation Protection  
N.C. Department of Environmental  
Commerce & Natural Resources  
Post Office Box 27687  
Raleigh, North Carolina 27611-7687

Mr. H. W. Habermeyer, Jr.  
Vice President  
Nuclear Services Department  
Carolina Power & Light Company  
Post Office Box 1551  
Raleigh, North Carolina 27602



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100




## Summary File for Pressurized Thermal Shock

Plant Name	Beltline Ident.	Heat No. Ident.	ID Neut. Fluence at EOL/EPY	IRT <sub>net</sub>	Method of Determin. IRT <sub>net</sub>	Chemistry Factor	Method of Determin. CF	%Cu	%Ni
Shearon Harris  EOL: 10/24/ 2026	Int. Shell	A9153-1	3.42E19	60°F	Plant Specific	58	Table	0.09	0.45
	Int. Shell	B4197-2	3.42E19	91°F	Plant Specific	38	Calculated	0.10	0.50
	Lower Shell	C-9924-1	3.42E19	54°F	Plant Specific	51	Table	0.08	0.45
	Lower Shell	C-9924-2	3.42E19	57°F	Plant Specific	51	Table	0.08	0.44
	Int. and Lower Axial Welds	484784	1.33E19	-20°F	Plant Specific	82	Table	0.06	0.91
	Circ. Weld	5P6771	3.42E19	-20°F	Plant Specific	54	Table	0.04	0.95

## REFERENCES FOR SHEARON HARRIS:

Fluence, IRT<sub>net</sub> and chemistry data from April 2, 1992 surveillance capsule report, "Analysis of Capsule V."



## Summary File for Upper Shelf Energy

Plant Name	Beltline Ident.	Heat No.	Material Type	1/4T USE at EOL/EFY	1/4T Neutron Fluence at EOL/EFY	Unirrad. USE	Method of Determin. Unirrad. USE
Shearon Harris EOL: 10/24/2026	Int. Shell	A9153-1	A 533B-1	64	2.148E19	83	Direct
	Int. Shell	B4197-2	A 533B-1	64	2.148E19	71	Direct
	Lower Shell	C-9924-1	A 533B-1	76	2.148E19	98	Direct
	Lower Shell	C-9924-2	Linde 124, SAW	68	2.148E19	88	Direct
	Int. and lower Axial Welds	484784	Linde 124, SAW	76	0.835E19	94	Direct
	Circ. Weld	5P6771	Linde 124, SAW	68	2.148E19	88	Surv. Weld
REFERENCES FOR SHEARON HARRIS:							
Fluence, UUSE data from April 2, 1992 surveillance capsule report, "Analysis of Capsule V."							



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

NOMENCLATURE AND TABLESPRESSURIZED THERMAL SHOCK AND USE TABLES FOR ALL PWR PLANTSNOMENCLATURE

## Pressurized Thermal Shock Table

- Column 1: Plant name and date of expiration of license.  
Column 2: Beltline material location identification.  
Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process, (T) indicates tandem wire was used in the SAW process.  
Column 4: End-of-life (EOL) neutron fluence at vessel inner wall; cited directly from inner diameter (ID) value or calculated by using Regulatory Guide (RG) 1.99, Revision 2 neutron fluence attenuation methodology from the quarter thickness (T/4) value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).  
Column 5: Unirradiated reference temperature.  
Column 6: Method of determining unirradiated reference temperature (IRT).

Plant-Specific

This indicates that the IRT was determined from tests on material removed from the same heat of the beltline material.

MTEB 5-2

This indicates that the unirradiated reference temperature was determined from following MTEB 5-2 guidelines for cases where the IRT was not determined using American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, NB-2331, methodology.

Generic

This indicates that the unirradiated reference temperature was determined from the mean value of tests on material of similar types.

- Column 7: Chemistry factor for irradiated reference temperature evaluation.  
Column 8: Method of determining chemistry factor

Table

This indicates that the chemistry factor was determined from the chemistry factor tables in RG 1.99, Revision 2.



Small, faint marks or artifacts in the top right corner of the page.

Calculated

This indicates that the chemistry factor was determined from surveillance data via procedures described in RG 1.99, Revision 2.

Column 9: Copper content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no copper data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Column 10: Nickel content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no nickel data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Upper Shelf Energy Table

- Column 1: Plant name and date of expiration of license.  
Column 2: Beltline material location identification.  
Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process. (T) indicates tandem wire was used in the SAW process.  
Column 4: Material type; plate types include A 533B-1, A 302B, A 302B Mod., and forging A 508-2; weld types include SAW welds using Linde 80, 0091, 124, 1092, ARCOS-B5 flux, Rotterdam welds using Graw Lo, SMIT 89, LW 320, and SAF 89 flux, and SMAW welds using no flux.  
Column 5: EOL upper-shelf energy (USE) at T/4; calculated by using the EOL fluence and either the copper value or the surveillance data. (Both methods are described in RG 1.99, Revision 2.)


EMA

This indicates that the USE issue may be covered by either owners group or plant-specific equivalent margins analyses.

- Column 6: EOL neutron fluence at T/4 from vessel inner wall; cited directly from T/4 value or calculated by using RG 1.99, Revision 2 neutron fluence attenuation methodology from the ID value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).  
Column 7: Unirradiated USE.

EMA

This indicates that the USE issue may be covered by either owners group or plant-specific equivalent margins analyses.





Column 8: Method of determining unirradiated USE

Direct

For plates, this indicates that the unirradiated USE was from a transverse specimen. For welds, this indicates that the unirradiated USE was from test date.

65%

This indicates that the unirradiated USE was 65% of the USE from a longitudinal specimen.

Generic

This indicates that the unirradiated USE was reported by the licensee from other plants with similar materials to the beltline material.

NRC generic

This indicates that the unirradiated USE was derived by the staff from other plants with similar materials to the beltline material.

10, 30, 40, or 50 °F

This indicates that the unirradiated USE was derived from Charpy test conducted at 10, 30, 40, or 50 °F.

Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having the same weld wire heat number.

Equiv. to Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having different weld wire heat number.

Sister Plant

This indicates that the unirradiated USE was derived by using the reported value from other plants with the same weld wire heat number.

Blank

indicates that there is insufficient data to determine the unirradiated USE.

