

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9407210146 DOC. DATE: 94/07/18 NOTARIZED: NO DOCKET #
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 AUTH. NAME AUTHOR AFFILIATION
 ROBINSON, W.R. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC 940603 ltr re violations noted in insp rept
 50-400/94-10. Corrective action: procedure update for full
 system filling & venting will be completed prior to next
 occurrence of fill & vent for that system.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: Application for permit renewal filed. 05000400

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	LE, N	1 1
INTERNAL:	ACRS	2 2	AEOD/DEIB	1 1
	AEOD/DSP/ROAB	1 1	AEOD/DSP/TPAB	1 1
	AEOD/TTC	1 1	DEDRO	1 1
	NRR/DORS/OEAB	1 1	NRR/DRCH/HHFB	1 1
	NRR/PMAS/IRCB-E	1 1	NUDOCS-ABSTRACT	1 1
	OE DIR	1 1	OGC/HDS2	1 1
	REG FILE 02	1 1	RES/HFB	1 1
	RGN2 FILE 01	1 1		
EXTERNAL:	EG&G/BRYCE, J.H.	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL ~~21~~ 0

P
R
I
O
R
I
T
Y

1
D
O
C
U
M
E
N
T





Carolina Power & Light Company
PO Box 165
New Hill NC 27562

William R. Robinson
Vice President
Harris Nuclear Plant

JUL 18 1994

File: HO-940344

Serial: HNP-94-059
10CFR2.201

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
REPLY TO A NOTICE OF VIOLATION - SUPPLEMENT

Gentlemen:

NRC Inspection Report 50-400/94-10 issued a Notice of Violation (NOV) on June 3, 1994, regarding use of proper procedures for filling and venting evolutions. The Shearon Harris Nuclear Power Plant responded to the NOV on July 5, 1994. Based on subsequent followup conversations with the Resident Inspector's Office, the following additional clarification to our violation response is provided:

While our response addressed filling and venting of entire systems, it did not address partial system fill and vent. If a partial system requires filling and venting, the applicable portions of that system's procedure section for fill and vent will apply to the partial system. Furthermore, we are providing additional guidance in OMM-001, "Operations-Conduct of Operations," describing the precautions and limitations for filling and venting. OMM-014, "Operation of the Work Control Center," which prescribes the process and requirements for restoration of systems following work activities, will reference these precautions and limitations. Both OMM-001 and OMM-014 will be revised by July 19, 1994.

The full compliance date was stated as September 1995, without any further discussion on procedure update sequencing. The required procedure updates will be sequenced in a time window which ends in September 1995; additionally, each required procedure update for full system filling and venting will be completed prior to the next occurrence of fill and vent for that system.

83002
9407210146 940718
PDR ADDCK 05000400
PDR

State Road 1134 New Hill NC Tel 919 362-2502 Fax 919 362-6950

1501
1/0

Document Control Desk
HNP-94-053 / Page 2

Questions regarding this matter may be referred to Mr. D. C. McCarthy at (919) 362-2100.

Sincerely,



W. R. Robinson

RWP:sdc

Attachment

c: Mr. S. D. Ebnetter (NRC-RII)
Mr. N. B. Le (NRR)
Mr. J. E. Tedrow (NRC-SHNPP)