

PRIORITY 2

(NUDOCS OFFSITE FACILITY)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9409190002 DOC. DATE: 94/09/08 NOTARIZED: NO DOCKET #
FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
AUTH. NAME AUTHOR AFFILIATION
BOGER, B.A. Region 2 (Post 820201)
RECIP. NAME RECIPIENT AFFILIATION
ROBINSON, W.R. Carolina Power & Light Co.

SUBJECT: Ack receipt of 940824 ltr informing NRC of steps taken to correct violations noted in insp rept 50-400/94-13.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: Application for permit renewal filed. 05000400 (

| | RECIPIENT ID CODE/NAME | COPIES LTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTR ENCL |
|-----------|---------------------------|--------------------|---------------------------|--------------------|
| | PD2-1 PD | 1 | LE,N | 1 |
| INTERNAL: | ACRS | 2 | AEOD/DEIB | 1 |
| | AEOD/SPD/RAB | 1 | AEOD/SPD/RRAB | 1 |
| | AEOD/TTC | 1 | DEDRO | 1 |
| | NRR/DORS/OEAB | 1 | NRR/DRCH/HHFB | 1 |
| | NRR/PMAS/IRCB-E | 1 | NUDOCS-ABSTRACT | 1 |
| | OE DIR | 1 | OGC/HDS2 | 1 |
| | REG-FILE 02 | 1 | RES/HFB | 1 |
| | RGN2 FILE 01 | 1 | | |
| INTERNAL: | EG&G/BRYCE, J.H. | 1 | NOAC | 1 |
| | NRC PDR | 1 | | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 9

SEP -8 1994

Docket No.: 50-400
License No.: NPF-63

Carolina Power & Light Company
ATTN: Mr. W. R. Robinson
Vice President
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Code: Zone 1
New Hill, NC 27562-0165

Gentlemen:

SUBJECT: NRC INSPECTION REPORT NO. 50-400/94-13

This will acknowledge receipt of your response of August 24, 1994, to our Notice of Violation issued on July 25, 1994, concerning activities conducted at your Harris facility.

We have examined your response and found that it meets the requirements of 10 CFR 2.201. In your response, you denied violation A and admitted violation B.

With respect to violation A, we understand your explanation of the sequence of events to use priority-E work to open valve 1SW-20 and concur that a violation of Technical Specification (TS) 6.8.1.a did not occur. The decision by the nuclear shift supervisor to authorize emergency work was based upon a perceived impression that TS 3.0.3 was applicable and that immediate work was required to avoid an unnecessary plant transient. Only after a detailed review of the system design was it subsequently determined that TS 3.0.3 was not applicable. Therefore, we conclude that the shift supervisor's actions were appropriate. As a result of the telephone conversation with Mr. Prunty of your staff on September 6, 1994, we understand that you will provide additional guidance to the shift supervisors to help them in similar situations with TS 3.0.3 applicability. Accordingly, we will adjust our records to reflect that no violation of regulatory requirements occurred with respect to Item A.

We will examine the implementation of your action to correct violation B during future inspections.

100065

9409190002 940908
PDR ADDCK 05000400
Q PDR

1/0
IEO1

SEP -8 1994

Carolina Power & Light Company

2

Thank you for your cooperation in this matter.

Sincerely,



Bruce A. Boger, Acting Director
Division of Reactor Projects

cc: H. W. Habermeyer, Jr.
Vice President
Nuclear Services Department
Carolina Power & Light Company
P. O. Box 1551 - Mail OHS7
Raleigh, NC 27602

J. W. Donahue
Plant Manager - Harris Plant
Carolina Power & Light Company
S. Harris Nuclear Power Plant
P. O. Box 165, MC: Zone 1
New Hill, ,NC 27562-0165

David McCarthy, Manager
Regulatory Affairs
Harris Nuclear Project
P. O. Box 165
New Hill, NC 27562

H. Ray Starling
Vice President - Legal Dept.
Carolina Power and Light Co.
P. O. Box 1551
Raleigh, NC 27602

Dayne H. Brown, Director
Div. of Radiation Protection
N. C. Dept. of Environmental
Commerce & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

Karen E. Long
Assistant Attorney General
State of North Carolina
P. O. Box 629
Raleigh, NC 27602

(cc cont'd - See page 3)

SEP -8 1994

Carolina Power & Light Company

3

(cc cont'd)
Public Service Commission
State of South Carolina
P. O. Box 11649
Columbia, SC 29211

Admiral Kinnaird R. McKee
214 South Morris Street
Oxford, MD 21654

Robert D. Martin
3382 Sean Way
Lawrenceville, GA 30244

Robert P. Grüber
Executive Director
Public Staff NCUC
P. O. Box 29520
Raleigh, NC 27626

bcc: H. Christensen, RII
N. Le, NRR
G. A. Hallstrom, RII
Document Control Desk

NRC Resident Inspector
U. S. Nuclear Regulatory Comm.
5421 Shearon Harris Road
New Hill, NC 27562-9998

| | | | | | | |
|-------|------|---|---|---|--|--|
| SEND | OFC | RII:DRP <i>[Signature]</i> | RII:DRP <i>[Signature]</i> | RII:DRP <i>[Signature]</i> | | |
| TO | NAME | JStarefo <i>[Signature]</i> | JTedrow <i>[Signature]</i> | HChristensen | | |
| DATE | | 09/6/94 | 09/7/94 | 09/7/94 | 1/194 | 1/194 |
| COPY? | | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |

OFFICIAL RECORD COPY

DOCUMENT NAME: P:\HARRIS.WP5

