

SHEARON HARRIS NUCLEAR POWER PLANT
NRC DOCKET NO. 50-400/LICENSE NO. NPF-63
REQUEST FOR LICENSE AMENDMENT
PERFORMANCE OF TECHNICAL SPECIFICATION SURVEILLANCES
SUPPLEMENTAL INFORMATION

TECHNICAL SPECIFICATION PAGES

9503230058 950320
PDR ADOCK 05000400
P PDR

APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25% of the specified surveillance interval.

4.0.3 ~~Failure to perform a Surveillance Requirement within the specified time interval shall constitute a failure to meet the OPERABILITY requirements for a Limiting Condition for Operation. Exceptions to these requirements are stated in the individual specifications.~~ ^{INSERT A} Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation has been performed within the stated surveillance interval or as otherwise specified.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR Part 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR Part 50, Section 50.55a(g)(6)(i);

APPLICABILITY

BASES

3.0.4 (Continued)

The intent of this provision is to ensure that facility operation is not initiated with either required equipment or systems inoperable or other specified limits being exceeded.

Exceptions to this provision have been provided for a limited number of specifications when startup with inoperable equipment would not affect plant safety. These exceptions are stated in the ACTION statements of the appropriate specifications.

4.0.1 This specification provides that surveillance activities necessary to ensure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements. Surveillance Requirements for Special Test Exceptions need only be performed when the Special Test Exception is being utilized as an exception to an individual specification.

4.0.2 The provisions of this specification establish the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18 month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

← INSERT B

4.0.3	The provisions of this specification set forth the criteria for determination of compliance with the OPERABILITY requirements of the Limiting Conditions for Operation. Under these criteria, equipment, systems or components are assumed to be OPERABLE if the associated surveillance activities have been satisfactorily performed within the specified time interval. Nothing in this provision is to be construed as defining equipment, systems or components OPERABLE when such items are found or known to be inoperable although still meeting the Surveillance Requirements. Items may be
-------	--

INSERT B CON'T

determined inoperable during use, during surveillance tests, or in accordance with this specification. Therefore, ACTION statements are entered when the Surveillance Requirements should have been performed rather than at the time it is discovered that the tests were not performed.									
---	--	--	--	--	--	--	--	--	--

4.0.4 This specification ensures that the surveillance activities associated with a Limiting Condition for Operation have been performed within the specified time interval prior to entry into an OPERATIONAL MODE or other applicable condition. The intent of this provision is to ensure that surveillance activities have been satisfactorily demonstrated on a current basis as required to meet the OPERABILITY requirements of the Limiting Condition for Operation.

INSERT A:

If it is discovered that a surveillance was not performed within its specified surveillance interval, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified surveillance interval, whichever is less. This delay period is permitted to allow performance of the surveillance.

If the surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable ACTION requirements must be met.

When the surveillance is performed within the delay period and the surveillance criteria are not met, the LCO must immediately be declared not met, and the applicable ACTION requirements must be met.

INSERT B:

Specification 4.0.3 establishes the flexibility to defer declaring affected equipment inoperable or an affected variable outside the specified limits when a surveillance has not been completed within the specified surveillance interval. A delay period of up to 24 hours or up to the limit of the specified surveillance interval, whichever is less, applies from the point in time that it is discovered that the surveillance has not been performed in accordance with Specification 4.0.2, and not at the time that the specified surveillance interval was not met.

This delay period provides adequate time to complete surveillances that have been missed. This delay period permits the completion of a surveillance before complying with ACTION requirements or other remedial measures that might preclude completion of the surveillance.

The basis for this delay period includes consideration of unit conditions, adequate planning, availability of personnel, the time required to perform the surveillance, the safety significance of the delay in completing the required surveillance, and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the requirements. When a surveillance with a surveillance interval based not on time intervals, but upon specified unit conditions or operational situations, is discovered not to have been performed when specified, Specification 4.0.3 allows the full delay period of 24 hours to perform the surveillance.

Specification 4.0.3 also provides a time limit for completion of surveillances that become applicable as a consequence of MODE changes imposed by ACTION requirements.

Failure to comply with specified surveillance intervals for surveillance requirements is expected to be an infrequent occurrence. Use of the delay period established by Specification 4.0.3 is a flexibility which is not intended to be used as an operational convenience to extend surveillance intervals.

INSERT B (CON'T)

If a surveillance is not completed within the allowed delay period, then the equipment is considered inoperable or the variable is considered outside the specified limits and the time limits of the ACTION requirements for the applicable LCO begin immediately upon expiration of the delay period. If a surveillance is failed within the delay period, then the equipment is inoperable or the variable is outside the specified limits, and the time limits of the ACTION requirements for the applicable LCO begin immediately upon the failure of the surveillance.

Completion of the surveillance within the delay period allowed by this Specification, or within the completion time of the ACTIONS, restores compliance with Specification 4.0.1.

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL MODES or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirement.

4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25% of the specified surveillance interval.

4.0.3 If it is discovered that a surveillance was not performed within its specified surveillance interval, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified surveillance interval, whichever is less. This delay period is permitted to allow performance of the surveillance.

If the surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable ACTION requirements must be met.

When the surveillance is performed within the delay period and the surveillance criteria are not met, the LCO must immediately be declared not met, and the applicable ACTION requirements must be met.

Surveillance Requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL MODE or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation has been performed within the stated surveillance interval or as otherwise specified.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR Part 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR Part 50, Section 50.55a(g)(6)(i);

APPLICABILITY

BASES

3.0.4 (Continued)

The intent of this provision is to ensure that facility operation is not initiated with either required equipment or systems inoperable or other specified limits being exceeded.

Exceptions to this provision have been provided for a limited number of specifications when startup with inoperable equipment would not affect plant safety. These exceptions are stated in the ACTION statements of the appropriate specifications.

4.0.1 This specification provides that surveillance activities necessary to ensure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL MODES or other conditions for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL MODES or other conditions are provided in the individual Surveillance Requirements. Surveillance Requirements for Special Test Exceptions need only be performed when the Special Test Exception is being utilized as an exception to an individual specification.

4.0.2 The provisions of this specification establish the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18 month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

4.0.3 Specification 4.0.3 establishes the flexibility to defer declaring affected equipment inoperable or an affected variable outside the specified limits when a surveillance has not been completed within the specified surveillance interval. A delay period of up to 24 hours or up to the limit of the specified surveillance interval, whichever is less, applies from the point in time that it is discovered that the surveillance has not been performed in accordance with Specification 4.0.2, and not at the time that the specified surveillance interval was not met.

This delay period provides adequate time to complete surveillances that have been missed. This delay period permits the completion of a surveillance before complying with ACTION requirements or other remedial measures that might preclude completion of the surveillance.

The basis for this delay period includes consideration of unit conditions, adequate planning, availability of personnel, the time required to perform the surveillance, the safety significance of the delay in completing the required surveillance, and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the requirements. When a surveillance with a surveillance interval based not on time intervals, but upon specified unit conditions or operational situations, is discovered not to have been performed when specified, Specification 4.0.3 allows the full delay period of 24 hours to perform the surveillance.

Specification 4.0.3 also provides a time limit for completion of surveillances that become applicable as a consequence of MODE changes imposed by ACTION requirements.

Failure to comply with specified surveillance intervals for surveillance requirements is expected to be an infrequent occurrence. Use of the delay period established by Specification 4.0.3 is a flexibility which is not intended to be used as an operational convenience to extend surveillance intervals.

If a surveillance is not completed within the allowed delay period, then the equipment is considered inoperable or the variable is considered outside the specified limits and the time limits of the ACTION requirements for the applicable LCO begin immediately upon expiration of the delay period. If a surveillance is failed within the delay period, then the equipment is inoperable or the variable is outside the specified limits, and the time limits of the ACTION requirements for the applicable LCO begin immediately upon the failure of the surveillance.

Completion of the surveillance within the delay period allowed by this Specification, or within the completion time of the ACTIONS, restores compliance with Specification 4.0.1.

4.0.4 This specification ensures that the surveillance activities associated with a Limiting Condition for Operation have been performed within the specified time interval prior to entry into an OPERATIONAL MODE or other applicable condition. The intent of this provision is to ensure that surveillance activities have been satisfactorily demonstrated on a current basis as required to meet the OPERABILITY requirements of the Limiting Condition for Operation.