Carolina Power & Light Company
ATTN: Mr. W. R. Robinson
Vice President - Harris Plant
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Code: Zone 1
New Hill, NC 27562-0165

SUBJECT: MEETING SUMMARY - SHEARON HARRIS NUCLEAR PLANT SERVICE WATER SELF-ASSESSMENT RESULTS

Dear Mr. Robinson:

This refers to the meeting conducted at your request at our Region II Office on January 11, 1996. The purpose of the meeting was to discuss the status of your self-assessments and ongoing actions concerning service water. It is our opinion that this meeting was beneficial to us in aiding our understanding of your ongoing engineering programs.

In accordance with section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

Should you have any questions concerning this matter, please contact us.

Sincerely, ORIGINAL SIGNED BY PAUL FREDRICKSON

Paul E. Fredrickson, Chief Special Inspection Branch Division of Reactor Safety

Enclosures: 1. Meeting Attendees

2. Licensee Handout

cc w/encls:
J. Cowan, Manager
Operations & Environmental
Support MS OHS7
Carolina Power & Light Company
P. O. Box 1551
Raleigh, NC 27602

7602010168 760117 PDR ADOCK 05000400 P PDR

(cc w/encls cont'd - See page 2)

010031

TE45 3

(cc w/encls cont'd)
J. W. Donahue
Plant Manager - Harris Plant
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P. O. Box 165, MC: Zone 1
New Hill, NC 27562-0165

T. D. Walt, Manager
Regulatory Affairs
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Zone 1
New Hill, NC 27562-0165

R. E. Jones
General Counsel - Legal Department
Carolina Power & Light Company
P. O. Box 1551
Raleigh, NC 27602

Dayne H. Brown, Director
Division of Radiation Protection
N. C. Department of Environmental
Commerce & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

Karen E. Long Assistant Attorney General State of North Carolina P. O. Box 629 Raleigh, NC 27602

Public Service Commission State of South Carolina P. O. Box 11649 Columbia, SC 29211

Chairman of the North Carolina Utilities Commission P. O. Box 29510 Raleigh, NC 27626-0510

Robert P. Gruber Executive Director Public Staff NCUC P. O. Box 29520 Raleigh, NC 27626

(cc w/encls cont'd - See page 3)

(cc w/encls cont'd)
Uva Holland, Chairman
Board of County Commissioners
of Chatham County
P. O. Box 87
Pittsboro, NC 27312

Distribution w/encls: M. Shymlock, RII N. Le, NRR G. A. Hallstrom, RII Document Control Desk

NRC Resident Inspector U. S. Nuclear Regulatory Commission 5421 Shearon Harris Road New Hill, NC 27562-9998

	SEND TO PUBLIC DOCUMENT ROOM? (YES) NO						
L	OFFICE	RII:DRS	RII:DRP	RII:DRŞ	Au:DRS		
	SIGNATURE	K/	- July 2	WX	1/1/1	_	
L	NAME	KELLOGG	Shymildek Wiseman	FREDRICKSON	GIBSON		
L	DATE	01 / 6/ 96	01/17/96	01 / <i>t</i> 7/ 96	01 / / 98	01/ /96	01/ /96
L	COPY?	YES (NO)	YES NO	YES NO	YES WO	YES NO	YES NO

OFFICIAL RECORD COPY DOCUMENT NAME: S:\DRS\SIB\MTGSUM.HAR

MEETING ATTENDEES

Carolina Power and Light

- G. Rolfson, Manager, Harris Engineering Section
- T. Walt, Manager, Performance Evaluation and Regulatory Affairs
- D. Alexander, Supervisor, Licensing
- C. Brown, Supervisor, Support Systems
- D. Hawley, Senior Engineer W. McGoun, Project Engineer


Nuclear Regulatory Commission

- A. Gibson, Director, Division of Reactor Safety (DRS)
 J. Brady, Project Engineer, Division of Reactor Projects (DRP)
 C. Casto, Breach Chief, DRS
 H. Christensen, Branch Chief, DRS

- P. Fredrickson, Branch Chief, DRS
 M. Shymlock, Branch Chief, DRP
 P. Kellogg, Project Manager, DRS
 T. Lee, Project Manager, Office of Nuclear Reactor Regulation
- *D. Roberts, Resident Inspector, DRP

By Telephone

Harris Nuclear Plant Technical Presentation Service Water Systems





Service Water Systems Purpose

Discuss assessments and ongoing actions for the Harris Nuclear Plant Service Water systems.



Service Water Systems Agenda

- Assessments Conducted
- Results and Actions
- Summary



Service Water Systems Assessments Conducted

- Conducted two assessments (Fall 1994)
- Assessed implementation of GL 89-13 program including a knowledgeable industry consultant
- Performed Service Water System Operational Performance Inspection (SWSOPI) utilizing utility/industry team of nine individuals in accordance with NRC TI 2515/118



Service Water Systems

Programmatic Issues

- ◆ Program documentation
- ◆ Test/inspection procedures
- ◆ Program implementation

• Technical Issues

- ◆ Single failure reviews
- ◆ Ultimate heat sink
- **→ ESW flow**



Service Water Systems Programmatic Issues

Issue:

Program Documentation

- Created living program document to identify scope, responsibility, and controls activities
- Defined responsibilities for site staff, including program manager



Service Water Systems Programmatic Issues

Issue

Test/Inspection Procedures

- Revised test/inspection procedures
 - ◆ Improved inspection guidance
 - ◆ Strengthened acceptance criteria
 - ◆ Added guidance for actions if acceptance criteria not met
- Training



Service Water Systems Programmatic Issues

Issue

Program Implementation

- Reviewed committed program scope
- Completed heat exchanger inspections
- Initiated pipe inspections
- Reassessed chlorination commitment



Service Water Systems Technical Issues

Issue

 Incomplete single failure reviews of Essential Services Chilled Water (ESCW) and Component Cooling Water (CCW)

Actions

Completed single failure reviews



Service Water Systems Technical Issues

Issue

Ultimate Heat Sink (UHS)

- Design basis clarified
 - ◆ Architect/Engineer (A/E) Analysis performed analysis
 - ◆ Determined maximum allowable UHS temperature to be 94° F (has never been exceeded)
 - ◆ Established plant controls
- Confirmed licensing basis requirements for both auxiliary and main reservoirs



Service Water Systems Technical Issues

Issue

Emergency Service Water (ESW) flow

- Reviewed ESW thermal and hydraulic design calculations
- Revised ESW flow test acceptance criteria based on design calculations
- ESW tested for new acceptance criteria
- Determined minimum allowable main reservoir level to be 215 feet
- Established plant controls



Issue

Analyses not initiated for some ESW inspection results

- Evaluated and determined that specific examples were satisfactory
- Revised procedures to provide method of documenting inspections and results to ensure appropriate investigation and resolution



Issue

 Some calculations revised without complete understanding of the Design Basis

- Reviewed and revising calculations as necessary; results acceptable
- Recalculated heat loads for margin refinement
- Continue other engineering improvement initiatives



Issue

Procedural guidance for operators

Actions

Completed operations procedure revisions



Issue

Surveillance test program implementation

- Added four valves to IST program
- Began assessment of surveillance testing required to satisfy Technical Specifications - to be completed in Summer 1996



Issue

Interface between design and other plant groups

- Addressing identified problems
- Implemented "plant engineer" concept
- Continue other engineering improvement initiatives



Service Water Systems Self-SWSOPI Identified Strengths

- Overall design of the ESW, CCW, and ESCW System
- Original design calculations and specifications are thorough
- Ongoing rigorous assessment of and proposed improvements to the GL 89-13 program
- Material condition and housekeeping



Service Water Systems Summary

- Improved management of program
- Increased knowledge of system limitations
- Enhanced monitoring/ability to detect degradation
- Reviewing Technical Specification surveillance program
- Developing recommendations for margin improvement

