

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9610100149 DOC. DATE: 96/09/19 NOTARIZED: NO DOCKET #
FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
AUTH. NAME AUTHOR AFFILIATION
ROBINSON, W.R. Carolina Power & Light Co.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch, (Document Control Desk)

SUBJECT: Discusses changes in peak fuel cladding temps resulting from rev to large break LOCA analysis for plant.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: OR Submittal: General Distribution

NOTES: Application for permit renewal filed. 05000400

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME	LTR	ENCL	
	PD2-1 LA		1		PD2-1 PD	1		
	LE,N		1					
INTERNAL:	ACRS		1		FILE CENTER 01	1		
	NRR/DE/EMCB		1		NRR/DRCH/HICB	1		
	NRR/DSSA/SPLB		1		NRR/DSSA/SRXB	1		
	NUDOCS-ABSTRACT		1		OGC/HDS2	1		
EXTERNAL:	NOAC		1		NRC PDR	1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 13 ENCL 0

MMT





Carolina Power & Light Company
PO Box 165
New Hill NC 27562

William R. Robinson
Vice President
Harris Nuclear Plant

September 19, 1996

SERIAL: HNP-96-160
10CFR50.46

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
EMERGENCY CORE COOLING SYSTEM EVALUATION CHANGES

Dear Sir or Madam:

Carolina Power and Light (CP&L) was notified by Siemen's Power Corporation (SPC) on August 19, 1996 of significant changes in the peak fuel cladding temperatures (PCT) resulting from a revision to the large break loss of coolant accident (LBLOCA) analysis for the Harris Plant. The changes to the LBLOCA analysis of record (AOR) and the effects of those changes are being reported in accordance with 10 CFR 50.46(a)(3)(ii). The revised analysis removes the SPC 1991 changes to the TOODEE2 LBLOCA analysis code currently under review by the NRC, and includes the correction of a complier problem. The revised analysis uses the 1986 approved reflood methodology and thereby avoids the concern relative to changes that SPC implemented to the LOCA model which were not specifically reviewed and approved by the NRC.

The new LBLOCA analysis results in a PCT of 1982°F for a 0.8 Double-Ended-Guillotine-Cold-Leg break and middle-of-cycle axial power shape. The previous LOCA analysis which used the 1991 TOODEE2 model reported a PCT of 2025°F for the same break and power shape combination.

This PCT reduction from 2025°F to 1982°F results from three factors. First, Siemens recognized an error associated with the compiler used in the LBLOCA calculations. Correction of that compiler error produced a reduction in the Harris PCT of about 6°F. Based on that assessment, Siemens determined that the Harris analysis of record (AOR) was conservative and it was not formally revised at that time. The compiler error correction is incorporated in this revised analysis.

Secondly, correction of the complier error coincidentally eliminated a conservative, non-physical spurious critical heat flux (CHF) lockout condition occasionally observed in some LOCA computer analysis runs. The CHF lockout was triggered when junction flows at each end of a RELAP4 volume were in opposite directions.

Handwritten: AOR 1/0

9610100149 960919
PDR ADCK 05000400
P PDR



1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for ensuring the integrity of the financial statements and for providing a clear audit trail. The text also mentions that proper record-keeping is a key component of good internal control.

2. The second part of the document focuses on the role of the accounting department in providing timely and reliable information to management. It highlights the need for the accounting staff to stay up-to-date on the latest accounting standards and to maintain a high level of professional competence.

3. The third part of the document discusses the importance of communication between the accounting department and other departments within the organization. It notes that effective communication is crucial for ensuring that all transactions are properly recorded and that any discrepancies are identified and resolved in a timely manner.

These flows were averaged by the RELAP4 code, resulting in a momentary, unrealistically low flow rate being used in the calculation of CHF. This produced an unrealistic spiked decrease in the CHF, resulting in momentary entry into CHF which trips an early CHF lockout in one of the RELAP4 volumes. The early CHF lockout results in an overly-conservative calculation of PCT. The previous AOR for Harris contained this spurious lockout which contributed 115°F to the 2025°F PCT. The correction of the compiler error caused the RELAP4 code to experience a slightly different calculational path. This calculational path coincidentally did not produce the spurious CHF lockout and its 115°F overly-conservative contribution to the PCT. Therefore, the elimination of the spurious CHF lockout reduced PCT for LBLOCA analysis by 115°F.

Removing the 1991 SPC changes to the TOODEE2 model actually produced a + 78°F increase in the PCT. The NRC is currently reviewing the 1991 changes to determine if the changes should have been classified by SPC as a model change to the NRC approved evaluation model.


The LBLOCA analysis changes and resulting PCT contributions discussed above are summarized in the following table.

Base Calculation and Subsequent Individual Changed Conditions	Calculated PCTs	Individual Changed Condition ΔPCTs
Post-1991 TOODEE2 Model Used	2025 °F	-----
Compiler Error Corrected	2019 °F	- 6 °F
Spurious CHF Lockout Eliminated	1904 °F	- 115 °F
Pre-1991 TOODEE2 Model Used	1982 °F	+ 78 °F

Collectively, the changes result in a net decrease in PCT of 43°F. These changes are considered to be significant per 10CFR50.46 (a)(3)(i) and are therefore being reported to the NRC in accordance with 10CFR50.46 (a)(3)(ii). Harris remains in compliance with the requirements specified in 10CFR50.46(b).

Questions regarding this matter may be referred to Mr. T. D. Walt at (919) 362-2711.

Sincerely,



WRW

DBA/dba

- c: Mr. J. B. Brady, HNP Senior Resident Inspector, NRC
- Mr. S. D. Ebnetter, Region II Regional Administrator, NRC
- Mr. N. B. Le, NRR Project Manager, NRC

Handwritten scribbles and marks in the top right corner.

Faint, illegible text or markings in the upper middle section of the page.