

CATEGORY 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9611050232 DOC.DATE: 96/10/31 NOTARIZED: NO DOCKET #
FACIL:50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
AUTH.NAME AUTHOR AFFILIATION
SHYMLOCK,M.B. Region 2 (Post 820201)
RECIP.NAME RECIPIENT AFFILIATION
ROBINSON,W.R. Carolina Power & Light Co. 96-07

SUBJECT: Ack receipt of 961007 ltr informing NRC of steps taken to correct violations noted in insp rept re Shearon Harris Nuclear Power Plant facility.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 5
TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:Application for permit renewal filed. 05000400

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	L	T	ID	CODE/NAME	L	T
	PD2-1	PD	1	1	LE,N		1	1
INTERNAL:	ACRS		2	2	AEOD/SPD/RAB		1	1
	AEOD/TTC		1	1	DEDRO		1	1
	FILE CENTER		1	1	NRR/DISP/PIPB		1	1
	NRR/DRCH/HHFB		1	1	NRR/DRPM/PECB		1	1
	NRR/DRPM/PERB		1	1	NUDOCS-ABSTRACT		1	1
	OE DIR		1	1	OGC/HDS2		1	1
	RGN2	FILE 01	1	1				
EXTERNAL:	LITCO BRYCE,J H		1	1	NOAC		1	1
	NRC PDR		1	1				

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 19

October 31, 1996

Carolina Power & Light Company
ATTN: Mr. W. R. Robinson
Vice President - Harris Plant
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Code: Zone 1
New Hill, NC 27562-0165

SUBJECT: NRC INSPECTION REPORT NO. 50-400/96-07

Dear Mr. Robinson:

Thank you for your response of October 7, 1996, to our Notice of violation issued on September 6, 1996, 1994, concerning activities conducted at your Shearon Harris Nuclear Power Plant facility. We have evaluated your response and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective action during future inspections.

We appreciate your cooperation in this matter.

Sincerely,

(Original signed by M. Shymlock)

Milton B. Shymlock, Chief
Reactor Projects Branch 4
Division of Reactor Projects

Docket No. 50-400
License No. NPF-63

cc: J. Cowan, Manager
Operations & Environmental
Support MS OHS7
Carolina Power & Light Company
P. O. Box 1551
Raleigh, NC 27602

(cc cont'd - See page 2)

9611050232 961031
PDR ADOCK 05000400
G PDR

1/1
Jed1

(cc cont'd)
J. W. Donahue
Director of Site Operations
Carolina Power & Light Company
S. Harris Nuclear Power Plant
P. O. Box 165, MC: Zone 1
New Hill, NC 27562-0165

Bo Clark
Plant General Manager - Harris Plant
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P. O. Box 165
New Hill, NC 27562-0165

T. D. Walt, Manager
Regulatory Affairs
Carolina Power & Light Company
Shearon Harris Nuclear Power Plant
P. O. Box 165, Mail Zone 1
New Hill, NC 27562-0165

W. D. Johnson, Vice President
and Senior Counsel
Carolina Power & Light Co.
P. O. Box 1551
Raleigh, NC 27602

Dayne H. Brown, Director
Div. of Radiation Protection
N. C. Dept. of Environmental
Health & Natural Resources
P. O. Box 27687
Raleigh, NC 27611-7687

Karen E. Long
Assistant Attorney General
State of North Carolina
P. O. Box 629
Raleigh, NC 27602

Public Service Commission
State of South Carolina
P. O. Box 11649
Columbia, SC 29211

(cc cont'd - See page 3)

(cc cont'd)
 Chairman of the North Carolina
 Utilities Commission
 P. O. Box 29510
 Raleigh, NC 27626-0510

Robert P. Gruber
 Executive Director
 Public Staff NCUC
 P. O. Box 29520
 Raleigh, NC 27626

Uva Holland, Chairman
 Board of County Commissioners
 of Chatham County
 P. O. Box 87
 Pittsboro, NC 27312

Distribution:

M. Shymlock, RII
 M. N. Miller, RII
 R. Aiello, RII
 G. A. Hallstrom, RII
 N. Le, NRR
 PUBLIC

NRC Resident Inspector
 U. S. Nuclear Regulatory Comm.
 5421 Shearon Harris Road
 New Hill, NC 27562-9998

* (See previous concurrence)

OFFICE	RII:DRP	RII:DRP		
SIGNATURE	<i>[Signature]</i>	*		
NAME	GMacDonald:ser	JBrady		
DATE	10 / 14 / 96	10 / / 96	10 / / 96	10 / / 96
COPY?	(YES) NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\HARRIS\9607ACK.LTR

CP&L

3

(cc cont'd)
 Chairman of the North Carolina
 Utilities Commission
 P. O. Box 29510
 Raleigh, NC 27626-0510

Robert P. Gruber
 Executive Director
 Public Staff NCUC
 P. O. Box 29520
 Raleigh, NC 27626

Uva Holland, Chairman
 Board of County Commissioners
 of Chatham County
 P. O. Box 87
 Pittsboro, NC 27312

Distribution:

- M. Shymlock, RII
- M. N. Miller, RII
- R. Aiello, RII
- G. A. Hallstrom, RII
- N. Le, NRR
- PUBLIC

NRC Resident Inspector
 U. S. Nuclear Regulatory Comm.
 5421 Shearon Harris Road
 New Hill, NC 27562-9998

OFFICE	RII-DRP	RII-DRP		
SIGNATURE	<i>[Signature]</i>	<i>[Signature]</i>		
NAME	MacDonald	Brady		
DATE	10/24/96	10/24/96	10 / / 96	10 / / 96
COPY?	(YES) NO	(YES) NO	YES NO	YES NO

OFFICIAL RECORD COPY DOCUMENT NAME: G:\HARRIS\9607ACK.LTR



**ROI 0917 CHECKLIST
EVALUATION OF LICENSEE CORRECTIVE ACTIONS FOR VIOLATIONS**

PLANT NAME: HARRIS

RESPONSE RECEIVED: 9/07/96

INSPECTION RPT NO: 50-400/96-06

VIOLATION NO: 96-06-01

RII MANAGEMENT ASSESSMENT OF LICENSEE'S CORRECTIVE ACTIONS

Was the Root Cause for the Violation Addressed? If no, explain. YES

Were the Steps Taken Adequate to Correct the Problem and Prevent Future Violation? Yes. And further steps will include the continuing FSAR review, and review of the process for "engineering reply" type ESRs.

Results Achieved: The spare pump and breaker in the CCW system were placed under clearance and a 50.59 review was completed justifying past operation without the overload protective interlocks. Operating procedures were revised and mechanical interlocks were installed on the "B" train breakers in September.

Additional Corrective Steps That Will Be Taken: A review of the ESR process (for "engineering replies"), a continuing FSAR review, and the installation of mechanical interlocks on the "A" train breakers.

Date of Full Compliance Indicated: ●Yes, July 19, 1996.

RECOMMENDED ACTIONS:

Response Letter X

PREPARED BY:

GRWiseman

[Signature]

10/28/96
Date

APPROVED BY:

MBSnymlock

[Signature]

10/28/96
Date

[Signature]

10-31-96